

Serial Number: SS17947823

Customer: M/s MAMTA ELECTRICALS

Customer P.O Number: MAMTA/23-24/017

Customer P.O Date: 16-DEC-2024

Voltage: 240V

Current: 05-30A

Accuracy Class: 1.0

Ref. Standard: IS : 13779

Meter Constant: 6400

1. AC VOLTAGE TEST: PASS
2. TEST OF NO LOAD CONDITION: PASS
3. TEST OF STARTING CURRENT: PASS
4. INSULATION TEST: PASS
5. METER ACCURACY:-

Reference Conditions: Vref = 240V/50Hz Ib = 05-30A Amb. Temp = 27 +/- 2 Deg. C

METER ACCURACY


% Active Import Errors


Load % Ib	0.5 Lag	0.8 Lead	UPF
600	0.4	0.0	0.0
100	0.2	0.1	0.1
10	0.2	0.1	0.1
5			0.1

00001.0

TEST DATE: 05/03/2025

This is computer generated test report no signature required


Meter Tester Gr - I
MTI Laboratory
MePDCL, Lumjingshai
Shillong


Executive Engineer
MTI Division
MePDCL, Shillong

ELECTION COMMISSION OF INDIA

IDENTITY CARD DHJ0555521



Name: KIRPA SINGH

Residence Name: K. SINGH

Sex: M

Age on 01.11.2006: 26

IDENTITY CARD DHJ0555521

Address: 26 LAWSYWA (KHYIM SYENSHIP)

Town/Vill: LAWSYWA

District: RI BHOI Pin: 743114

Signature

Electoral Registration Officer

For 11 UMSNING Assembly Constituency

Place: RI BHOI

Date: 03.11.2006

OFFICE OF THE DORBAR SHNONG LAWBYRWA

Raid Mawbuh Myllem Syiemship
Ri-Bhoi District, Meghalaya 793104

Under Rule 10(3) of the Administration of Myllem Syiemship Rules, 2015 of the Khasi Hills Autonomous District
(Appointed and succession of Syiem, Deputy Syiem, Electors and Rangbah Shnong of Myllem Syiemship) Act 2007

No DSL/DK/2023/ 17

Dated Lawbyrwa The 30th Nov, 2023.

KA DULIR KHYNDEW

Nga U Bah/ Ka Kong Plarmai Nongbsap ba shong ba sah ha ka Shnong
ryngkat ka jingia don lang bad ki khun ki kli hapteng ka jingkoit jingkhiah bad jingtip
briew tip Blei ngi la die duh noh shi lyngkhol ia ka jaka jong ngi kaba don ha Lawbyrwa, Ri-Bhoi District, ha phi U
Bah/Kong Kairin Lyngdoh ha ka dor
Rs _____ (Rupees _____) only

Kat kum kine ki pud sawdong harum:

1. Mihngi: la khap ka jaka Mary Jane Sana & Sutar Shnong - 124 ft
2. Sepngi: la khap ka jaka Plarmai Nongbsap - 200 ft
3. Shatei: la khap ka jaka Hister Nongbsap & Sutar Nongbsap, Soin, Nongbsap - 154 ft
4. Shathie: la khap ka jaka Plarmai Nongbsap - 100 ft

Ka Total Area ka long _____

Te naduh mynta ka sngi ka 30-11-2023 ka la dei ka hok ka jong phi U/Ka nongthied bad phi dei
ban peit ban sumar ia la ka jong ka jaka bad kumjuh phi dei ban kohnguh ia ka jingpyniaid ka Shnong ka Thaw bad
lada ka Shnong ka lap ba phi leh pyrshah ia ka jingpyniaid ka Shnong kan sa leh kat kum ki ain Shnong.

Nga U Bah/Ka Kong Kairin Lyngdoh khlem kino kino ki jingpynbor
nga kloil ban bud bad kohnguh ia ki jingpyniaid ka Shnong Ka Thaw ka Raid Mawbuh Myllem Syiemship.

Nongdie

Plarmai Nongbsap P. Nongbsap

Nongthied

Kairin Lyngdoh. K. Lyngdoh

Ki Sakhi:

1. Pyrdan Mahnari - P. Mahnari
2. Arjun Lyngdoh - A.S. Lyngdoh
3. Nanboktor L. Nongbri - W. Shyngdoh
4. Laibhenbor Kharkrang - Kharkrang
5. Shalmanik L. Nongbri - Shalmanik
6. _____

Willstarbor Lyngdoh
Rangbah Shnong
(Rijied Kharkrang)
Rangbah Shnong

Willstarbor Lyngdoh
Secretary Shnong
Lawbyrwa
(Willstarbor Lyngdoh)
Secretary Shnong

To,

The Assistant Executive Engineer
Umiam Distribution Sub-Division
MCPDCL Umiam.

Sub: Clarification

Sir,

with reference to the above, I Smti.
Kairin Lyngdoh would like to clarify you that
Smti T.L Nongbri and Kairin Lyngdoh refer to
the same person as mentioned in the Electricity
bill. Due to Variation in Spelling the names
may appear differently in various records. This
clarification is necessary for official records and
all other purposes.

I kindly request you to noted and update
my record and documents with my new name
Smti. Kairin Lyngdoh

I would appreciate your assistance in this
matter.

K. Lyngdoh
Yours faithfully.

Headmas

Proved



Rijied Kharkrang
Rangbah Shnong Lawbyrwa
Ri Bhoi District

(Smti Kairin Lyngdoh)
P. O. Sumer - No 5
Lawbyrwa - village
Ri-Bhoi - 793104.

II. Type of wiring *B+C wiring pip*

III. Voltage and system of supply *220V*

IV. Test Result *o/k*

Date of testing by licensed contractor

1 9 0 6 . 2 5

	Type of test	Result of test carried out by licensed contractor (in MΩ) / Ω	Result of test carried out by the supplier under relevant Cea regulations, (in MΩ) / Ω
(a)	Insulation resistance between earth and whole system of conductor.	<i>100 mΩ</i>	
(b)	Insulation resistance between all conductors	<i>120 mΩ</i>	
(c)	Earth continuity between earth electrode and earth continuity conductor	<i>300</i>	
(d)	Polarity of non-linked SP switches	<i>0Ω (P.N. 220V) EN. 0V</i>	

V. Full name with signature of licensed contractor (with date)

LIC No.

Mobile No.

M/s. R. D. Electrical
Electrical Contractor
Lic. No : 381

VI. Full name with signature of supervisor (with date)

LIC No.

Mobile No.

Mr. R. Dohdong
Electrical Supervisor
Regd. No: 459

VII. Full name with signature of wireman (with date)

LIC No.

Mobile No.

Mr. R. Dohdong
Electric Wireman
Regd. No: 2126

VIII. Signature of the authorized official who

tested the installation on behalf of supplier (with date)

Mobile No.

IX. Date of connection of supply to the installation

Meghalaya Power Distribution Corporation Limited
Test Report

This is to certify that repaired/renewed/additional/new electric installation at the premises of

Full name

K A I R I N - L Y N G D O H

(Please leave one block between name & surname)

Address

L A A B I R W A

1. The load has been arranged as follows:

Details of load	Wattage of each item	Phase I		Phase II		Phase III		Total wattage of all 3 phases
		No. of points	Total wattage	No. of points	Total wattage	No. of points	Total wattage	
1. Light points	60w.	4	240w					
(i) Fluorescent								
(ii) Incandescent								
(iii) CFL 110	9w	10	90w					
(iv) Halogen								
(v) Others								
2. Fan points								
3. Plug points (3-Pin)								
(i) 6 Amps	100w	4	400w					
(ii) 16 Amps	1000w	1	1000w					
4. Electrical gadgets								
(i) Water Heater (Geyser)								
(ii) Refrigerator								
(iii) AC								
(iv) Others								
5. Welding transformer								
6. Motor								
Total								
In case of load enhancement existing load (in watts)								
Total load in the premises (in watts)			1730w or 2kw					

Notes:

(a) Details of any apparatus (other than the above mentioned) should be given.

(b) Rating of capacitor used in induction Motor and welding

Transformer (Test report of capacitor is to be enclosed)

KVAR

Provided that on the part of the MePDCL notice shall be given to the consumer stating the reasons for the proposed termination and giving him opportunity to state his case and his statement, if any duly considered before the agreement is terminated and the supply of electricity cut off;

(7) The terms and conditions of this agreement shall be effective from the date of supply of electricity is commenced.

IN WITNESS WHEREOF the parties hereto have set their hands and seals the date, month and year first above written.

K. 1429204
Consumer

For and behalf of MePDCL.

Witness:

1. Signature:

Name:

Address:

2. Signature:

Name:

Address:



Agreement for supply of electricity Low

An agreement made this the 7th day of Aug of 2025 between Kavindya Lal and his successor and assigns (hereinafter referred to as the consumer) of the one part and the Meghalaya Power Distribution Corporation Limited an electricity distribution licensee under the EA, 2003 and its successors and assigns (hereinafter referred to as the Distribution Utility / MePDCL) of the other part.

Note: the term 'consumer' includes an individual person (whether male or female), a body of persons, a company, society, firm, association or organisation.

Whereas, the consumer has applied to the distribution utility for supply of electricity to the premises and the distribution utility has agreed to give the supply under the terms and conditions hereinafter appearing;

Now, therefore, the agreement witness –

- (1) That the supply shall be given to the premises located at Lawbylao with the consumer as owner / occupier of;
- (2) That the supply shall be for the purpose of DLT
The load whereof shall not exceed 2kW watts
- (3) That the provisions of the EA 2003 and the regulations, code and orders including tariff orders, as may be made from time to time by the MSERC shall apply and bind the consumers and the distribution utility alike;
- (4) That the consumer shall regularly and timely pay to MePDCL all charges as may be due for the supply of electricity;
- (5) That the agreement shall be a period of two years and may be renewed for a further period;
Provided that supply shall not be terminated by mere efflux of time if the consumer is willing that the agreement is renewed;
- (6) That the agreement shall be terminated if the consumer on its part desires it so and gives to the MePDCL a prior notice of not less than one month or, on the part of the MePDCL, if the consumer has violated any of the terms and conditions of the agreement.

1406

Additional meter

APPLICATION FORM FOR PROVIDING LT SERVICE CONNECTION
(FOR ALL CATEGORY AND FOR ALL PURPOSE)

230. K.V.A

To

The Area Manager / Asst Executive Engineer
Service Connection Sub-Division/ Distribution Sub-Division
MeECL
(Indicate the local men of the jurisdiction of the Engineer of the licensee)

Sir,

1. I / We hereby request you to supply electricity to the premises located at the address fully described below. I/We are the owner / lawful occupier of the premises.
2. I/We agree to abide by the terms and condition relating to the supply of electricity by MeECL and to make all payments as may be required and also to pay regularly all the charges as may become due.
3. a) Full name and address of the applicant with contact telephone number.

Shmt - Kairin Lyngdoh

b) Status in relation to the premises.

Owner

☒

Occupier

☐

c) Location and address of the premises including Police Station.

d) Nature of LT Supply: Commercial

☐

Domestic

☒

Industrial

☐

General Purpose

☐

WSLT

☐

PL

☐

Agriculture

☐

KJ

☐

2KW Load Sanction from
Lawbyrwa 250 KW 8/2
8/8/25
Junior Engineer
Umiam Distribution Sub Division-I
Me. P.D.C.L. Umiam

K. LYNGDOH
Applicant's Signature

NB : The following documents are to be enclosed:

- 1) Test Report from Licensed contractor.
- 2) Agreement Form duly filled in.
- 3) Proof of ownership (in case the applicant is owner)
- 4) Number of the nearest Electric Pole.
- 5) NOC of the owner of the premises (in case the applicant is occupier).
- 6) Attested copy of permission obtained from Pollution Control Board.
- 7) Building permission from the concerned authority.

Kang Angeline please take
necessary action
Junior Engineer
Umiam Distribution Sub Division-I
Me. P.D.C.L. Umiam

NEW CONSUMER APPLICATION FORM

☐ If Consumer Apply for Sub-Meter/ Additional Connection
(Please tick on the check box)



Personal Details

* Application No

* Consumer Name

* Husband's Name

* Mobile No

* Aadhaar / EPIC No.

Kaisin Lyngdoh

K. Basaiawmoit

8974109045

Email

DHJ0555821

Address Details

* Accommodation

* Discom

* Zone

* Sub-Division

* Village Name

* State

* Area Pin Code

* Full Address

- Own / Rented (Pl. tick one)

- Meghalaya Power Distribution Corporation

- Eastern Zone * Circle - Ribhoi Circle * Division - Umiam Division

- Umiam Distribution Sub-Division

- Lawbywa

- Meghalaya * City - Ribhoi (Nongpoh)

- 793104 Locality - Lawbywa

- Lawbywa

New Connection Details

* Consumer Type: SG / CG / NG (Pl. tick one)

* Urban/Rural Type: Rural / Urban (Pl. tick one)

* Activity

- House

* Contract Load Unit

- KW / KVA (Pl. tick one) * Contract Load: 2KW

* Category

- Domestic * Product Type: LT / HT (Pl. tick one)

* Scheme

- All Categories excluding industrial / Industrial / Free Scheme /
Saubhagya / DDUGJY (Pl. tick one)

Other Details

* Meter Number

- SS17947823

* Initial KWH - 1.0 * Initial KVAH - 1.0

* Meter MF

- 1

Meter Owned - Utility / Consumer (Pl. tick one)

* Phase

- 1 Phase / 3 Phase (Pl. tick one) * TMC - Yes / No (Pl. tick one)

Meter Reader

Group No.

List of Documents to be attach:

- * Test Report
- * Ownership Proof
- * Identity Proof
- * Meter Test Report
- * Landlord NOC
- * Agreement Fill
- * Pollution Control Board

Date of Connection:

All fields mark with * are mandatory