

Meghalaya Energy Power Distribution Corporation Limited

TEST REPORT

This is to certify that repaired/renewed/additional/new electric installation at the premises of

S H R I L A C H L A N L I A M K H A R M A L K I

(Please leave one block between name & surname)

(Full Name)

S I E J I O N G S L I P R A

(Address)

is duly completed, tested and is ready for your Engineer to test and connect on your main line.

1 The load has been arranged as follows :-

Details of Load	Wattage of each Item							Total watt of all 3 phases
		No. of points	Total Watt	No. of points	Total Watt	No. of points	Total Watt	
1 Light points (i) Fluorescent (ii) Incandescent (iii) CFL (iv) Halogen (v) Others	9 W	60 Nos	540 W					
2 Fan points	60 W	4 Nos	240 W					
3 Plug points (3-pin) (i) 6 Amps (ii) 16 Amps	100 W 1000 W	7 Nos 2 Nos	700 W 2000 W					
4 Electrical gadgets (i) Water Heater (Geyser) (ii) Refrigerator (iii) Air Conditioner (iv) Others	1000 W	1 No	1000 W					
5 Welding Transformer								
6 Motor								
Total		4480						
In case of load enhancement Existing load (in watts)								
Total load in premises (in watts)		4480 W	Say	5 Kws				

Notes -

- Details of any apparatus (other than the above mentioned) should be given
- Rating of capacitor used in Induction Motor and Welding Transformer (Test report of capacitor is to be enclosed)

KVAR