

Meghalaya Power Distribution Corporation Limited

TEST REPORT

This is to certify that/repaired/additional/ enhancement/ reduction/new electric installation at the premises of

S H R A N O D H T D O N G

(Please leave one block between name & surname)

(Full Name)

M A W L O N G K H A P S B E R

(Address)

is duly completed, tested and is ready for your Engineer to test and connect on your main line.

I. The load has been arranged as follows :-

Details of Load	Wattage of each item	Phase - 1		Phase - 2		Phase - 3		Total watt of all 3 phases
		No. of points	Total watt	No. of points	Total watt	No. of points	Total watt	
1. Light points (i) Fluorescent (ii) Incandescent (iii) CFL, LED ✓ (iv) Halogen (v) Others	20 W	10	200 W					
2. Fan points								
3. Plugs points (3-pins) (i) 6 Amps (ii) 16amps	100 W 1000 W	5 1	500 W 1000 W					
4. Electrical gadget (i) Water Heater (Geyser) (ii) Refrigerator (iii) Air Conditioner (iv) Others								
5. Welding Transformer								
6. Motor								
Total			1700 W					
In case of load enhancement Existing load (in watt)								
Total load in the premises (in watt)								

I Note:-

(a) Detail of any apparatus (other than the above mentioned) should be given.