

NEW CONSUMER APPLICATION FORM

(1567)



If Consumer Apply for Sub-Meter/ Additional Connection
(Please tick on the check box)

Personal Details

*Application No: 223202260039
 *Consumer Name: Hameilang Kharbudnah
 *Father's Name: D. S. Jana Mother's Name: Thrian Kharbudnah
 *Mobile No: 6009949473 Email: _____
 *Aadhaar / EPIC No: ZBV0011916

Address Details

*Accommodation: Own / Rented (Pl. tick one)
 *Discom: Meghalaya Power Distribution Corporation
 *Zone: Eastern Zone *Circle: Ribhoi Circle *Division: Umiam Division
 *Sub-Division: Umiam Distribution Sub-Division
 *Village Name: Mawpun Kshaid
 *State: Meghalaya *City: Ribhoi (Nongpoh)
 *Area Pin Code: 793103 Locality: Mawpun Kshaid
 *Full Address: Mawpun Kshaid

New Connection Details

*Consumer Type: SG / CG / NG (Pl. tick one) *Urban/Rural Type: Rural / Urban (Pl. tick one)
 *Activity: Shop
 *Contract Load Unit: KW / KVA (Pl. tick one) *Contract Load: 2KW
 *Category: Commercial *Product Type: LT / HT (Pl. tick one)
 *Scheme: All Categories excluding industrial / Industrial / Free Scheme / Saubhagya / DOUGJY (Pl. tick one)

Other Details

*Meter Number: _____ *Initial KWH: _____ *Initial KVAH: _____
 *Meter Mf: _____ Meter Owned - Utility / Consumer (Pl. tick one)
 *Phase: 1 Phase / 3 Phase (Pl. tick one) *TMC: Yes / No (Pl. tick one)
 Meter Reader: _____ Group No: _____

List of Documents to be attach:

- *Test Report
- *Ownership Proof
- *Identity Proof
- *Meter Test Report
- Landlord NOC
- Agreement Fill
- Pollution Control Board

Date: _____

- Sir,
1. I / We hereby request you to supply electricity to the premises located at the address fully described below. I/We are the owner / lawful occupier of the premises.
 2. I/We agree to abide by the terms and condition relating to the supply of electricity by MeECL and to make all payments as may be required and also to pay regularly all the charges as may become due.

3. a) Full name and address of the applicant with contact telephone number. **600 9949473**
Wanrilang Kharbudnah

b) Status in relation to the premises. Owner
Occupier

c) Location and address of the premises including Police Station.

Mampun Kshaid

d) Nature of I T Supply: Commercial Domestic
Industrial General Purpose
WSLT PL
Agriculture KJ

**Sanction from
Kshaid 100KVA Dt**
[Signature]

W.k. budnah
Applicant's Signature

**Junior Engineer (EL)
Uiam Dist. Sub-Division
MePDCL, Uiam**

Following documents are to be enclosed:

- Test Report from Licensed contractor.
- Agreement Form duly filled in.
- Proof of ownership (in case the applicant is owner)
- Number of the nearest Electric Pole.
- NOC of the owner of the premises (in case the applicant is occupier).
- Attested copy of permission obtained from Pollution Control Board.
- Building permission from the concerned authority.



Agreement for supply of

An agreement made this the 10th day of September 2026 between Leovaty Kshaid and his successor and assigns (hereinafter referred to as the consumer) of the one part and the Meghalaya Power Distribution Corporation Limited an electricity distribution licensee under the EA, 2003 and its successors and assigns (hereinafter referred to as the Distribution Utility / MePDCL) of the other part.

Note: the term 'consumer' includes an individual person (whether male or female), a body of persons, a company, society, firm, association or organisation.

Whereas, the consumer has applied to the distribution utility for supply of electricity to the premises and the distribution utility has agreed to give the supply under the terms and conditions hereinafter appearing;

Now, therefore, the agreement witness –

Manjun Kshaid

- (1) That the supply shall be given to the premises located at _____ with the consumer as owner / occupier of;
- (2) That the supply shall be for the purpose of Commercial
The load whereof shall not exceed 2000 watts
- (3) That the provisions of the EA 2003 and the regulations, code and orders including tariff orders, as may be made from time to time by the MSERC shall apply and bind the consumers and the distribution utility alike;
- (4) That the consumer shall regularly and timely pay to MePDCL all charges as may be due for the supply of electricity;
- (5) That the agreement shall be a period of two years and may be renewed for a further period;
Provided that supply shall not be terminated by mere efflux of time if the consumer is willing that the agreement is renewed;
- (6) That the agreement shall be terminated if he consumer on its part desires it so and gives to the MePDCL a prior notice of not less than one month or, on the part of the MePDCL, if the consumer has violated any of the terms and conditions of the agreement.

Provided that on the part of the MePDCL notice shall be given to the consumer stating the reasons for the proposed termination and giving him opportunity to state his case and his statement, if any duly considered before the agreement is terminated and the supply of electricity cut off.

(7) The terms and conditions of this agreement shall be effective from the date of supply of electricity is commenced.

IN WITNESS WHEREOF the parties hereto have set their hands and seals the date, month and year first above written.

W.K. Bhandari
Consumer

For and behalf of MePDCL.

Witness:

1. Signature:

Name:

Address:

2. Signature:

Name:

Address:

Meghalaya Power Distribution Corporation Limited
Test Report

This is to certify that repaired/renewed/additional/new electric installation at the premises of

Full name

WANRILANG KHARBUDNAH

(Please leave one block between name & surname)

Address

MAWPUN KSHAID

1. The load has been arranged as follows:

Details of load	Wattage of each item	Phase I		Phase II		Phase III		Total wattage of all 3 phases
		No. of points	Total wattage	No. of points	Total wattage	No. of points	Total wattage	
1. Light points								
(i) Fluorescent								
(ii) Incandescent								
(iii) CFL								
(iv) Halogen								
(v) Others / LED	9Watt	5 Nos	45					
2. Fan points								
3. Plug points (3-Pin)								
(i) 6 Amps	100Watt	5 Nos	500					
(ii) 16 Amps	1000Watt	1 No	1000					
4. Electrical gadgets								
(i) Water Heater (Geyser)								
(ii) Refrigerator								
(iii) AC								
(iv) Others								
5. Welding transformer								
6. Motor								
Total			1545					
In case of load enhancement existing load (in watts)								
Total load in the premises (in watts)			2kW					

Details of any apparatus (other than the above mentioned) should be given.
Rating of capacitor used in induction Motor and welding transformer (Test report of capacitor is to be enclosed)

KVAR

II. Type of wiring

III. Voltage and system of supply

IV. Test Result

Date of testing by licensed contractor

Casy Cappi
230V/1

28012026

	Type of test	Result of test carried out by licensed contractor (in MΩ) / Ω	Result of test carried out by the supplier under relevant Cea regulations, (in MΩ) / Ω
(a)	Insulation resistance between earth and whole system of conductor.	110 MΩ	
(b)	Insulation resistance between all conductors	107 MΩ	
(c)	Earth continuity between earth electrode and earth continuity conductor	3Ω	
(d)	Polarity of non-linked SP switches	0V (PN-230V) EM-0.2V	

V. Full name with signature of licensed contractor (with date)

LIC No.

Mobile No.

M/s. R. D. Electrical
 Pvt. Electrical Contractor
 Lic. No: 381

VI. Full name with signature of supervisor (with date)

LIC No.

Mobile No.

Mr. R. Dohdong
 Electrical Supervisor
 Regd. No. 459

VII. Full name with signature of wireman (with date)

LIC No.

Mobile No.

Mr. R. Dohdong
 Electrical Wireman
 Regn NO - 2126

VIII. Signature of the authorized official who

tested the installation on behalf of supplier (with date)

Mobile No.

IX. Date of connection of supply to the installation

DORBAR SHNONG MAWPUN KSHAIID

RAID MAWBUH, MYLLIEM SYIEMSHIP
 P.O. BOX 50, NUAL RI-BROI DISTRICT, MEGHALAYA-78600

Under Rule 14 (2) of the Administration of Mylliem Syiemship Rules, 2015 of the Khasi Hills Autonomous District Council (Appointments and Succession of Syiem, Deputy Syiem, Electors, and Rangbah Shnong of Mylliem Syiemship) Act, 2007.

Date 4-01-2023

DORBAR DSMIS/111/2022-23/53

KA DULIR KHYNDEW

Nga UKa Kwila Kharbani UKa ba dei
 Ka Trai Jaka ha kane ka sngi ka 4-01-2023 hapdeng ka jingkoit jingkhiah, ka jingtipbriew
 ia bad da ka jinglapynbeit bad ia sngewitah jingmut lang ha ing ha sem, nga wan ban ai siew bai lutksan noi
 ia ka Jaka/Khyndew ba dei hok jong nga kaba don ha Maupun Isshaid ba shong ba
 shphi UKa wanrilang kharbudnah ha ka dor
 sah ha Maupun Isshaid
 Rs. 1,00,000/- (Shi Lak) bed ia ka Dulir Khyndew
 tyngka. Ha kaba ia ka tyngka la ioh dep mynta ka sngi ka 4-01-2023
 la aiti sha phi UKa wanrilang kharbudnah UKa Nongshim bai lutksan.

KI SAWDONG PUD KA JAKA

- MIHNGI : Jaka ia khat naduh ka nala 2m2 - 10 ft
- SEPNGI : Jaka ia khat bad i kong kwila kharbani. - 7 ft
- SHATEI : Jaka ia khat bad ia Surde Bye-Passed - 75 ft
- SHATHIE : Jaka ia khat Maupun Ma khat wah Fishery - 75 ft

Ka Jingheh ka jaka - 3037.5 Sq. ft

Naduh kane ka sngi katei ka jaka ka ba la ai sawdong pud haneng, kan dei hok ka jong phi bad ki pateng
 jong phi. Ma nga lem bad ki pateng jong nga, ngim don hok shuh ban kam trai ia ka.

Hynrei lada don ba uxor ne ba pynwit ia ka jingdakhol jong phi ia katei ka jaka, ka jingkitkhlich baroh
 kan long ka jong nga ba ai siew.

La leh ia kane ha khmat u Rangbah Shnong lem bad ki sakhi satar.

Sakhi:

- Pyntngen Markhap. PM
- Carlton Kharpyntiew (Kwila Kharbani) (wanrilang) kharbudnah
- Lidar Kus Mongliet Longiz Nongdie Nongthied

Ka Rai jong ka Dorbar Shnong ka long ba phim bit ban aiti ne die shawei pat khlem ka jingtip ki
 Nongsynshar Shnong.

Ce: tied to be true copy

Sub-Registrar
 Nongboh

21/2/24

Rangbah Shnong

Bandari Rymtithiang
 Rangbah Shnong

S. Nongrum
 Synrap Nongrum
 Secretary

Secretary

भारत निर्वाचन आयोग
ELECTION COMMISSION OF INDIA
भारत निर्वाचन आयोग - भारत निर्वाचन आयोग



ZBV0011916



Name : WANRILANG
KHARBIUDNAH

Father's Name : S JANA

SEX : Female
DATE OF BIRTH/AGE : 02/10/1992
ADDRESS:
HNo.87, MAWPUN KSHAID,
VILL-MAWPUN KSHAID,
DIST-RLBHOI-793103

Date: 22-7-2018 Electoral Registration Officer

Assembly Constituency No & Name :
12 - UMROI

Part No and Name :
24 - MAWPUN KSHAID

ध्यान / Note

1. यह कार्ड केवल निर्वाचन के लिए ही उपयोग किया जा सकता है। इसे किसी भी अन्य उद्देश्य के लिए नहीं प्रयोग किया जाना चाहिए।

2. ध्यान दें कि निर्वाचन आयोग के द्वारा जारी किए गए निर्वाचन कार्डों में उल्लिखित जानकारी का उपयोग केवल निर्वाचन के लिए ही किया जा सकता है।

3. निर्वाचन आयोग के द्वारा जारी किए गए निर्वाचन कार्डों में उल्लिखित जानकारी का उपयोग केवल निर्वाचन के लिए ही किया जा सकता है।
Date of Birth mentioned in this card can't be required as a proof of age (13 B). For any purpose other than registration in electoral roll.

UNIAM SUBDIVISION
1000200568

2232005
Wanrilang Kharbudhari
Mawpun (Umroi),
Mawpun (Umroi)
3061205800

Single Phase Static Wattour Meter
240 Volt/5-30 A / 50 HZ
1
3200 Impulse/Kwh
IS 13779 : 1999

Maximum Demand Load
Meter No.
D.M.I. (Cons)
Total Tariff Diff

Billing Details
Prev. Reading Date 04/07/2025
Cur. Reading Date 05/08/2025
No. of Days
Bill Number 2232005256805067
Bill Status OK (No meter)
Prev KWH 936.0
Current KWH 941.4
Billed Unit 5.4
Recorded MD
Power Factor
Average

Bill Charges
Fixed Charges (Unit, Rate, Amount)
1.0 KW 90.0 92.90
Energy Charges (Unit, Rate, Amount)
49.0 5.0 245.00
ED Amount (Unit, Rate, Amount)
49.0 0.05 2.45
FPPAS -15.14
(JUN 25 TO JUN 25 : -15.140)
Current Bill Amt 325.21
Consumer Credit -0.13
Adjustment 0.00
Tariff Diff(8/9 Inst.) 53.77
Gross Bill Amount 328.85

Net Bill Amount ₹ 379.00
Due Date 28/08/2025
Last Payment Date 08/07/2025
Last Payment Amount 295

This bill will be construed as final notice under section 13 of the
MSERC (Electricity Supply Code) Regulations, 2018. Supply of
electricity shall be disconnected at any date, if dues of electricity
bill is not paid within 15 (fifteen) days (notice period) from the
date of the bill. Thanks for paying, We really appreciate it.



For Bill Payments, Please visit www.meghapower.com OR
Download Megha Power App from Google Playstore

used following routine test as per
n :

	RESULT
Passed	Passed
Passed	Passed
Passed	Passed
Passed	Passed
Passed	Passed
Meter accuracy observed within ± 1%	

Certified Signature

Anant Ashantha

15/3/2025

01

4997282

[Signature]

Executive Engineer
MTI Division
Met DCL, Shillong

**BENLO
BENTEC INDIA LIMITED**

Test Certificate

Items Single Phase Static Wattour Meter
Rating 240 Volt/5-30 A / 50 HZ
Class 1
Meter Constant 3200 Imulse/Kwh
Standard IS 13779 : 1999

The meter was tested & has passed following routine test as per
IS : 13779 at reference Condition :

TEST	RESULT
No Load Conditions	Passed
AC Voltage Test	Passed
Insulation Resistance Test	Passed
Starting Test	Passed
Meter Accuracy Test	Passed
	Meter accuracy observed within $\pm 1\%$

Office
150, Open Banerjee Road ,
Kolkata - 700060 (INDIA)


Certified Signature




15/3/2025

Meter Initial Reading: 000001

METER SERIAL NUMBER	4997282
----------------------------	----------------


Meter Tester Gr - 1
MTI Laboratory
MePDCL, Lumjingshal
Shillong


Executive Engineer
MTI Division
MePDCL, Shillong

DORBAR SHNONG MAWPUN KSHAIID

RAID MAWBUH, MYLLIEM SYIEMSHIP

P.O. & P.S UMIAM, RI-BHOI DISTRICT, MEGHALAYA-793103


Under Rule 10 (3) of the Administration of Myllem Syiemship Rules, 2015 of the Khasi Hills Autonomous District Council (Appointment and Succession of Syiem, Deputy Syiem, Electors, and Rangbah Shnong of Myllem Syiemship) Act, 2007.

Ref No. DSMK/NDC/2026-27/01

Date 28.01.2026

To whom it may concern

This is to certify that i have no objection for
santi wawitany khathudual D/O (k) Jana to
transfer the electricity connection in her residence
at mawpun kshaid, Ri Bhoi district PO-793103


Bandari Rynthiang
Rangbah Shnong
Mawpun Kshaid