

EB Schedule I Form 7

Meghalaya Energy Power Distribution Corporation Limited

TEST REPORT

This is to certify that repaired/renewed/additional/new electric installation at the premises of

SMT. ELEONORA WARBAH

(Please leave one block between name & surname)

(Full Name)

MAWDIANKIDIAN

(Address)

is duly completed, tested and is ready for your Engineer to test and connect on your main line.

1 The load has been arranged as follows :-

| Details of Load | Wattage of each Item | | | | | | | Total watt of all 3 phases |
|-----------------------------------|----------------------|---------------|------------|---------------|------------|---------------|------------|----------------------------|
| | | No. of points | Total Watt | No. of points | Total Watt | No. of points | Total Watt | |
| 1. Light points | | | | | | | | |
| (i) Fluorescent | | | | | | | | |
| (ii) Incandescent | | | | | | | | |
| (iii) CFL | 9W | 5Nos | 45W | 5Nos | 45W | 5Nos | 45W | |
| (iv) Halogen | | | | | | | | |
| (v) Others | | | | | | | | |
| 2. Fan points | 60W | 2Nos | 120W | 2Nos | 120W | 2Nos | 120W | |
| 3. Plug points (3-pin) | 100W | 6Nos | 600W | 6Nos | 600W | 6Nos | 600W | |
| (i) 6 Amps | 1000W | 1No | 1000W | 1No | 1000W | 1No | 1000W | |
| (ii) 16 Amps | | | | | | | | |
| 4. Electrical gadgets | | | | | | | | |
| (i) Water Heater (Geyser) | | | | | | | | |
| (ii) Refrigerator | | | | | | | | |
| (iii) Air Conditioner | | | | | | | | |
| (iv) Others | | | | | | | | |
| 5. Welding Transformer | | | | | | | | |
| 6. Motor | | | | | | | | |
| Total | | | 1765 | | 1765 | | 1765 | |
| In case of load enhancement | | | | | | | | |
| Existing load (in watts) | | | | | | | | |
| Total load in premises (in watts) | | | 1765 | | 1765 | | 1765 | 5295W |

Notes :-

- Details of any apparatus (other than the above mentioned) should be given.
- Rating of capacitor used in Induction Motor and Welding Transformer (Test report of capacitor

Say 6 Kvar

KVAR