



ALL AGREEMENT made on this

3<sup>rd</sup>

Jan

2025

between L. Khomyiang

and his successors and assigns (hereinafter referred to as the Consumer) of the One Part and the Meghalaya Electricity Corporation Ltd. or its successors and assigns (hereinafter referred to as MeECL) of the Other Part

Note : The term 'consumer' includes an individual person (whether male or female), a body of persons, a company, society, firm, association or organisation

WHEREAS, the consumer has applied to the MeECL for supply of electricity to its premises and the MeECL has agreed to give the supply under the terms and conditions hereinafter appearing

NOW, THEREFORE, the agreement witnesses -

1. That the supply shall be given to the premises located at Rimai with the consumer as owner/occupier of
2. That the supply shall be for the purpose of Domestic lines the load whereof shall not exceed 2kw watt(s).
3. That the provisions of the Electricity Act, 2003 and the Regulations, Code and Orders including Tariff Orders, as may be made from time to time by the Meghalaya State Electricity Regulatory Commission shall apply and bind the consumer and the MeECL alike.
4. That the consumer shall regularly and timely pay to the MeECL all charges and may be due for the supply of electricity.
5. That the Agreement shall be a period of two years and may be renewed for a further period: Provided that supply shall not be terminated by mere efflux of time if the consumer is willing that the agreement is renewed.
6. That the Agreement shall be terminated if the consumer on its part desires it so and gives to the MeECL a prior notice of not less than one month or, on the part of the MeECL, if the consumer has violated any of the terms and conditions of the agreement.

provided that on the part of the MeECL there shall be given to the consumer a reasonable opportunity to state his case and a statement, if any, duly considered before the agreement is terminated and the supply of electricity cut off

7. That the terms and conditions of this Agreement shall be effective from the date supply of electricity is commenced

IN WITNESS WHEREOF the parties hereto have set their hands and seals the date, month and year first above written.

*L. Khongyiang*

The Consumer

( *[Signature]* )  
For and on behalf of the MeECL

Witnesses :-

1. Signature : *L. Khongyiang*

Name :

*Richmond Khongyiang*

Address :

*Riwai Puri [East Khasi Hills Districts]*

1. Signature : *[Signature]*

Name :

*Newborn Mylliem-gop*

Address :

*Riwai Puri [East Khasi Hills Districts]*

# Meghalaya Energy Power Distribution Corporation Limited

## TEST REPORT

To certify that repaired/renewed/additional/new electric installation at the premises of

**L A N A N B I A N G K H O N G Y I A N G**

(Please leave one block between name & surname)

(Full Name)

**R I W A I**

(Address)

is duly completed, tested and is ready for your Engineer to test and connect on your main line.

i The load has been arranged as follows -

Details of Load	Wattage of each item							Total watt of all 3 phases
		No. of points	Total Watt	No. of points	Total Watt	No. of points	Total Watt	
1 Light points	60	8	480					
(i) Fluorescent								
(ii) Incandescent								
(iii) CFL								
(iv) Halogen								
(v) Others								
2 Fan points								
3 Plug points (3-pin)	100	2	200					
(i) 6 Amps								
(ii) 16 Amps	1000	1	1000					
4 Electrical gadgets	Total.	2	1680 watts					
(i) Water Heater (Geyser)								
(ii) Refrigerator								
(iii) Air Conditioner								
(iv) Others								
5. Welding Transformer								
6. Motor								
Total		1680 watts or 2kw						
In case of load enhancement								
Existing load (in watts)								
Total load in premises (in watts)								

Notes :-

- Details of any apparatus (other than the above mentioned) should be given.
- Rating of capacitor used in Induction Motor and Welding Transformer (Test report of capacitor is to be enclosed).

KVAR

Type of wiring *Pvc Looping System*

Voltage and system of supply *230V*

Test Result *ok*

Date of Testing by Licensed Contractor: 

3	1	2	0	2	0
---	---	---	---	---	---

Type of Test	Result of test carried out by licensed contractor (In MΩ) / Ω	Result of test carried out by Supplier under relevant IS Rules, in (MΩ) / Ω
a. Insulation resistance between earth and whole system of conductor.	<i>18 M Ω</i>	
b. Insulation resistance between all conductors.	<i>20 M Ω</i>	
c. Earth continuity between earth electrode and earth continuity conductor.		
d. Polarity of non-linked SP switches	<i>phase</i>	

V. Full Name with signature of Licensed contractor

LIC No. *M/S. NONGKYNRIH ELECTRICAL*  
Contractor  
Govt of Meghalaya  
Lic No. 318.

VI. Full Name with signature of supervisor (with date)

LIC No. *Shri. B.S. NONGKYNRIH*  
Electrical Supervisor  
Govt of Meghalaya  
Lic No. 537.

VII. Full Name with signature of wireman (with date)

*B. S. Nongkynrih*  
PERMIT No. *B. S. Nongkynrih*  
Electrical Wireman  
Govt. Of Meghalaya  
Lic No. 2469

VIII. Signature of the authorized official who tested The installation of behalf of supplier.

IX. Date of connection of supply to the installation

X. Date of Commencement