

Genus Power Infrastructures Ltd.

Test Certificate

1 Ph, 2W, 5 -30A, 240V, 50Hz, CL-1

As Per IS:13779

Meter Serial No. : 301109

Date:

26/10/2025

No Load Ok, HV Test Ok, IR Test OK, Starting Current Ok

Load Points 000001

% Error

U1 = 240 I1 = 600%Ib PF = 1

0.02 %

U1 = 240 I1 = 600%Ib PF = 0.5

0.05 %

U1 = 240 I1 = 100%Ib PF = 1

0.07 %

U1 = 240 I1 = 100%Ib PF = 0.5

0.16%

U1 = 240 I1 = 100%Ib PF = -0.86

0.15 %

U1 = 240 I1 = 10%Ib PF = 0.5

0.26%

U1 = 240 I1 = 5%Ib PF = 1

0.16 %

Testing Incharge: - Rajiv Tiwari


U1=Applied Voltage, I1=% Of Basic Current

This is System Generated report

Meter Tester Gr
MTI Laboratory
MePDCL, Lumjingshat
Shillong

Executive Engineer
MTI Division
PDCL Shillong

भारत निर्वाचन आयोग
ELECTION COMMISSION OF INDIA
भारत में पहला पहचान पत्र - ELECTORAL PHOTO IDENTITY CARD
MTL0614479



Name : BATSKHEM BASAIAWMOIT
Mother's Name : MARTINIA BASAIAWMOIT

भारत निर्वाचन आयोग

Gender : Male
Date of Birth/ Age : 22-08-1968

Address : HNo.2, MAWLAI NONGLUM B, VILL- MAWLAI, DIST-EAST KHASI HILLS-793008

Date : 02-12-2019
Electoral Registration Officer

Assembly Constituency No. and Name : 15- MAWLAI (ST)

Part No. and Name : 46-MAWLAI NONGLUM A

नोट / Note :

1. इस कार्ड का अर्थ यह नहीं है कि आप वर्तमान निर्वाचन आयोग के विधान हैं। प्रमाण के रूप में इसे केवल प्रमाण के रूप में ही देखा जाना चाहिए।
Mere possession of this card is no guarantee that you are elector of the current electoral roll. Please check your name in the current electoral roll before every election.

2. इस कार्ड में उल्लिखित तिथि को प्रमाण के रूप में केवल केवल के लिए ही देखा जाना चाहिए।
Date of Birth mentioned in this card shall not be treated as a proof of age/D.O.B. for any purpose other than registration in electoral roll.

Meghalaya Power Distribution Corporation Limited
ELECTRICITY BILL

Account Details

Sub-Division UMIAM SUBDIVISION
Consumer Id 1000198264
MR Code 2232004
Consumer Name M/S B.B.Enterprise
Address M.I.D.C., Umiam,, Umiam,
#311108
Category ILT
C.Demand/Load 11.111KVA
Meter No 22001058
OMF(Cons) 1
VAN No MEPDCL1000198264

Billing Details

Prev. Reading Date 10/10/2025
Cur. Reading Date 13/11/2025
No. of Days 34
Bill Number 223200425B130183
Bill Status OK(Normal)
Prev KVAH 32412.42
Current KVAH 34295.68
Billed Unit 1853.26
Recorded MD 2.017
Power Factor 0
Average

Bill Charges

Fixed Charges (Unit, Rate, Amount)
11.111 KVA 170.0 2071.11
Energy Charges (Unit, Rate, Amount)
1853.26 6.8 12592.00
ED Amount (Unit, Rate, Amount)
1853.26 0.05 92.66
FPPAS
(SEP 25 TO SEP 25 -733.758)
DPC 1300.00
Current Bill Amt 15804.54
Prev Outstanding 142612.85
Adjustment 0.00
Gross Bill Amount 15804.54

Net Bill Amount ₹ 15804.50
Due Date 27/11/2025
Last Payment Date 10/04/2025
Last Payment Amount 30000

13/11/2025 12:05 V1.6

This bill will be construed as final notice under Section 8.2 of
MSERC (Electricity Supply Code) Regulations, 2018. Supply
of electricity shall be disconnected at any date, if dues of
Electricity bill is not paid within 15 (fifteen) days (notice
period) after due date of the bill. Thanks for paying. We really
appreciate it!



For Bill Payments, Please Visit www.mepdcl.com OR
Download Megha Power Distribution Corporation Paystore

In case of load enhancement Existing load (in watts)			
Total load in the premises (in watts)			

Notes:-

(a) Details of any apparatus (other than the above mentioned) should be given.

(b) Rating of capacitor used in Induction Motor and Welding Transformer (Test report of capacitor is to be enclosed) KVAR

II. Type of wiring *Casing type of wiring*

III. Voltage and system of supply. *CLT*

IV. Test Result: *o.k!*

Date of Testing by Licensed Contractor

0	3	1	2	2	5
---	---	---	---	---	---

Type of Test	Result of test carried out by licensed contractor (in MΩ) / Ω	Result of test carried out by the supplier under relevant IE Rules, (in MΩ) / Ω
a. Insulation resistance between earth and whole system of conductor.	<i>25 MΩ</i>	
b. Insulation resistance between all conductors.	<i>25 MΩ</i>	
c. Earth continuity between earth electrode and earth continuity conductor.	<i>5Ω</i>	
d. Polarity of non-linked SP switches	<i>Phase</i>	

V. Full Name with signature of Licensed contractor :
(with date) LIC No :

S. Shylla

S. Shylla
Electrical Contractor
Regd. No: 1592

VI. Full Name with signature of supervisor :
(with date) LIC No :

W. Nongkhaw
Electrical Supervisor
Regd. No. 1377

VII. Full Name with signature of wireman :
(with date) PERMIT No. :

W. Nongkhaw
Wireman
Lic. No. 10341

VIII. Signature of the authorized official who tested the installation of behalf of supplier (with date) :

IX. Date of connection of supply to the installation :

Meghalaya Energy Units
Net Consumption

25 KVA
Distance - 10 meters
L.M. Singh
9.1.26

MEGHALAYA ENERGY CORPORATION LIMITED TEST REPORT (LT SUPPLY)

1 Kw at Rs. 170 per Kw at BM: (31/31)**

To, _____
The _____

This is to certify that repaired / renewed / additional / new electric installation at the premises of (Full Name)

M / S B . B ENTERPRISE

(Please leave one block between name & surname)

(Address)

M I D C W M I A M

is duly completed, tested and is ready for your authorized representatives to test and connect on your main line.

I. The load has been arranged as follows:-

Details of Load	Wattage of each item	Phase- I		Phase- II		Phase- III		Total watt of all 3 phases
		No. of points	Total watt	No. of points	Total watt	No. of points	Total watt	
1. Light points								
(i) Fluorescent								
(ii) Incandescent								
(iii) CFL								
(iv) Halogen								
(v) Others led fitting	20	6	120					
2. Fan Points								
3. Plug points (3-pin)								
(i) 6 Amps	100	3	300					
(ii) 16 Amps	1000	1	1000					
4. Electrical gadgets								
(i) Water Heater (Geyser)								
(ii) Refrigerator								
(iii) Air Conditioner								
(v) Others								
5. Welding Transformer								
6. Motor								
Total			1420					

Provided that on the part of the MePDCL notice shall be given to the consumer stating reasons for the proposed termination and giving him opportunity to state his case and his statement, if any duly considered before the agreement is terminated and the supply of electricity cut off;

(7) The terms and conditions of this agreement shall be effective from the date of supply of electricity is commenced.

IN WITNESS WHEREOF the parties hereto have set their hands and seals the date, month and year first above written.


Consumer

For and behalf of MePDCL.

Witness:

1. Signature:

Name:

Address:


Mankubhar Syiem
Mawlai

2. Signature:

Name:

Address:


Zafinta Syiem
Mawlai

Agreement for supply of electricity Low Tension

An agreement made this the 03rd day of the December 2025 between M/S B.B Enterprise and his successor and assigns (hereinafter referred to as the consumer) of the one part and the Meghalaya Power Distribution Corporation Limited an electricity distribution licensee under the EA, 2003 and its successors and assigns (hereinafter referred to as the Distribution Utility / MePDCL) of the other part.

Note: the term 'consumer' includes an individual person (whether male or female), a body of persons, a company, society, firm, association or organisation.

Whereas, the consumer has applied to the distribution utility for supply of electricity to the premises and the distribution utility has agreed to give the supply under the terms and conditions hereinafter appearing;

Now, therefore, the agreement witness -

- (1) That the supply shall be given to the premises located at Dmiam with the consumer as owner / occupier of;
- (2) That the supply shall be for the purpose of CLT The load whereof shall not exceed 1420 watts
- (3) That the provisions of the EA 2003 and the regulations, code and orders including tariff orders, as may be made from time to time by the MSERC shall apply and bind the consumers and the distribution utility alike;
- (4) That the consumer shall regularly and timely pay to MePDCL all charges as may be due for the supply of electricity;
- (5) That the agreement shall be a period of two years and may be renewed for a further period; Provided that supply shall not be terminated by mere efflux of time if the consumer is willing that the agreement is renewed;
- (6) That the agreement shall be terminated if the consumer on its part desires it so and gives to the MePDCL a prior notice of not less than one month or, on the part of the MePDCL, if the consumer has violated any of the terms and conditions of the agreement.

3023750 Additional 2KW



(526)

APPLICATION FORM FOR PROVIDING LT SERVICE CONNECT
(FOR ALL CATEGORY AND FOR ALL PURPOSE)

To
The Area Manager / Asst Executive Engineer
Service Connection Sub-Division/ Distribution Sub-Division
MeECL
(Indicate the local area of the jurisdiction of the Engineer of the licensee)

Sir,

1. I / We hereby request you to supply electricity to the premises located at the described below. I/We are the owner / lawful occupier of the premises.
2. I/We agree to abide by the terms and condition relating to the supply of electricity by MeECL and to make all payments as may be required and also to pay regularly all the charges as may become due.
3. a) Full name and address of the applicant with contact telephone number.

M/S B.B Enterprise
M.I.D.C Umiam

- b) Status in relation to the premises.
- Owner
- Occupier

c) Location and address of the premises including Police Station.

- d) Nature of LT Supply:
- | | | | |
|-------------|-------------------------------------|-----------------|--------------------------|
| Commercial | <input checked="" type="checkbox"/> | Domestic | <input type="checkbox"/> |
| Industrial | <input type="checkbox"/> | General Purpose | <input type="checkbox"/> |
| WSLT | <input type="checkbox"/> | PL | <input type="checkbox"/> |
| Agriculture | <input type="checkbox"/> | KJ | <input type="checkbox"/> |

2KW load sanction: from
MIDC umiam: 2SKVA.

Date 9/01/26

[Signature]
Applicant's Signature

NB : The following documents are to be enclosed:

Junior Engineer (EL)
Umiam Dist. Sub-Division
MePDCL, Umiam

- 1) Report from Licensed contractor.
- 2) Agreement Form duly filled in.
- 3) Proof of ownership (in case the applicant is owner)
- 4) Number of the nearest Electric Pole.
- 5) NOC of the owner of the premises (in case the applicant is occupier).
- 6) Attested copy of permission obtained from Pollution Control Board.
- 7) Building permission from the concerned authority.

Kindly Angeline take
necessary action
[Signature]

[Signature]
Assistant Executive Engineer
Umiam Distribution Sub - Division
MePDCL, Umiam

NEW CONSUMER APPLICATION FORM

If Consumer Apply for Sub-Meter/ Additional Connection
(Please tick on the check box)

Paste
Photo
Here

Personal Details

*Application No - _____
*Consumer Name - M.S. B-B. Enterprise
*Father's Name - _____
*Mobile No - 9856050189 Email - _____
Aadhaar / EPIC No. - MLT0614479

Address Details

*Accommodation - Own / Rented (Pl. tick one)
*Discom - Meghalaya Power Distribution Corporation
*Zone - Eastern Zone *Circle - Ribhoi Circle *Division - Umiam Division
*Sub-Division - Umiam Distribution Sub Division
*Village Name - MIDC Umiam
*State - Meghalaya *City - Ribhoi (Nongpoh)
*Area Pin code - 793103 Locality _____
*Full Address - _____

New Connection Details

*Consumer Type : SG / CG / NG (Pl. tick one). *Urban/Rural Type: Rural / Urban (Pl. tick one)
*Activity - Residential
*Contract Load Unit - KW / KVA (Pl. tick one) *Contract Load: 2kw
*Category - CLT *Product Type: LT / HT (Pl. tick one)
*Scheme - All Categories excluding industrial / Industrial / Free Scheme / Saubhagya/ DDUGJY (Pl. tick one)

Other Details

*Meter Number - 301109 *Initial KWH- 01 *Initial KVAH - 01
*Meter MF - 1 Meter Owned - Utility / Consumer (Pl. tick one)
*Phase - 1 Phase / 3 Phase (Pl. tick one) *TMC - Yes / No (Pl. tick one)
Meter Reader - _____ Group No - _____