

ECURE

ROUTINE TEST REPORT

Serial Number: SS18098397
Customer: M/S MAMTA ELECTRICALS
Customer P.O Number: Mamta/SML/25-26/01
Customer P.O Date: 02-APR-2025
Voltage: 240V
Ref. Standard: IS : 13779
Current: 05-30A
Accuracy Class: 1.0

Meter Constant: 6400

- 1. AC VOLTAGE TEST: PASS
- 2. TEST OF NO LOAD CONDITION: PASS
- 3. TEST OF STARTING CURRENT: PASS
- 4. INSULATION TEST: PASS
- 5. METER ACCURACY:-

Reference Conditions: Vref = 240V/50Hz Ib = 05-30A Amb. Temp = 27 +/- 2 Deg. C

METER ACCURACY


% Active Import Errors

Load % Ib	0.5 Lag	0.8 Lead	UPF
600	0.4	0.0	0.0
100	0.2	0.0	0.0
10	0.2	0.0	0.0
5			0.0

00001.0

TEST DATE: 24/05/2025

This is computer generated test report no signature required


Meter Tester Gr - I
MTI Laboratory
MePDCL, Lumjingshal
Shillong


Executive Engineer
MTI Division
MePDCL, Shillong

JNOC

I Mr. S. Marbaniang Owner of the
plot of land in Block IV, Rongmen
Kongsder, hereby have no objection
for the Additional metre connection
for my tenant, Snt Amoita Mapa.

S. MARBANIANG

Owner

PROTESTOR
S. Marbaniang

MSEER (Electricity Supply Code) Regulations, 2012
 electricity shall be disconnected at any date
 bill is not paid within 15 (fifteen) days
 date of the bill. Thanks for your cooperation.



For Bill Payments, Please visit www.mseer.org or
 Download Megha Power App from Google Play store
 The current bill includes the new tariff difference amount
 as per the MSEER-approved Distribution Tariff for
 2024-25, to be collected in nine equal installments. For
 any queries, please contact the AEEs of the respective
 sub-divisions.

Meghalaya Power Distribution Corporation Limited
 ELECTRICITY BILL

Account Details	
Sub-Division	UMIAM SUBDIVISION
Consumer Id	1000206905
MR Code	2232002
Consumer Name	C K Chetri
Address	Rangmen, Rangmen #3061308400
Category	DLT
C.Demand/Inst	1.0KW
Meter No	11102846
OMF No	1.0
	564.99

Billing Cycle	01/03/2025
Prev. Reading Date	02/04/2025
Curr. Reading Date	32
No. of Days	25010615181967
Bill Number	GK(Auto)
Bill Status	841.20
Prev KWH	889.70
Current KWH	48.50
Billen Unit	0.574
Recorded MD	0.913
Power Factor	
Average	

Bill Charges		
Fixed Charges (Unit, Rate, Amount)		
1.0 KW	90.00	2.90
1.0 KW	90.00	90.00
Energy Charges (Unit, Rate, Amount)		
1.52	5.00	7.58
46.98	5.55	260.76
ED Amount (Unit, Rate, Amount)		
1.52	0.05	2.35
46.98	0.05	2.35
FPPAS		-26.13
DPC		31.30
Current Bill Amt		368.83
Prev Outstanding		3239.31
Adjustment		0.00
Tariff Diff (4.9 last)		62.78
Gross Bill Amount		3670.92

Bill Amount
 Date
 Payment Us...
 Bill Payment Amount



OFFICE OF THE RANGBAH SHNONG NONGSDER

RAID MAWBUH, MYLLIEM SYIEMSHIP
P.O. UMIAM - 793103
Ri Bhoi District (Meghalaya)

Under Rule 10(3) of the Administration of Myllem Syiemship rule, 2015 of the Khasi Autonomous District
(Appointment and Succession of Syiem, Deputy Syiem, Electors and Rangbah Shnong of Myllem Syiemship)



NO OBJECTION CERTIFICATE

This is to certify that Shri/Smt. Asmita Thapa ^{Daughter} husband/wife

of (2) Smt. Puma Thapa is a residential (tenant) of Nongsder Village

Block 4 P.O. & P.S. Umiam Ri Bhoi District of Meghalaya.

I confirm herewith that I have No Objection for him/her to apply for Electric/LPG
Gas-connection to his/her house for domestic use only.

Headman
Rangbah Shnong
(Headman)
Nongsder Village
P.O Umiam - 793103
Ri Bhoi District

II. Type of wiring **CAPPING: CAPPING**
 III. Voltage and system of supply **230V**
 IV. Test Result **OK**
 Date of testing by licensed contractor


2	0	0	1	2	6
---	---	---	---	---	---

Type of test	Result of test carried out by licensed contractor (In MΩ) / Ω	Result of test carried out by the supplier under relevant Cea regulations, (In MΩ) / Ω
(a) Insulation resistance between earth and whole system of conductor.	116MΩ	
(b) Insulation resistance between all conductors	116MΩ	
(c) Earth continuity between earth electrode and earth continuity conductor	4Ω	
(d) Polarity of non-linked SP switches	OK (SINGLE PHASE)	

V. Full name with signature of licensed contractor (with date)

LIC No.

Mobile No.


 M/s. R. Dohdong
 Lic. No: 301

VI. Full name with signature of supervisor (with date)

LIC No.


Mobiles No.


 Mr. R. Dohdong
 Electrical Supervisor
 Regd No: 459

VII. Full name with signature of wireman (with date)

LIC No.

Mobile No.


 Mr. Dohdong
 Electrical Wireman
 Regn NO - 2126

I. Signature of the authorized official who tested the installation on behalf of supplier (with date)

Mobile No.

Date of connection of supply to the installation

Form 7

Meghalaya Power Distribution Corporation Limited

Test Report

This is to certify that repaired/renewed/additional/new electric installation at the premises of

Full name

A	S	M	I	T	A	T	H	A	P	A									
---	---	---	---	---	---	---	---	---	---	---	--	--	--	--	--	--	--	--	--

(Please leave one block between name & surname)
 Address

R	A	N	G	M	E	N	N	O	N	G	S	D	E	R	B	L	O	C	K	-	4						
---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	--	--	--	--	--	--

1. The load has been arranged as follows:

Details of load	Wattage of each item	Phase I		Phase II		Phase III		Total wattage of all 3 phases
		No. of points	Total wattage	No. of points	Total wattage	No. of points	Total wattage	
1. Light points								
(i) Fluorescent								
(ii) Incandescent								
(iii) CFL								
(iv) Halogen								
(v) Others L.E.D	9W	10	90W					
2. Fan points	100W	1	100W					
3. Plug points (3-Pin)								
(i) 6 Amps								
(ii) 16 Amps	1000W	1	1000W					
4. Electrical gadgets								
(i) Water Heater (Geyser)								
(ii) Refrigerator								
(iii) AC								
(iv) Others								
5. Welding transformer								
6. Motor								
Total			1190W					
In case of load enhancement existing load (in watts)								
Total load in the premises (in watts)			2KW					

Notes:

- (a) Details of any apparatus (other than the above mentioned) should be given.
- (b) Rating of capacitor used in induction Motor and welding Transformer (Test report of capacitor is to be enclosed)

KVAR

Provided that on the part of the MePDCL notice shall be given to the consumer stating the reasons for the proposed termination and giving him opportunity to state his case and his statement, if any duly considered before the agreement is terminated and the supply of electricity cut off;

(7) The terms and conditions of this agreement shall be effective from the date of supply of electricity is commenced.

IN WITNESS WHEREOF the parties hereto have set their hands and seals the date, month and year first above written.

Satish

Consumer

For and behalf of MePDCL.

Witness:

1. Signature:

Name:

Address:

2. Signature:

Name:

Address:

Agreement for supply of electricity Low Tension



An agreement made this the 20 day of 01 of 2024 between ASMITA THAKUR and his successor and assigns (hereinafter referred to as the consumer) of the one part and the Meghalaya Power Distribution Corporation Limited an electricity distribution licensee under the EA, 2003 and its successors and assigns (hereinafter referred to as the Distribution Utility / MePDCL) of the other part.

Note: the term 'consumer' includes an individual person (whether male or female), a body of persons, a company, society, firm, association or organisation.

Whereas, the consumer has applied to the distribution utility for supply of electricity to the premises and the distribution utility has agreed to give the supply under the terms and conditions hereinafter appearing;

Now, therefore, the agreement witness –

(1) That the supply shall be given to the premises located at NONGS DER B with the consumer as owner / occupier of;

~~(2) That the supply shall be for the purpose of DOMESTIC~~
The load whereof shall not exceed 2000 watts

(3) That the provisions of the EA 2003 and the regulations, code and orders including tariff orders, as may be made from time to time by the MSERC shall apply and bind the consumers and the distribution utility alike;

(4) That the consumer shall regularly and timely pay to MePDCL all charges as may be due for the supply of electricity;

(5) That the agreement shall be a period of two years and may be renewed for a further period;

Provided that supply shall not be terminated by mere efflux of time if the consumer is willing that the agreement is renewed;

(6) That the agreement shall be terminated if the consumer on its part desires it so and gives to the MePDCL a prior notice of not less than one month or, on the part of the MePDCL, if the consumer has violated any of the terms and conditions of the agreement.

(1547)

NEW CONSUMER APPLICATION FORM

If Consumer Apply for Sub-Meter/ Additional Connection
(Please tick on the check box)



Personal Details

*Application No - _____
 *Consumer Name - Asmita Thapa
 *Father's Name - Purna Thapa Mother's Name - Sita Thapa
 *Mobile No - 8414084415 Email - _____
 Aadhaar / EPIC No. - ZRL0921536

Address Details

*Accommodation - Own / Rented (Pl. tick one)
 *Discom - Meghalaya Power Distribution Corporation
 *Zone - Eastern Zone *Circle - Ribhoi Circle *Division - Umiam Division
 *Sub-Division - Umiam Distribution Sub Division
 *Village Name - Rangmen, Nongsdar Block - IV
 *State - Meghalaya *City - Ribhoi (Nongpoh)
 *Area Pin code - 793103 Locality - Rangmen, Nongsdar Block - IV
 *Full Address - Rangmen, Nongsdar Block - IV

New Connection Details

*Consumer Type : SG / CG / NG (Pl. tick one) *Urban/Rural Type: Rural / Urban (Pl. tick one)
 *Activity - House
 *Contract Load Unit - KW / KVA (Pl. tick one) *Contract Load: 2KW
 *Category - Domestic *Product Type: LT / HT (Pl. tick one)
 *Scheme - All Categories excluding industrial / Industrial / Free Scheme / Saubhagya / DDUGJY (Pl. tick one)

Other Details

*Meter Number - _____ *Initial KWH - _____ *Initial KVAH - _____
 *Meter MF - _____ Meter Owned - Utility / Consumer (Pl. tick one)
 *Phase - 1 Phase / 3 Phase (Pl. tick one) *TMC - Yes / No (Pl. tick one)
 Meter Reader - _____ Group No. - _____

List of Documents to be attach:

- > *Test Report
- > *Ownership Proof
- > *Identity P...