

2817

NEW CONSUMER APPLICATION FORM

☐ If Consumer Apply for Sub-Meter/ Additional Connection
(Please tick on the check box)



Personal Details

* Application No

* Consumer Name

* Father's Name

* Mobile No

* Aadhaar / EPIC No

Ibanpyntgen Kharsohnah

S. Lamara

6009766242

Email

ZRI0923136

Address Details

* Accommodation

* Discom

* Zone

* Sub-Division

* Village Name

* State

* Area Pin Code

* Full Address

Own / Rented (Pl tick one)

Meghalaya Power Distribution Corporation

Eastern Zone * Circle - Ribhoi Circle * Division - Umiam Division

Umiam Rural Distribution Sub-Division

Nonglum

Meghalaya * City - Ribhoi (Nongpoh)

793103

Locality - Nonglum

Nonglum

New Connection Details

* Consumer Type - SG / CG / NG (Pl tick one)

* Urban/Rural Type - Rural / Urban (Pl tick one)

* Activity

House

* Contract Load Unit

KW / KVA (Pl tick one) * Contract Load 2KW

* Category

Domestic * Product Type LT / HT (Pl tick one)

* Scheme

All Categories excluding industrial / Industrial / Free Scheme /

Saubhagya/ DDUGJY (Pl tick one)

Other Details

* Meter Number

* Initial KWH

* Initial KVAH

* Meter MF

Meter Owned - Utility / Consumer (Pl tick one)

* Phase

1 Phase / 3 Phase (Pl tick one) * TMC - Yes / No (Pl tick one)

* Meter Reader

Group No

List of Documents to be attach:

- * Test Report
- * Ownership Proof
- * Identity Proof
- * Meter Test Report
- Landlord NOC
- Agreement/ Bill
- Pollution Control Board

All items marked with * are mandatory

Date of Connection:

Meghalaya Power Distribution Corporation Limited
Test Report

63 kVA

Distance from Pole to
house 25 mtr
A. Jharbarki

This is to certify that repaired/renewed/additional/new electric installation at the premises of

Full name

IBANPYNTNGEN KHARSOHNDH

(Please leave one block between name & surname)

Address

NONGLUM

1. The load has been arranged as follows:

Details of load	Wattage of each item	Phase I		Phase II		Phase III		Total wattage of all 3 phases
		No. of points	Total wattage	No. of points	Total wattage	No. of points	Total wattage	
1. Light points								
(i) Fluorescent								
(ii) Incandescent								
(iii) CFL								
(iv) Halogen								
(v) Others/LED	9W	8 Nos	72 W					
2. Fan points								
3. Plug points (3-Pin)								
(i) 5 Amps	1000 W	6 Nos	600 W					
(ii) 15 Amps	1000 W	1 No	1000 W					
4. Electrical gadgets								
(i) Water Heater (Geyser)								
(ii) Refrigerator								
(iii) AC								
(iv) Others								
5. Welding transformer								
6. Motor								
Total			1672 W					
In case of load enhancement existing load (in watts)								
Total load in the premises (in watts)			2 kW					

Notes:

(a) Details of any apparatus (other than the above mentioned) should be given.

(b) Rating of capacitor used in induction Motor and welding

Transformer (Test report of capacitor is to be enclosed)

KVAR

II. Type of wiring

Cable Capped

III. Voltage and system of supply

230V

IV. Test Result

OK

Date of testing by licensed contractor

01/05/2025

	Type of test	Result of test carried out by licensed contractor (in M Ω) / Ω	Result of test carried out by the supplier under relevant Cea regulations (in M Ω) / Ω
(a)	Insulation resistance between earth and whole system of conductor	108 M Ω	
(b)	Insulation resistance between all conductors	110 M Ω	
(c)	Earth continuity between earth electrode and earth continuity conductor	3 Ω	
(d)	Polarity of non-linked SP switches	0 M Ω (PN-230V) EN-0.2V	

V. Full name with signature of licensed contractor (with date)

LIC No.

Mobile No.

VI. Full name with signature of supervisor (with date)

LIC No.

Mobile No.

VII. Full name with signature of wireman (with date)

LIC No.

Mobile No.

VIII. Signature of the authorized official who

tested the installation on behalf of supplier (with date)

Mobile No.

IX. Date of connection of supply to the installation

Signature of Licensed Contractor

Mr. R. D. D. D.
Electrical Supervisor
Regd. No: 459

Signature of Authorized Official

DORBAR SHNONG NONGLUU

RAID MAWBUI, MYLLIEM SYIEMSHIP
KI BHOI DISTRICT

Dated: Nongluu
The 10.4.2012

KA KOT AI PATENG (Jaka) Pynthei Kba

Ha,

U/Ka Ka Kba Kba Saharai

Ba shnong ha Nongluu Kaidmait Kaid Mylliem Syiem Ship Kaidmait

Ma ngu ka Kma/Kpa lem bad ki long Kai kiba soi kyrteng harum, ngi wan ban
aiti duh ia ka jaka hok tra ka long tigi kaba kyrteng ka Uzi Sipi Kama Pynthei Kba
kaba don ha u pud synshar shnong jang ka Nongluu Raid Maubui Mylliem Syiemship. Ngi la
aiti duh haphi ka khun jong ngi kana don ka kyrteng baneng ba kan long kum ka jingai nongkynti
haphi nadah mynta ka ngi Dated: 10.4.2012

Kine harum ki long ki pud sawding kina ker tawar ia kane ka jaka

Mihngi (East) Ka ia khap bad ka jaka Ka Sipi Kama Kaidmait
Shatei (North) Ka ia khap bad ka jaka Ka Khun Kba Kaidmait
Sepngi (West) Ka phut wadi uon Sipi Kama Kaidmait
Shathier (South) Ka ia khap bad ka Pynthei Kba Ka Wadi Sipi Kama

Ka jingheti antad Kuma ha ka Kaidmait kan long noh ka hok nongkynti
jongphi bad ki khun ki kiewe jongphi pateng ia pateng. Kuma phi lah ban rep ne ban die ban boh
kaba phi mon, tang ba phi dei ban ioh shwa ka jingmyntur na ngi ki nongaiti haphi, bad ha ki
nongioh pateng ki jingphi. Hynrei ladi don ka uoi ne dawa, ma ngi ki ka nongaiti duh ngi ki
khlich ia kane ka jaka

Ia kane ka jingaiti duh ia pyndep hapdeng ka jingiahun lang ka iing ka som
ryngkar ka mei ba koi ba khun lem ka jingdon ryngkar ki Sakhi bad u Nongluu ban pyndusha
bad pyndshem ia ki jingaiti duh ka ka long kaba beir.

(NB): 1. Kiei kiei kiba don ha kane ka jaka kan long ka hok nongkynti ka jongphi ka
nongioh pateng wai shaduh shapoh khyndew ruh.

2. Phi dei ban sumar ia la u pud katkum ka jingthaw

P. Shadup

Nongluu

Sakhi

Jingsoi kyrteng
Ki nongam pateng

Dated 10.4.2012

1. P. Shadup 1. Kma

2. R. Wadhy 2. Kpa

3. Kpura

4. Kpura

5. Kpa



Nga pyndusha ba kane ka jingaiti ka Kma/Kpa ia ka khun ka long kaba shisha

DORBAR SHNONG NONGLUM

RAID MAWBUH, MYLLIEM SYIEMSHIP

B.P.O UMROI, RI- BHOI DISTRICT, MEGHALAYA- 793103

Ref No.

Date 28.3.25

NO OBJECTION CERTIFICATE

This is to certify that Mr/Mrs. Iban pyntnyen khars chut
S/o D/o S. Lamare a residence of Nonglum Village and that the
Dorbar Shnong along with the Executive Committee Members have No
Objection against Him/Her for Applying/ Granting new Electricity Connection
in the above said residence.


A. PARIAT
Rangbar Shnong
Nonglum Village