

NEW CONSUMER APPLICATION FORM

(amount pending)



☐ If Consumer Apply for Sub-Meter/ Additional Connection
(Please tick on the check box)

Personal Details

*Application No
*Consumer Name
*Father's Name
*Mobile No
Aadhaar / EPIC No.

Manbha Syiemlich
Dhiren Kharsyntoo
9366660599
ZRL0974550

Address Details

*Accommodation
*Discom
*Zone
*Sub-Division
*Village Name
*State
*Area Pin Code
*Full Address

☒ Own / ☐ Rented (Pl tick one)
Meghalaya Power Distribution Corporation
Eastern Zone *Circle - Ribhoi Circle *Division - Umiam Division
Umiam Rural Distribution Sub-Division
Umroi Madan
Meghalaya *City - Ribhoi (Nongpoh)
793116 Locality Umroi Madan
Umroi Madan

New Connection Details

*Consumer Type SG / CG / ☒ NG (Pl tick one) *Urban/Rural Type ☒ Rural / ☐ Urban (Pl tick one)
*Activity House
*Contract Load Unit KW / KVA (Pl tick one) *Contract Load 2KW
*Category Domestic *Product Type LT / HT (Pl tick one)
*Scheme All Categories excluding industrial / Industrial / Free Scheme /
Saubhagya/ DDUGJY (Pl tick one)

Other Details

*Meter Number *Initial KWH *Initial KVAH
*Meter MF Meter Owned - Utility / Consumer (Pl tick one)
*Phase 1 Phase / 3 Phase (Pl tick one) *TMC - Yes / No (Pl tick one)
Meter Reader Group No.

List of Documents to be attach:

- *Test Report
 - *Ownership Proof
 - *Identity Proof
 - *Meter Test Report
 - Landlord NOC
 - Agreement Fill
 - Pollution Control Board
- All fields mark with * are mandatory

Date of Connection:

The Area Manager/Asst. Executive Engineer
Service Connection Sub-Division/Uniform Power Distribution Sub-Division
MeECI / 11222
(Indicate the name of the jurisdiction of the Engineer of the licensee)

The Area Manager/Asst. Executive Engineer
Service Connection Sub-Division/Uniform ~~Panel~~ Distribution Sub-Division
MeECI / 11222
(Indicate the ~~area~~ area of the jurisdiction of the Engineer of the licensee)

3. a) Full name and address of the applicant with contact telephone number
Manisha Sijimbhik 93 6666 6597

c) Location and address of the premises including Police Station
Umrai Madan

kw Load Sanction from
Maidan 25kVA S/S

M. S. S. S. S.

Applicant's Signature

NB: The following documents are to be enclosed :

- who defected from
Marshall's expedition to
attley for new
frontier connection
Poppydel

AGREEMENT FOR SUPPLY OF ELECTRICITY
LOW TENSION



AN AGREEMENT made this the day of 20.....
between and his successors and assigns (hereinafter referred
to as the Consumer) of the One Part and the Meghalaya Energy Corporation Ltd. an electricity
distribution licensee under the Electricity Act, 2003 and its successors and assigns (hereinafter
referred to as MeECL) of the Other Part.

Note : The term 'consumer' includes an individual person (whether male or female),
a body of persons, a company, society, firm, association or organisation.

WHEREAS, the consumer has applied to the MeECL for supply of electricity to its
premises and the MeECL has agreed to give the supply under the terms and conditions hereinafter
appearing.

NOW, THEREFORE, the agreement witnesses -

1. That the supply shall be given to the premises located at Umroi Madan
with the consumer as owner/occupier of.
2. That the supply shall be for the purpose of Domestic
the load whereof shall not exceed 2000 watt(s).
3. That the provisions of the Electricity Act, 2003 and the Regulations, Code and Orders, including
Tariff Orders, as may be made from time to time by the Meghalaya State Electricity Regulatory
Commission shall apply and bind the consumer and the MeECL alike.
4. That the consumer shall regularly and timely pay to the MeECL all charges and may be due for
the supply of electricity.
5. That the Agreement shall be a period of two years and may be renewed for a further period:
Provided that supply shall not be terminated by mere efflux of time if the consumer is
willing that the agreement is renewed.
6. That the Agreement shall be terminated if the consumer on its part desires it so and gives to the
MeECL a prior notice of not less than one month or, on the part of the MeECL, if the consumer
has violated any of the terms and conditions of the agreement.

Provided that on the part of the MeECL notice shall be given to the consumer stating reasons for the proposed termination and giving him opportunity to state his case and his statement, if any, duly considered before the agreement is terminated and the supply of electricity cut off.

7. That the terms and conditions of this Agreement shall be effective from the date supply of electricity is commenced

IN WITNESS WHEREOF the parties hereto have set their hands and seals the date, month and year first above written.

(*M. S. J. S.*)

The Consumer

Witnesses :-

1. Signature .

Name :

Address :

1. Signature :

Name :

Address :

For and on behalf of the MeECL

MEGHALAYA POWER DISTRIBUTION CORPORATION LIMITED.

1 PHASE TEST REPORT

This is to certify that repaired/renewed/additional/new electric installation at the premises of :-

Full name :-

M A N B H A S Y I E M L I E H

(Address)

(Please leave one block between name and surname)

U M R O I M A D A N


Is duly completed tested and ready for your Engineer to test and connect on your main line.
1-. The Load has been arranged as follows :

Details of Load	Wattage Of each items	No of Points	Total
1. LIGHT POINTS			
(i) Fluorescent			
(ii) Incandescent			
(iii) CFL			
(iv) Halogen			
(v) Others / LED	9 Wt	6 Nos	54 Wt
2. FAN POINTS			
3. PLUG POINTS 3PIN			
(i) 6 Amps	100 Wt	5 Nos	500 Wt
(ii) 16 Amps	1000 Wt	1 No	1000 Wt
4. ELECTRICAL GADGETS			
(i) Water heater			
(ii) Refrigerator			
(iii) Others			
5. WELDING TRANSFORMER			
6. MOTOR			
TOTAL LOAD			1554 Wt
Incase if Load enhancement existing load (in watts)			
Total Load in the premises			2 kW

Note :

(a) A details of any apparatus (Other than the above mention) should be given

(b) Rating of Capacitor used in Induction Motor and Welding transformer (Test report of Capacitor is to be enclosed)



KVAR

II. Type of Wiring : Cable Capping

III. Voltage and System of Supply 230 V

IV. Test Result :- OK

Date of testing by licensed contractor :

1	7	0	2	0	2	5
Date		Month		Year		

Type of Test	Result of Test carried out by Licensed Contractor (In MO) Ω	Result of Test carried out by the Supplier under relevant L.R. Rule (In MO) Ω
a. Insulation resistance between earth and whole system of conductor	110 MO Ω	
b. Insulation resistance between all conductor	108 MO Ω	
c. Earth continuity between earth electrode and earth continuity conductor	30 Ω	
d. Polarity of non-linked SP switches	0 MO Ω (PN-230V EN-0.2V)	

V. Full name with signature of Licensed Contractor :

LIC No :

VI. Full name with signature of supervisor :(with date)

LIC No :

VII. Full name with signature of wireman :

Permit No. :

For Office used only

VIII. Signature of the Authorised Official who tested the installation behalf of supplier

Signature

IX. Date of Connection of supply to the installation :

भारत निर्वाचन आयोग
ELECTION COMMISSION OF INDIA
निर्वाचन पत्रिका पहचान पत्र - ELECTOR PHOTO IDENTITY CARD
ZRL0974660



Name : MANBHA SYIEMLIEH
Father's Name : DHIREN
KHARSYNTIEW

Gender : Male
Date of Birth/ Age : 03-03-1984

Address : HNo.52, UMROI MADAN , VILL-UMROI
MADAN, DIST-RI-BHOI-792103

Date : 13-01-2021
Electoral Registration
Officer

Assembly Constituency No. and Name : 12-UMROI
(ST)

Part No. and Name : 26-UMDOHBYRTHIH

नोट/Note :
1 इस पत्र के सम्बन्ध में यह ध्यान रखना चाहिए कि यह केवल निर्वाचन पत्रिका पहचान पत्र है। इसका उपयोग केवल निर्वाचन पत्रिका पहचान पत्र के रूप में ही किया जा सकता है।
More possession of this card is no guarantee that you are elector of the current electoral roll. Please check your name in the current electoral roll before every election.
2 इस पत्र के सम्बन्ध में यह ध्यान रखना चाहिए कि यह केवल निर्वाचन पत्रिका पहचान पत्र है। इसका उपयोग केवल निर्वाचन पत्रिका पहचान पत्र के रूप में ही किया जा सकता है।
Date of Birth mentioned in this card shall not be treated as a proof of age/D.O.B. for any purpose other than registration in electoral roll.

NA KA DORBAR U SYIEM RAID MAWBUIH

MYLLIEM SYIEMSHIP, UMROI

Dated : Umroi

The 10-04-2023

U/Ka Bereda, Bantishista, Phida Sylliang

Da kane la shah ia phi ba phin rep phin riang bad dakhol ia kane ka Jaka/ Pynthor Kba kaba don ha

Umroi Madan (Umlyngleir)

Raid Mawbuh, Mylliem Syiemship.

Phin pyndonkam ia kane ka jaka tang hapoh kine ki sawdong pud ba la ai harum :

MIHNGI : Ia khap jaka ka Edenora Syiem - 62 ft

SEPNGI : Ia khap ka Suok Shong - 59 ft

SHATEI : Ia khap jaka ka Keelida Sylliang - 95 ft

SHATHIE : Ia khap jaka ka Baintin Dhor - 117 ft

1. Haba phi rep phi riang ne dakhol ia katei ka jaka phi dei ban kohnguh ia ka jingpyniaid bad jingsynshar jong kane ka Dorbar.
2. Ka dustur bad riti jong ka Raid ka long ba lada phi la ieh noh khlem rep khlem riang ne khlem trei khlem ktah ne khlem dakhol ia katei ka jaka hapoh ka 3 (lai) snem, kane ka Dorbar ka lah ban ai noh shawei pat, bad phim lah ban ujo ei ei, ruh em.
3. Phim lah ban die lane aiti shawei pat ia katei ka jaka khlem ka jingup bad ka jingmynjur jong kane ka Dorbar. Lada phi leh pyrshah ia kane, kata kan long ka jingitkhlieh jong phi hi.
4. Lada shem ba phi leh pyrshah ia kawei na ki kyndon lane pyrshah ia ka jingmynjur jong kane ka Dorbar. kata lah ban pynshitom ia phi bad knieh noh ia katei ka jaka na ka jingdakhol jong phi.



[Signature]
Syiem
Raid Mawbuh

Ma U/Ka Bereda, Bantishista, Phida Sylliang

ba shong ha Umroi Madan (Umlyngleir)

nga mynjur bad kohnguh ia kitei ki kyndon baroh kumba la thoh haneng.

- 1) B. Sylliang
- 2) B. Sylliang
- 3) P. Sylliang

Dated : Umroi

The 10-04-2023

Jingrol Kyrteng

10000846732
22/11/2024
Phala 5/10/2024
CHARGES MCDATI
DIT
18/11
5/6/1912
1
149 50

20/11/2024
04/02/2025
26
22/11/2024 5252046846
DIT (Normal)
08/10
214 0
31 0
0
0

223.04
172.05
1.55
1.89
324.75
0.03
0.00
16.62
411.34
412.00
27/02/2025
23/11/2024
244
04/02/2025 12:41 V4.0

This bill will be considered as final notice under Section 9.2 of MSERC (Electricity Supply Code) Regulations, 2018. Supply of electricity shall be disconnected at any date if dues of electricity bill is not paid within 15 (fifteen) days from the due date of the bill. Thank you for paying. We really appreciate it!



For Bill Payments, Please visit www.mspower.com OR download Megha Power App from Google Playstore
The current bill includes the non-tariff difference amount for the MSERC-approved Distribution Tariff for 2024-25, to be collected in nine equal installments. For queries, please contact the AEEs of the respective divisions.

0	0
50	0
00	0
50	0
10	0
00	0
20	0
80	0
05	0
72	0
500	0
557.00	

DORBAR SHNONG UMROI MADAN RAID MAWBUI MYLLEIM SYIEMSHIP

Ri-Bhoi District Meghalaya-793116

Under rule 10(3) of the administration of Myllem Syiemship rules, 2015 of the Khasi Hills Autonomous District
Government and Succession of Syiem, Deputy Syiem, Electors and Rangbah Shnong of Myllem Syiemship] Act 2007

Dated: Umroi Madan
The: 17th / 12 / 2025

NO OBJECTION CERTIFICATE

Da kane nga pynshisha ba kam don kano kano ka jingpyrshah ia uka

Nubha Syiemleh _____ uka ba shong basah ha Umroi Madan ba un/kan apply
ymmai ia ka light connection domestic line sha iing jong uka kaba don ha Umroi Madan.

Shri
Rangbah Shnong
Dorbar Shnong Umroi Madan
Shri P. Matri
Rangbah Shnong
Umroi Madan

नकद पत्र

Date तिथि 17/02/25

PARTICULARS		RATE	AMOUNT	रकम
विवरण		दर	₹	P.
1 No	Meter Box	1000	1000	00
30mts	Pvc wire 6mm	80	2400	00
1 No	Cutout 32A	250	250	00
1 No	G.I. Earth 40mm	370	370	00
2 kgs	GT wire 6SWG	100	200	00
3 mts	G.I. pipe 25mm dia	260	780	00
2 No	G.I. Bend 25mm dia	40	80	00
3 No	G.I. Socket 25mm dia	35	105	00
3 No	Service clamp 25x5	24	72	00
Misc (Black tape, Fuse wire + Seal)			300	00
Rupees Five Thousand Five				
Hundred fifty Seven Only				
Thank You ! धन्यवाद!		Total	5557	00
E & S. Electrical		जोड़		

Nordlagen

DVT Electrical Contractor

~~LTC No: 387~~

Signature
हस्ताक्षर



DORBAR SHINONG UMSNING PATARIM

RAID MAWBUH : : MYLLIEM SYIEMSHIP
Ri Bhoi District


REF. NO:

DATED: UMSNING PATARIM
THE: 26TH FEBRUARY, 2025

TO WHOM IT MAY CONCERN

This is to CERTIFY that SHRI. MANBHA SYIEMLIEH son of
Shri. Dhiren Kharsyntiew is not a resident of Umsning Patarim.

SPECIFIED AUTHORITY



RANGBAJ SHINONG
UMSNING PATARIM
RI BHOI DISTRICT

RANGBAH SHNONG UMROI MADAN

RAID MAWBUH, MYLLIEM SYIEMSHIP
RI-BHOI DISTRICT, MEGHALAYA - 793116

rule 10 (3) of the administration of Myllem Syiemship rules, 2015 of the Khasi Hills Autonomous District Council.
Government and Succession of Syiem, Deputy Syiem, Electors and Rangbah Shnong of Myllem Syiemship) Act 2007

Ref. No.

Date 27/02/2025

RESIDENTIAL CERTIFICATE

This is to certify that Shri. / Smti. MANBHA SYIEMLIEM
Son/Daughter/Husband/Wife of Shri./Smti. Dhiren Kharsyntiew
is a permanent resident of Umroi Madan Village, Ri-Bhoi District, Block-Bhoirymbong,
Post Office-Bhoirymbong, Police Station - Umiam, Pin Code - 793116.

His / Her date of Birth is 03/03/1984.

To the best of my knowledge and belief, he/she bear a good moral character and
nothing adverse was found against him / her till date.

I wish Him / Her all success in life.

Shri. L.B. Makri
Headman Signature
Shri. L.B. Makri
Rangbah Shnong
Umroi Madan