

# APPENDIX - I

Form of application for supply of electricity at Low Tension / High tension

To,

The S.D.O Me. P.D. C. L (Elect)  
P.O Gmaballa  
Dist West Goro Helh

Sir,

I/We request you to supply electricity at Low Tension/High Tension to my/our premises situated at Dakupara.

The requisite information is furnished below :-

- i) Name of the applicant (consumer)
  - ii) Address for communication.
  - iii) Status of the consumer (applicant should state the legal status i.e. whether he is an individual owner or lawful occupant of the premises for which the supply is required, partnership firm or limited company or any other local person and in case of partnership firm it should be stated whether it is registered, or unregistered, location of its head office, names and address of all partners and a copy of the partnership deed should be filled. In case of company it should be stated whether it is a Private Ltd. or Public Ltd. names of present Directors and a copy of the memorandum of articles of association should be furnished. In case of any other type of articles of association should be furnished. In case of any other type of local person, full details and name and address of the person, competent to represent the consumer should be stated.
  - iv) Location of the premises where supply is required Dakupara
  - v) Character of Supply 230 volt AC sphere
  - vi) Purpose for which supply is required Domestic
  - vii) Contracted load 1.5 kw
  - viii) Details of the concerned load (The consumer should furnish the requirement for a period not less than 2 years and preferably for a period of 5 years)
 

L.P =	10x60w =	600 watt
P.P =	4x100w =	400 "
F.P =	4x100w =	400 "
T.P =	5x20w =	100 "
		<u>Total = 1500 watt</u>
2. I/We hereby agree to take supply and to pay all charges such as for energy, service connection and other dues including deposit of such security as may be demanded in accordance with the rates and conditions of supply of the Board in force from time to time. I/We further declare and agree to take supply of electric power for the above-mentioned purpose for a period of not less than 2 years from the date of commencement of supply and, in case of reconnection of supply after a period of 6 months from the date of disconnection for not less than one year from the date of re-connection.
  3. I/We also undertake to receive supply within 3 months from the date of Board intimates that it is ready to give supply to our premises failing which I/We undertake to pay the Board the minimum charges as may be applicable.
  4. This application is for
    - a) A new service connection yes
    - b) Re-connection ✓
    - c) Alteration to may existing installation ✓
    - d) Temporary Service Connection ✓
    - e) Charge of Service Connection in the name of ✓

APPENDIX - II  
AGREEMENT FOR SUPPLY AT LOW TENSION

Agreement executed this \_\_\_\_\_ day of \_\_\_\_\_ 20\_\_\_\_ by \_\_\_\_\_  
for themselves/ himself/herself/itself and for their/his/ her/ its assigns and successor of the Meghalaya State Electricity Board statutory corporation constituted under Section 5 of the Electricity (Supply) Act, 1948 and its successor and assigns hereinafter called the BOARD.

**2. SUPPLY OF POWER**

I/We the above mentioned have requested the Board to supply electricity at High Tension for the purpose of Domestic and the Meghalaya State Electricity Board has agreed to afford such supply Act on the terms and conditions notified by them from time to time under Section 49 of the Electricity (Supply) Act, 1948 and those herein contained.

Details of Supply

- a) Purpose Domestic  
b) Category 230v/1t A/c

**3. LOAD**

I/We agree to take from Meghalaya State Electricity Board electric power for a load not exceeding 230v/1t A/c 8 HP/KW for exclusive use for the purpose as mentioned above at our mills/factory/premises situated at Dakupura

The contract demand agreed between the Board and myself/ourselves are \_\_\_\_\_ KW/HP for the first year 1.54 KW/HP for 2 year.

**4. OBLIGATION TO COMPLY WITH REQUIREMENT OF ACTS, RULES, TERMS AND CONDITIONS OF SUPPLY :**

I/We further undertake to comply with all the requirements of the Indian Electricity Act, 1940, the Electricity (Supply) Act, 1948, the rules thereunder, the provisions of the Schedule of Miscellaneous charges, the terms and conditions of supply prescribed by the Board from time to time and not to dispute the same.

**5. DATE OF COMING INTO FORCE OF THE AGREEMENT :**

I/ We undertake to receive the supply within 3 months from the date the Board intimates that it is ready to give the supply to my/our premises, failing which I/We undertake to pay the Board the minimum charges as may be applicable and decided by the Board, further the provisions of the contracts shall be deemed to have come into force from the date of commencement of the supply or the date of expiry of 3 months notice above referred to whichever is earlier.

**6. PERIOD OF AGREEMENT**

I/We undertake to avail supply for a minimum period of 2 years from the date of this agreement has come into force.

**7. DETERMINATION OF THE AGREEMENT**

I/We shall be at liberty to determine the contract by giving in writing one month's notice expressing intentions at any time after the expiry of 2 years. I/We agree that Meghalaya State Electricity Board may terminate the contract at any time giving 7 days notice if I/We violate the terms and conditions of supply notified by the Meghalaya State Electricity Board from time to time or provisions of any law touching this agreement including the Electricity (Supply) Act 1948 the Indian Electricity Act



# NOTICE OF COMMENCEMENT OF WORKS

From

The Inspector of Electricity  
Meghalaya, Shillong

M/S. Modern Electrical House  
Halliday Ganj  
West Garo Hills, Meghalaya  
Regd. No. 428

Subject :- Notice of commencement of works under clause 36 of Rules and condition prescribed under Rule 45 (1) of India Electricity Rules, 1956

Sir,

I have the honour to inform you that Addition/ Alternation/ Repair New Electricity installation will be executed by me/us in the undermentione premises and the particulars are stated below.

1. Owner of premises :- Name :- Kenedi Hyang  
Address :- DAKU P 909  
P.O. :- Bokrong Dist :- South West Garo Hills

2. Number of points	Nos	Watts	Total Wattage	
i) Light points	10 Nos	60 W -	600 W	
ii) Plug point	4 Nos	100 W -	400 W	
iii) Fan point	4 Nos	100 W	400 W	1.5 K/W
ii) Plug point Tube	5 Nos	20 W =	100 W	
ii) Power plug			C	
ii) Other apperatus			1500 W	

3. Type of Wiring :- Looping

4. Date of commencement :- 18/12/24

5. Name of supervisor :- A.F. Hoque  
Regd. No. 670

6. Name of Wireman

i) Bijendra Paul  
ii)

Regd. No. 2308

Yours faithfully

*[Signature]*

M/S. Modern Electrical House

Hallydayganj  
Regd. No. 428

Copy to :-

The S.D.O. (Elect.)

Me. P.D.C.L

Garebadha

# MEGHALAYA POWER DISTRIBUTION CORPORATION LIMITED

## TEST REPORT

This is to certify that repaired / renewed / additional / new electric installation at the premises of

K E N E D I H A J O N G

(Full Name)

V I L L D A K U P A R A P O B O R K O N A

(Address) Dist South West Garo Hills

is duly completed, tested and is ready for your Engineer to test and connect on your main line.

1. The load has been arranged as follows :

Details of Load	Wattage of each item	Phase - 1		Phase - 2		Phase - 3		Total Watt of all 3 phases
		No. of Points	Total Watt	No. of Points	Total Watt	No. of Points	Total Watt	
1. Light Points	60 W x 10 No		600 watt					
i) Fluorescent	20 W x 5 No		100 "					
ii) Incandescent								
iii) CFL								
iv) Halogen								
v) Others								
2. Fan Points	100 W x 4 No		400 watt					
3. Plug Points (3-pin)								
i) 6 Amps	100 W x 4 No		400 "					
ii) 16 Amps								
4. Electrical gadgets								
i) Water Heater (Geyser)								
ii) Refrigerator								
iii) Air Conditioner								
iv) Others								
5. Welding Transformer								
6. Motor								
<b>TOTAL</b>			1500 watt					
In Case of load enhancement								
Existing load								
Total load in premises								

Notes :

- Details of any apparatus (other than the above mentioned) should be given
- Rating of capacitor used in Induction Motor and welding Transformer (Test report of capacitor is to be enclosed).



भारत निर्वाचन आयोग  
ELECTION COMMISSION OF INDIA  
मतदाता फोटो पहचान पत्र - Elector Photo Identity Card

KZS0617340



Name: Kenedi Hajong  
Father's Name: Lt.amendra Hajong  
Gender: Male  
Date of Birth / Age: 41



*Signature*

Address: 37, DINGJOAR, DAKUPARA, SOUTH WEST GARD  
HILLS, MEGHALAYA - 794105



Electoral Registration Officer, SJ AMPATI  
Issue Date: 05-06-2023

KZS0617340

1) Before every Election, please check that your name exists in current electoral roll  
2) This card is not a proof of age except for purpose of Election

1950

[www.eci.gov.in](http://www.eci.gov.in)



# ROUTINE TEST REPORT

Serial Number: SS17289168

Customer: M/S MAMTA ELECTRICALS

Customer P.O Number: MAMTA/23-24/005

Customer P.O Date: 21-SEP-2023

Voltage: 240V

Current: 05-30A

Accuracy Class: 1.0

Ref. Standard: IS : 13779

Meter Constant: 6400

1. AC VOLTAGE TEST: PASS
2. TEST OF NO LOAD CONDITION: PASS
3. TEST OF STARTING CURRENT: PASS
4. INSULATION TEST: PASS
5. METER ACCURACY:-

Reference Conditions: Vref = 240V/50Hz Ib = 05-30A Amb. Temp = 27 +/- 2 Deg. C

## METER ACCURACY


### % Active Import Errors

Load % Ib	0.5 Lag	0.8 Lead	UPF
600	0.3	0.0	0.0
100	0.1	0.0	0.0
10	0.1	0.0	0.0
5			0.0

00001.0

TEST DATE: 29/11/2023

This is computer generated test report no signature required

  
Meter Tester Gr - I  
MTI Laboratory  
MePDCL, Lumjingshai  
Shillong

  
Executive Engineer  
MTI Division  
MePDCL, Shillong