

# Form 7

## Meghalaya Energy Corporation Limited

### TEST REPORT

This is to certify that repaired/renewed/additional/new electric installation at the premises of

DAIANA KHARRYNBA

(Please leave one block between name & surname)

(Full Name)

MAWLYNONG

(Address)

is duly completed, tested and is ready for your Engineer to test and connect on your main line.

1. The load has been arranged as follows:-

Details of Load	Wattage of each item	Phase - I		Phase - 2		Phase - 3		Total watt of all 3 phases
		No. of points	Total wart	No. of points	Total wart	No. of points	Total wart	
1. Light points (i) Fluorescent (ii) Incandescent (iii) CFL / LED (iv) Halogen (v) Others	18w	7	126w					
2. Fan points								
3. Plug points (3-pin) (i) 6 Amps (ii) 16 Amps	100w	6	600w					
4. Electrical gadgets (i) Water Heater (geyser) (ii) Refrigerator (iii) Air Conditioner (iv) Others								
5. Welding Transformer								
6. Motor								
<b>Total</b>			726 watt					
In case of load enhancement Existing load (in watts)			or					
Total load in the premises (in watts)			1 Kilo watt					

Notes:-

- Details of any apparatus (other than the above mentioned) should be given.
- Rating of capacitor used in Induction Motor and Welding Transformer (Test Report of capacitor is to be enclosed)

KVAR

- II. Type of wiring *pvc Looping system*
- III. Voltage and system of supply *230v*
- IV. Test Result : *OK*

Date of Testing by Licensed Contractor:

*050225*

Type of Test	Result of test carried out by licensed contractor (in M $\Omega$ )/ $\Omega$	Result of test carried out by the supplier under relevant IE Rules, in (M $\Omega$ )/ $\Omega$
a. Insulation resistance between earth and whole system of conductor	<i>18 <math>\Omega</math></i>	
b. Insulation resistance between all conductors.	<i>19 <math>\Omega</math></i>	
c. Earth continuity between all earth electrode and earth continuity conductor.	<i>Phase</i>	
d. Polarity of non-linked SP switches.	<i>OK</i>	

V. Full Name with signature of Licensed contractor :

LIC No.

*A. Khongwieng*  
A. KHONGWIENG  
ELECTRICAL CONTRACTOR  
LIC. NO. 285

VI. Full Name with signature of supervisor (with date) :

LIC No.

*A. Khongwieng*  
A. KHONGWIENG  
ELECTRICAL SUPERVISOR  
LIC. NO. 375

VII. Full Name with signature of wireman (with date) :

PERMIT No.

*A. Khongwieng*  
Lic no - 10739

VIII. Signature of the authorised official who tested The installation of behalf of supplier. :

IX. Date of connection of supply to the installation :



## AGREEMENT FOR SUPPLY OF ELECTRICITY LOW TENSION

AN AGREEMENT made this the 4th day of February 20 25  
between \_\_\_\_\_ and his successors and assigns (hereinafter  
referred to as the Consumer) of the One Part and The Meghalaya State Electricity Board an electricity  
distribution licensee under the Electricity Act, 2003 and its successors and assigns (hereinafter referred to as  
the Board) of the Other Part

*Note: The term 'consumer' includes an individual person (whether male or female), a body  
of persons, a company, society, firm, association or organization*

WHEREAS, the consumer has applied to the Board for supply of electricity to its premises and the  
Board has agreed to give the supply under the terms and conditions hereinafter appearing

NOW, THEREFORE, the agreement witnesses-

- (1) That the supply shall be given to the premises located at \_\_\_\_\_  
with the consumer as owner/occupier of. *Maulynrong*
- (2) That the supply shall be for the purpose of \_\_\_\_\_, the load  
whereof shall not exceed 1kw watt(s); *DAT*
- (3) That the provisions of the Electricity Act, 2003 and the Regulations, Code and Orders, including Tariff  
Orders, as may be made from time to time by the Meghalaya State Electricity Regulatory Commission  
shall apply and bind the consumer and the Board alike,
- (4) That the consumer shall regularly and timely pay to the Board all charges and may be due for the  
supply of electricity,
- (5) That the Agreement shall be for a period of two years and may be renewed for a further period.  
Provided that supply shall not be terminated by mere efflux of time if the consumer is willing  
that the agreement is renewed,
- (6) That the Agreement shall be terminated if the consumer on its part desires it so and gives to the Board  
a prior notice of not less than one month or on the part of the Board if the consumer has violated any  
of the terms and conditions of the agreement.

