



MEPDCL ENERGY POWER DISTRIBUTION CORPORATION LIMITED
APPLICATION FORM FOR PROVIDING SERVICE CONNECTION
(FOR ALL CATEGORY AND FOR ALL PURPOSE)

15 meters Transformer 100K.V.A

The Area Manager / Assistant Executive Engineer
 Service Connection Sub Division / Distribution Sub Division
 MePDCL

(Indicate the local area of the jurisdiction of the Engineer of the Licensee)

I/We hereby request you to supply electricity to the premises located at the address more fully described below.

I/We agree to abide by the terms and conditions relating to the supply of electricity by MePDCL and to make all payments as may be required and also to pay regularly all charges as may become due.

(a) Full name and address of the applicant with contact telephone/ Mobile number

Balarisha Nongrum
Mawpun Kshaid
8837489753

*load sanction of 69kw
 from Py 11 um. blocks
 (1.V)
 Dist 100KV*

(b) Status in relation to the premises :
 Owner
 Occupier

*Junior Engineer (EL)
 Umlam Dist.Sub-Division
 MePDCL, Umlam*

(c) Location and address of the premises including Police Station :

(d) Nature of LT Supply :
 Commercial Domestic Industrial
 General Purpose WSLT PL
 Agriculture KJ MePDCL
 Employee

Date : *24/02/26*

B. Nongrum
 Applicant's Signature

- NB : The following documents are to be enclosed
- (1) Test Report from Licensed contractor
 - (2) Agreement form duly filled in
 - (3) Proof of ownership (in case an applicant is owner)
 - (4) Number of nearest Electric Pole Number of nearest Consumer.....
 - (5) NOC of the owner of the premises (in case an applicant is an occupier)
 - (6) Attested copies of permission obtained from Pollution Control Board (if applicable).
 - (7) Building permission from the concerned authority (if applicable)
 - (8) Occupancy Certificate from MUDA for areas within Shillong Municipal Limit (if applicable)
 - (9) Proof of Identification (any one of the following) -
 Electoral Identity Card/Possport/Driving Licence/ Ration Card/Photo Identity Card issued by Government agency / PAN Card/Certificate of residence or identity from the Headman/Nokma.Village Levelworker/Primary School Teacher/Incharge of primary health centre



Annexure -3

Agreement for Supply of Electricity Low Tension

An Agreement made this the _____ day of _____ of 20 _____ between _____ and his successor and assigns (hereinafter referred to as the consumer) of the one part and the Meghalaya Power Distribution Corporation Limited an electricity distribution licensee under the EA, 2003 and its successors and assigns (hereinafter referred to as the Distribution/Utility/MePDCL) of the other part.

Note : The term 'consumer' includes an individual person (Whether male or female), a body of persons, a company, society, firm, association or organization.

Whereas, the consumer has applied to the distribution utility for supply of electricity to the premises and the distribution utility has agreed to give the supply under the terms and conditions hereafter appearing.

Now, therefore, the agreement witness :-

(1) That the supply shall be given to the premises located at Mawpan Kshaid with the Consumer as owner/occupier of ;

(2) That the supply shall be for the purpose of DLT the load whereof shall not exceed 2 kw watts.

(3) That the provision of the EA, 2003 and the regulations, code and orders including tariff orders, as may be made from time to time by the MSERC shall apply and bind the consumers and the distribution utility alike.

(4) That the consumer shall regularly and timely pay to MePDCL all charges may be due for the supply of electricity.

(4-a). That the consumer shall pay the Transformer Maintenance Charge as stipulated in the license and thereby maintenance and replacement of the transformer on account of which shall be the responsibility of the licensee.

(5). That the agreement shall be a period of two years and may be renewed for a further period of two years. Provided that supply shall not be terminated by mere efflux of time if the consumer is willing that the agreement is renewed;

(6). That the agreement shall be terminated if the consumer on its part desires it so and gives to the MePDCL a prior notice of not less than one month or on the part of the MePDCL, if the consumer has violated any of the terms and conditions of the agreement.

Provided that on the part of the MePDCL notice shall be given to the consumer stating the reasons for the proposed termination and giving him opportunity to state his case and his statement, if any, duly considered before the agreement is terminated and the supply of Electricity cut off:

(7) The terms and conditions of this agreement shall be effective from the date of supply of electricity is commenced.

IN WITNESS WHEREOF the parties hereto have set their hands and seals the date, month, and year first above written.

(For and on behalf of and by
Authorisation the) consumer.

For and on behalf of MePDCL

Witness :-

1. Signature : [Signature]
Name : ELTO Skylla
Address : Nongluch

2. Signature : B. Nongrum
Name : Balaritka Nongrum
Address : Pyllun

Malaya Energy Corporation Limited

TEST REPORT

I hereby certify that repaired/renewed/additional/new electric installation at the premises of

ALARISHA HONGRUM

(Please leave one block between name & surname)

(Full Name)

PYLLUN BLOCK IV

(Address)

is duly completed, tested and is ready for your Engineer to test and connect on your main line.

The load has been arranged as follows :-

Details of Load	Wattage of each item	Phase - 1		Phase - 2		Phase - 3		Total watt of all 3 phases
		No. of points	Total watt	No. of points	Total watt	No. of points	Total watt	
1 Light points								
(i) Fluorescent								
(ii) Incandescent								
(iii) CFL								
(iv) Halogen								
(v) Others (LED)	12	12	144					
2 Fan points								
3 Plug points (3-pin)								
(i) 6 Amps	100	4	400					
(ii) 16 Amps	1000	1	1000					
4 Electrical gadgets								
(i) Water Heater (Geyser)								
(ii) Refrigerator								
(iii) Air Conditioner								
(iv) Others								
5 Welding transformer								
6 Motor								
Total			1544					
In case of load enhancement Existing load (in watts)								
Total load in the premises (in watts)			2 Kw					

Notes :-

- (a) Details of any apparatus (other than the above mentioned) should be given.
- (b) Rating of capacitor used in Induction Motor and Welding Transformer (Test report of capacitor is to be enclosed)

2 Kw

KVAR

II Type of wiring *Casing capping*

III Voltage and system of supply *230V*

IV Test Result: *OK*

Date of Testing by Licensed Contractor :

2	4	0	2	2	6
---	---	---	---	---	---

Type of Test	Result of test carried out by licensed contractor (in M Ω) / Ω	Result of test carried out by the supplier under relevant IE Rules, in (M Ω) / Ω
a. Insulation resistance between earth and whole system of conductor	<i>110 MΩ</i>	
b. Insulation resistance between all conductors	<i>107 MΩ</i>	
c. Earth continuity between earth electrode and earth continuity conductor.	<i>3 Ω</i>	
d. Polarity of non-linked SP switches.	<i>0 MΩ (PN-230V EN-DU)</i>	

V Full Name with signature of Licensed contractor

LIC No.

D. S. Kharsyntiev

D. S. KHARSYNTIEV
Electrical Contractor
Registered No. 222

VI Full Name with signature of supervisor (with date)

LIC No.

D. Kharkrang

D. Kharkrang
Electrical Supervisor
Regd No. 1130

VII Full Name with signature of wireman (with date)

PERMIT No.

D. Kharkrang

D. Kharkrang
Electrical Licence
Regd No. 8589

VIII Signature of the authorised official who tested The installation of behalf of supplier.

IX Date of connection of supply to the installation

DORBAR SHNONG MA WPUN KSHAID

(Ka Dulir Ai Siew, Shim Siew Khyndew)

Dated: Mawpun Kshaid
The: 27th March, '09

Bah Michael Pasaah

Ha kane ka sngi 27 - March - 2009 Hapdeng ka jingkoit jingkhiah bad
jingtipbriew bha bad da ka jingiapyneit ha ing ha sem, nga u / ka Shou Sing Malngiang
ba long trai jong katei ka jaka nga wan ban Ai Siew
bait ksan duh noh ia ka jaka jong nga Raid Mawbuh Hima Myllem ha phi ba don kyrteng haneng ha ka
dor Rs 30,000/- (Lai phaw hayar) nyngkat ka ing.
Ha kaba ia ka tyngka baroh lab ban ioh dep mynta ka sngi bad ia ki kot ki sla jong katei ka jaka la
aiti noh sha phi

KI SAWDONG PUD KA JAKA.


SHATEI	Ka jaka u Kayphas fahyathien - 38 1/2 ft.
SHATHIE	Ka Surok shnung. - 41 ft.
MIINGI	Ka Kati Eketon Kharkongoo - 34 ft.
SEPNGI	Ka Lynti shnung. - 33 ft.

Naduh kane ka sngi katei ka jaka ba la ai sawdong pud haneng kan long noh ka hok jong phi bad ki
pateng junom. Ma nga lem bad ki pateng ngim don hok shuh ban kam trai junom


Hynrei lada don ba uxor lane ba pynwit ia ka jingdakhol jong phi ia katei ka jaka, ka jingkitkhieh
baroh kan long halor jong nga u / ka ba ai siew

La leh ia kane hakmat u Rangbah shnung lem bad ki sakh i satar.

Sakhi	Nongthoh	Nongaisiew
1	Dombor Kharsahat Dombor Kharsahat	Shou Sing Malngiang
2		Shou Sing Malngiang
3		
4		
5		
6		


Secretary
Mawpun Kshaid Village
5 Km Umrui Road, Umrui District.

La leh ia kane hakmat jong nga u Rangbah shnung bad ka Rai Dorbar ka long ba phim bit ban die
ne aiti shawei khlei ka jingtip ki Nongsynshar Shnung



7/27/09
Headman,
Rangbah Shnung
5 Km Umrui Road
Umrui District

Dated: Mawpun Kshaid

No Objection Certificate

Tarik: 24-02-2026

Da Kane, manga u Michael Passah, kwim jong 3
Balaiuha Wongum ba dei u Thai Jaka jong ka
iing kaba don ha Mauwun kshaid, nga pynpaw
hangre ba ngam don jing ujer eiei ouh ia
3 kong Balaiuha Wongum sba dei 3 kwim jong
nga ban leh connection light ia ka iing ha
ka kyiteng jong 3.



Michael Passah

Thai Jaka.

RANGBAH SHNONG MAWPUN KSHAIID
RAID MAWBUH, MYLLIEM SYIEMSHIP
P.O. & P.S UMIAM, RI-BHOI DISTRICT, MEGHALAYA-793103

(3) of the Administration of Myllem Syiemship Rules, 2015 of the Khasi Hills Autonomous District Council (Appointment and Succession of Syiem, Deputy Syiem, Electors, and Rangbah Shnong of Myllem Syiemship) Act, 2007.

No. DSMK/NOC/2026-27/01

Date 19 Feb. 2026.

To whom it may concern

This is to certify that I have no objection for Smti Pzalarisha Nongrum D/O Smti & Susana Nongrum to approach the MeECL authorities for electricity connection in her residence at Mawpun Kshaid, Ri Bhoi District PO-793103

Pratijaka

Chassak

25/2/26

Rangbah Shnong
Bandari Rynthiang
Rangbah Shnong
Mawpun Kshaid

908468

0557

27-01-2026 11:18:52

: Balarisha Nongrum-Mawpun (Umroi), Mawpun_Umroi #3061204600
- 1000200557

Amount : Rs.354.0/-

(Three Hundred Fifty Four Rupees Only.)

Secret Key : INBF

Drawn BY : FEBRICA KHARBULI-CASHIER(SUB DIV
)

Verify the Consumer ID and Amount

Thank you for using i~EasyBill

URGAM SUBJ: 70125.001

1000200557

22320057

Balansha Nagpur

Mawpur (Umra)

Maw, - Umra

101120490

DLI

1831

Meter No.

429151

DMF Code

IAN No

MEPDCL1000200557

Billing Details

Prev. Reading Date

09/12/2025

Cur. Reading Date

12/01/2026

No. of Days

34

Bill Number

2232005261120407

Bill Status

On (Normal)

Prev KWH

646.41

Current KWH

746.41

Billed Unit

54.0

Recorded MD

Power Factor

Average

Bill Charges

Fixed Charges (Unit, Rate, Amount)

LD KW

90.0

91.71

Energy Charges (Unit, Rate, Amount)

54.0

5.0

270.00

ED Amount (Unit, Rate, Amount)

54.0

0.05

2.70

FPPAS

-18.00

(NOV 26 TO NOV 25 : -18.00)

Current Bill Unit

353.41

Consumer Credit

-41.14

Adjustment

0.00

Gross Bill Amount

352.27

Net Bill Amount

₹ 354.00

Due Date

29/01/2026

Last Payment Date

27/12/2025

Last Payment Amount

704

12/01/2026 14:14 V4.6

This bill will be considered as final notice under Section 92 of MSEDCL (Electricity Supply Code) Regulations. The Supply of electricity shall be disconnected at any date, if dues of Electricity bill is not paid within 15 (fifteen) days (notice period) after the date of the bill. Thanks for paying. We really appreciate it!



For Bill Payments, Please visit www.meghaponline.com or Download Megha Power App from Google Playstore

on



CABLES

Date 30/1/26

DESCRIPTION	Qty.	Rate	Amount
ing 1"	16 PC		720
wire 1.5mm	2 coil		4400
1) wire 2.5mm	35m		1500
2) wire 6.0mm	10m		900
3) MCB Box 6way	1PC		500
4) Insulator 40A	1PC		380
5) MCB 10A	3PC		390
6) Angle holder	6PC		280
7) Square Box	6PC		105
8) Switch 6A	11PC		165
9) Socket 6A	4PC		120
10) G. Box 2way	1PC		25
11) G. Box 3way	2PC		60
12) G. Box 4way	2PC		80
13) SS combine	1PC		150
14) Earthing Plate 1x1	1PC		2750
15) Nut bolt	1PC		75
16) copper wire	5m		650
17) Screw 1"	1PKt		90
18) Gutter	1PKt		40

21)	MCB 32A	1 PC	
22)	Meter Box	1 PC	1000
23)	G.I wire 6mm	25m	700
24)	G-I Pipe 40mm	1 PC	500
25)	G-I Bend	2 PC	110
26)	Clamp	3 PC	60
27)	Kit Kat Furl 32A	2 No	220
28)	Insulation tape	2 No	80
	Total		<u>15,780</u>

भारत निर्वाचन आयोग
ELECTION COMMISSION OF INDIA
भारतीय निर्वाचन पहचान पत्र - ELECTORAL PHOTO IDENTITY CARD
DHJ0529297




Name : **BALARISHA NONGRUM**
Father's Name : **D SUMER**

Gender : Female
Date of Birth/ Age : 12.07.1983

Address : HNo.40, PYLLUN , VILL-PYLLUN, DIST- RI.BHOI-793103

Date : 18-03-2021

Electoral Registration Officer

Assembly Constituency No. and Name : 12-UMRO (ST)

Part No. and Name : 26-PYLLUN

नोट / Note :

1. इस कार्ड को धरन कतने बार से का कोई गारंटी नहीं है कि उन लोग निरन्तर पंजामी में लिखत है। कृपया कतने बार जहा कतने बार से का निरन्तर पंजामी में जात ले।
More possession of this card is no guarantee that you are elector of the current electoral roll. Please check your name in the current electoral roll before every election.

2. इस कार्ड में उल्लिखित जन्मदिनि को निरन्तर पंजामी में पंजामी के कतने बार लिखत से लिखत में का कतने बार से का में का कतने बार।
Date of Birth mentioned in this card shall not be treated as a proof of age/D.O.B. for any purpose other than registration in electoral roll.