

2833

NEW CONSUMER APPLICATION FORM



☐ If Consumer Apply for Sub-Meter/ Additional Connection
(Please tick on the check box)

Personal Details

* Application No. _____
 * Consumer Name Kmensemai Kharsyntiew
 * Father's Name Bensing Nonghang
 * Mobile No. 6009911866 Email _____
 Aadhaar / EPIC No. KCX0527796

Address Details

* Accommodation Own / Rented (Pl. tick one)
 * Discom Meghalaya Power Distribution Corporation
 * Zone Eastern Zone * Circle Ribhoi Circle * Division Umiam Division
Umiam Rural Distribution Sub-Division
 * Sub-Division Mawpurn Kshaid
 * Village Name Mawpurn Kshaid
 * State Meghalaya * City Ribhoi (Nongpoh)
 * Area Pin code 793103 Locality Mawpurn Kshaid
 Full Address Mawpurn Kshaid

New Connection Details

* Consumer Type SG / CG / NG (Pl. tick one) * Urban/Rural Type Rural / Urban (Pl. tick one)
 * Activity House
 * Contract Load Unit KW / KVA (Pl. tick one) * Contract Load _____
 * Category Domestic * Product Type LT / HT (Pl. tick one)
 * Scheme All Categories excluding industrial / Industrial / Free Scheme /
Saubhagya/ DDUGJY (Pl. tick one)

Other Details

* Meter Number _____ * Initial KWH _____ * Initial KVAH _____
 * Meter MF _____ Meter Owned - Utility / Consumer (Pl. tick one)
 * Phase 1 Phase / 3 Phase (Pl. tick one) * TMC - Yes / No (Pl. tick one)
 Meter Reader _____ Group No. _____

List of Documents to be attach:

- * Test Report
- * Ownership Proof
- * Identity Proof
- * Meter Test Report
- Landlord NOC
- Agreement Fill
- Pollution Control Board

Kong. Dari
for Add meter

AS
Assistant Executive Engineer
Umiam Rural Distribution Sub-Division
M.P.D.C.L. Umiam

Date of Connection: _____

Sub meter

20 meter

Transformer 100KV-A

APPLICATION FORM FOR PROVIDING LT SERVICE CONNECTION (FOR ALL CATEGORY AND FOR ALL PURPOSE)

The Area Manager/ Asstt. Executive Engineer.

Service Connection Sub-Division/ UR Distribution Sub-Division

Me. SEB, Umiam

(Indicate the local area of the jurisdiction of the Engineer of the licensee)

Sir,

- I/We hereby request you to supply electricity to the premises located at the address more fully described below. I/We are the owner/lawful occupier of the premises.
- I/We agree to abide by the terms and conditions relating to the supply of electricity by Me. SEB and to make all payments as may be required and also to pay regularly all charges as may become due.

a) Full name and address of the applicant with contact telephone number. 6009911866

• Komen Simai Khar Syntian Mawpun

b) Status in relation to the premises Kshaid Owner ☒

Occupier ☐

c) Location and address of the premises including Police Station.

Mawpun Kshaid Umroi Road

d) Nature of LT supply:

P.S. Umiam

Commercial ☐

Domestics ☒

Industrial ☐

General Purpose ☐

WSLT ☐

PL ☐

Agriculture ☐

KI ☐

2kw Load Sanction from
Mawpun Kshaid 100KVA S/S

Date:

5/5/25

Junior Engineer (EL)
Umami Rural Dist Sub-Division
Umiam

Applicant's Signature

NE. The following documents are to be enclosed:

- Test Report from Licensed contractor.
- Agreement Form duly filled in.
- Proof of ownership (in case applicant is owner).
- Number of nearest Electric Pole.
- NOC of the owner of the premises (in case the application is an occupier).
- Attested copy of permission obtained from Pollution Control Board.
- Building permission from the concerned authority.

AGREEMENT FOR SUPPLY OF ELECTRICITY
LOW TENSION



AGREEMENT made this the _____ day of _____
between Konenshanti Khoshtaria and his successors and assigns
hereinafter referred to as the Consumer) of the One Part and the Meghalaya State Electricity Board
and electricity distribution licensee under the Electricity Act, 2003 and its successors and assigns
(hereinafter referred to as the Board) of the Other Part.

Note: The term 'consumer' includes an individual person (whether male or female), a body of persons, a company, society, firm, association or organization.

WHEREAS, the consumer has applied to the Board for supply of electricity to its premises
and the Board has agreed to give the supply under the terms and conditions hereinafter appearing.

NOW, THEREFORE, the agreement witnesses:-

- 1) That the supply shall be given to the premises located at Mangpan Kshaid with
the consumer as owner/occupier of;
- 2) That the supply shall be for the purpose of Domestic, the load
whereof shall not exceed 2000 watt(s);
- 3) That the provisions of the Electricity Act 2003 and the Regulations, Code and Orders, including
Tariff Orders, as may be made from time to time by the Meghalaya State Electricity Regulatory
Commission shall apply and bind the consumer and the Board alike;
- 4) That the consumer shall regularly and timely pay to the Board all charges and may be due for the
supply of electricity;
- 5) That the Agreement shall be for a period of two years and may be renewed for a further period:
Provided that supply shall not be terminated by mere efflux of time if the consumer is willing
that the agreement is renewed;
- 6) That the Agreement shall be terminated if the consumer on its part desires it so and give to the
Board a prior notice of not less than one month or, on the part of the Board, if the consumer has
violated any of the terms and conditions of the agreement;

Provided that on the part of the Board notice shall be given to the consumer of the reasons for the proposed termination and giving him opportunity to state his statement, if any, duly considered before the agreement is terminated and the supply of electricity cut off.

- 7) That the terms and conditions of this Agreement shall be effective from the date supply of electricity commenced.

IN WITNESS WHEREOF the parties hereto have set their hands and seals the _____ month and year first above written.

(*K. Khasaria*)
The Consumer

(_____)
For and on behalf of the Board

Witnesses :-

1. Signature :

Name :

Address :

1. Signature :

Name :

Address :

TEST REPORT

For the supply of electricity to the premises of

K M E N S I M A I K H A R S Y N T I E M

(Please leave one block between name & surname)

(If any)

M A V P U N K S H A I D U M R O I R O A D

(Address)

is duly completed, tested and is ready for your Engineer to test and connect on your main line.

1. The load has been arranged as follows :-

Details of Load	Voltage of each item	Phase - 1		Phase - 2		Phase - 3		Total Watt of all 3 phases
1. Light Points (i) Fluorescent (ii) Incandescent (iii) CFL (iv) Halogen (v) Others W L E D	12 w	5	60 w					
2. Fan Points	100 w	2	200 w					
3. Plug Points (3-pin) (i) 6Amps (ii) 16Amps	100 w	3	300 w					
	1000 w	1	1000 w					
4. Electrical gadgets (i) Water Heater (geyser) (ii) Refrigerator (iii) Air Conditioner (iv) Other								
5. Welding Transformer								
6. Motor								
Total			1560					
In case of load enhancement								
Existing load (in watts)								
Total load in the premises (in watts)								

Notes :-

(a) Details of any apparatus (other than the above mentioned) should be given

(b) Rating of capacitor used in Induction Motor and Welding Transformer (Test report of capacitor to be enclosed)

KVAR

III. Voltage and system of supply *230V*

IV. Test Result : *O.K. 230V*

Date of Testing by Licensed Contractor :

0	5	0	5	2	5
---	---	---	---	---	---

Type of Test	Result of test carried out by licensed contractor In (M Ω)/ Ω	Result of test carried out by the supplier under relevant IE Rules, In (M Ω)/ Ω
a. Insulation resistance between earth and whole system of conductor	<i>120 MΩ</i>	
b. Insulation resistance between all conductors.	<i>120 MΩ</i>	
c. Earth continuity between earth electrode and earth continuity conductor.	<i>2 Ω</i>	
d. Polarity on non-linked SP switches.	<i>single phase</i>	

V. Full Name with signature of Licensed Contractor

LIC No.

S. Langstieh
Electrical Contractor
Regd. No : 652

VI. Full Name with signature of supervisor
(with date)

S. Langstieh
Electrical Supervisor
Regd. No : 1537

VII. Full Name with signature of wireman
(with date).

PERMIT NO.

VIII. Signature of the authorized official who tested
The installation of behalf of supplier.

IX. Date of connection of supply to the installation

Raj-Rhod District.

भारत निर्वाचन आयोग
ELECTION COMMISSION OF INDIA
नगरपालिका निर्वाचन प्रमाण पत्र / Gender Based EPIC Card

REGISTRATION

Photo

Name: Khensimal Kharsynliu
Father's Name: Bonsing Nongrang
Gender: Female
Date of Birth: Age: 28-01-1991

EPIC Card

UMBAM SUBDIVISION
1000200556
2232005

Name: Khensimar Kharsynbew
Mawpun (Umro),
Mawpun (Umro),
#3061204500
Category: DLT
C. Demand Load: 1KW
Meter No.: 166901
OMI (Conn): 1
Total Tariff Diff: 791.26

Customer:

Secure Meter:

ent: 05-

Billing Details

Prev. Reading Date: 04/12/2024
Curr. Reading Date: 09/01/2025
No. of Days: 36
Bill Number: 2232005251090091
P/H Status: OK (Normal)
v KWH: 14131.0
Current KWH: 14732.0
Billed Unit: 601.0
Recorded MD: 0
Power Factor: 0
Average:

ASS

SS

0V/50Hz

Bill Charges

Fixed Charges (Unit, Rate, Amount)
1.0 KW 90.0 104.52
Energy Charges (Unit, Rate, Amount)
116.13 5.55 644.52
116.13 5.65 658.13
368.74 6.12 2256.70
ED Amount (Unit, Rate, Amount)
601.0 0.05 30.05
FPPAS -23.07
DPC 11.47
Current Bill Amt 3680.32
Prev Outstanding 1163.88
Adjustment 0.00
Tariff Diff (1/9 inst.) 87.92
Net Bill Amount 4932.12

Net Bill Amount: ₹ 4933.00
Due Date: 30/01/2025
Last Payment Date: 11/10/2024
Last Payment Amount: 6815

09/01/2025 12:15 V3.8

This bill will be construed as final notice under Section 9.2
MSERC (Electricity Supply Code) Regulations. If the bill is not paid within 15 (fifteen) days (notice date of the bill), electricity shall be disconnected at any date, if the bill is not paid within 15 (fifteen) days (notice date of the bill). Thanks for paying. We really appreciate your payment.



Net Bill Amount: (2/6 Inst.)
Net Bill Amount: (1/9 Inst.)

Net Bill Amount

AMOUNT IN WORDS

Due Date

Last Payment Date

Last Payment Amount

Sd-

Asst Executive Engineer
UMBAM SUBDIVISION

This Bill will be Construed as final notice under Section 9.2
bill is not paid within 15

The current bill includes the new tariff difference amount a

SECURE

ROUTINE TEST REPORT

Serial Number: SS17930698

Customer: R.K. TRADING CO.

Customer P.O Number: RKTC/RO/Secure Meters/2024-25/095

Customer P.O Date: 27-DEC-2024

Voltage: 240V

Current: 05-30A

Accuracy Class: 1.0

Ref. Standard: IS : 13779

Meter Constant: 6400

1. AC VOLTAGE TEST: PASS
2. TEST OF NO LOAD CONDITION: PASS
3. TEST OF STARTING CURRENT: PASS
4. INSULATION TEST: PASS
5. METER ACCURACY:-

Reference Conditions: $V_{ref} = 240V/50Hz$ $I_b = 05-30A$ Amb. Temp = 27 ± 2 Deg. C

METER ACCURACY


% Active Import Errors

Load % I_b	0.5 Lag	0.8 Lead	UPF
600	0.3	0.0	0.0
100	0.2	0.0	0.0
10	0.2	0.0	0.0
5			0.0

00001.0

TEST DATE: 26-02-2025

This is computer generated test report no signature required


Meter Tester Gr - I
MTI Laboratory
MePDCL, Lumjingshal
Shillong


Executive Engineer
MTI Division
MePDCL, Shillong