



MTI, Gate No. 1, Plot No. 324-330, KIADB Industrial Area, Hebbal-Hootagalli, Mysuru - 570 018.

TEST CERTIFICATE

ITEM : Single Phase Static Watthour Meter
METER SL NO. : U5680414
RATING : 5-30A, 240V, 50Hz
METER CLASS : 1.0
CONSTANT : 3200 Impulses per kWh
STANDARD : IS 13779

The Meter was tested & has passed following routine tests as per IS: 13779 at reference conditions:

	TEST	RESULT
01	No-Load Conditions	Passed
02	AC Voltage Test	Passed
03	Insulation Resistance Test	Passed
04	Starting Test	Passed
05	Meter Accuracy Test	Passed Meter Accuracy Observed within $\pm 1\%$

Initial Reading

00001

CERTIFIED


Signature:


Date:

30/07/2025

Meter Tester Gr - I
MTI Laboratory
MePDCL, Lumjingshai
Shillong

Executive Engineer
MTI Division
MePDCL Shillong



SEX	Male
DATE OF BIRTH/AGE : 26/08/1956	
ADDRESS:	
HNo.63, UMSAWLUM,	
VILL-UMSAWLUM,	
DIS :-RI-BHOI-793103	
	
Date:9-1-2017 Electoral Registration Officer	
Assembly Constituency No & Name	
11 - UMSNING	
Part No and Name :	
42 - UMSAWLUM	
नोट / Note :	
1. इस कार्ड को धारण करने मात्र से यह कोई गारंटी नहीं है कि आप वर्तमान निर्वाचक नामावली में निर्वाचक हैं। कृपया अपना नाम प्रत्येक चुनाव से पहले वर्तमान नामावली में जांच लें।	
More possession of this card is no guarantee that you are elector of the current electoral roll. Please check you name in the current electoral roll before every election	
2. इस कार्ड में उल्लिखित जनसंख्या को निर्वाचक नामावली में प्रतीक के अलावा अन्य किसी भी स्थिति में आयु के प्रमाण के रूप में नहीं माना जाएगा।	
Date of Birth mentioned in this card shall not be treated as a proof of age/D.O.B. for any purpose other than registration in electoral roll.	

145
KA DULIR AITI PATENG KHYNDEW

Mangi Ki Kmle ki Kpa kiba shong basah ha Umsaw Khwan
ngi la aiti pateng ia ka jaka jongngi kaba don ha
Umsaw Khwan haphi U khun jongngi U Shemphanglin Nongkse
ha kane ka sngi 3rd July, 1993. Ki pud sawdong jong kane
ka jaka ki long kumne harum:

Mihngi :- Ka iing bad jaka ka Enia Shylla.
Sepngi :- Ka jaka U Eklanstick Syiem
Shathie :- Ka iing ka Nodra Nongbsap
Shatei :- Ka jaka ka Sidrot Lyngdoh.

Naduh kane ka sngi ka 3rd July, 1993, katei ka jaka
kan long noh ka hok jongphi bad yn nym don mano mano ruh
ba lah ban deya halor jongka.

Ia kane ngi la leh hapteng ka jingkoit jingkhiah
bad jingtip briew bha hakmat jongphi ki khun kiba ia soi
kyrteng lang hangne harum.

Ki khun ba iadon
ryngkat ha kane
ka kam:

M. Mersha
1. (Ka Mersha Nongkse)

U. Amrose
2. (U Amrose Nongkse)

R. Rosabel
3. (U Rosabel Nongkse)

Nongaiti pateng:-

L. Shadap
(L. Shadap) 3/7/93
Kpa

Nages Lulida
(Ngestrida Nongkse)
Kmle

Nongshimti pateng:-

S. Shemphanglin
(Shemphanglin Nongkse)
Khun

Tarik:
3rd July, 1993.

DORBAR SHNONG UMSAWKHWAN

(Raid Mawbuh, Myllem Syiemship),
HQrs. UMSAWLUM, P.O. UMSAW - 793 123,
RI BHOI DISTRICT, MEGHALAYA.


Under Rule 10(3) of the Administration of Myllem Syiemship Rule 2015 of the East Khasi Hills Autonomous District. (Appointment and Succession of Syiem, Electors and Rangbah Shnong of Myllem Syiemship) Act, 2007.

Ref. No. UKVD/2024-25/

Dated Umsawlum,
The 23/9/2025

To whom it may concern.

This is to certify that the
Nonsawkhwan Village Dorbar has
no objection to Shri S. Nongkseh
for enhancement of load from
1kw to 3kw for his domestic use
for his house


23/9/25
(H. NONGKSEH)

Headman
Umsawkhwan Village Dorbar
P.O. Umsaw-793123.

I Type of wiring: *Looping in System*

III. Voltage and system of supply: *220 v / 1φ.*

IV Test results:

Date of Testing by Licensed Contractor

220925

Type of test	Result of test carried out by licensed contractor (In (MΩ)/Ω)	Result of test carried out by the supplier under relevant IE Rules in (MΩ)/Ω
a. Insulation resistance between earth and whole system of conductor	<i>40 mΩ</i>	
b. Insulation resistance between all conductors	<i>40 mΩ</i>	
c. Earth continuity between earth electrode and earth continuity conductor.	<i>5 mΩ</i>	
d. Polarity of non-linked SP switches.	<i>Phase -</i>	

V Full Name with signature of Licensed contractor :
LIC No:

S.S. Lyngdoh
S.S. Lyngdoh
Electrical Contractor
Regd. No. - 793

VI. Full Name with signature of supervisor
(With date)
LIC No:

S.S. Lyngdoh
S.S. Lyngdoh
Electrical Supervisor
Lic. No - 1046

VII Full Name with signature of wireman
(With date) :

PERMIT No:

S.S. Lyngdoh
5454

VIII Signature of the authorised official who tested
The Installation on behalf of supplier :

IX Date of connection of supply to the installation :

This is to certify that repaired/renewed/additional/new electric installation at the premises of

(Full Name)

(Full Name) SRI SEMPANG LIN MONG SEH

(Address) Umsa, P.O. Umsa-793123, R. 'Dro' Dist,
is duly completed, tested and is ready for your Engineer to test and connect on your main line.

1. The load has been arranged as follows;-

Note:

- Details of any apparatus (other than the above mentioned) should be given.
- Rating of capacitor used in Induction Motor and Welding Transformer (Test report of capacitor is to be enclosed)

KVAR

Provided that on the part of the Board notice shall be given to the consumer stating the reasons for the proposed termination and giving him opportunity to state his case and his statement, if any, duly considered before the agreement is terminated and the supply of electricity cut off;

- (7) That the terms and conditions of this Agreement shall be effective from the date supply of electricity is commenced.

IN WITNESS WHEREOF the parties hereto have set their hands and seals the date, month and year first above written.



(S. Norkser)

The Consumer

()

For and on behalf of the Board

Witnesses :-

1. Signature :

Name :

Address :

1. Signature :

Name :

Address :

AGREEMENT FOR SUPPLY OF ELEC LOW TENSION



AN AGREEMENT made this the 22nd day of Sept 2025
between Shomphanglin Nongkshel and his successors and assigns
(hereinafter referred to as the Consumer) of the One Part and The Meghalaya Energy Corporation Ltd.
an electricity distribution licensee under the Electricity Act, 2003 and its successors and assigns
(hereinafter referred to as the Board) of the Other Part.

Note : The term 'consumer includes an individual person (whether male or female), a body of persons, a company, society, firm, association or organization.

WHEREAS, the consumer has applied to the Board for supply of electricity to its premises and the Board has agreed to give the supply under the terms and conditions hereinafter appearing.

NOW, THEREFORE, the agreement witnesses -

- (1) That the supply shall be given to the premises located at Yonsaw
with the consumer as owner/occupier of;
- (2) That the supply be for the purpose of D/E, the load
whereof shall not exceed 2 (two) Kva watt(s);
- (3) That the provisions of the Electricity Act, 2003 and the Regulations, Code and Orders, including Tariff Orders, as may be made from time to time by the Meghalaya State Electricity Regulatory Commission shall apply and bind the consumer and the Board alike;
- (4) That the consumer shall regularly and timely pay to the Board all charges and may be due for the supply of electricity;
- (5) That the Agreement shall be for a period of two years and may be renewed for a further period:
Provided that supply shall not be terminated by mere efflux of time if the consumer is willing that the agreement is renewed;
- (6) That the Agreement shall be terminated if the consumer on its part desires it so and gives to the Board a prior notice of not less than one month or, on the part of the Board, if the consumer has violated any of the terms and conditions of the agreement;

Transformer = 100 KVA.
Slyngda

APPLICATION FORM OF PROVIDING LT SERVICE CONNECTION (FOR ALL CATEGORY AND FOR ALL PURPOSE)

To,

The Area Manager/Asstt. Executive Engineer
Service Connection Sub-Division/ Distribution Sub-Division
MeECL
(Indicate the local area of the jurisdiction of the Engineer of the licensee)

Sir,

1. I/We hereby request you to supply electricity to the premises located at the address more fully described below. I/We are the owner/lawful occupier of the premises.
2. I/We agree to abide by the terms and conditions relating to the supply of electricity by MeECL and to make all payments as may be required and also to pay regularly all charges as may become due.

3. a) Full name and address of the applicant with contact telephone number

SHRI SHEMPHANGLIN NONGKSEH
UMSAW, PO. UMSAW, D. BHOI DIST.
Tel. No. 93663-65079

- b) Status in relation to the premises

Owner

☒

Occupier

☐

- c) Location and address of the premises including Police Station.

- d) Nature of LT supply :

Commercial

☐

Domestic

☒

Industrial

☐

General Purpose

☐

WSLT

☐

PL

☐

Agriculture

☐

KJ

☐

Junior Engineer
Umiam Distribution Sub Division-I
Me. P.D.C.L. Umiam

Date :

Applicant's Signature

N.B. : The following documents are to be enclosed :

- 1) Test Report from Licensed contractor.
- 2) Agreement Form duly filled in.
- 3) Proof of ownership (in case applicant is owner).
- 4) Number of nearest Electric Pole.
- 5) NOC of the owner of the premises (in case the application is an occupier).
- 6) Attested copy of permission obtained from Pollution Control Board.
- 7) Building permission from the concerned authority.

1453

NEW CONSUMER APPLICATION FORM

☐ If Consumer Apply for Sub-Meter/ Additional Connection
(Please tick on the check box)



Personal Details

* Application No

* Consumer Name

* Father's Name

* Mobile No

* Aadhaar / EPIC No

Shemphangin Wongkesh

L. Shadap

93663 650

Email -

DHJO 52/666

Address Details

* Accommodation

* Discom

* Zone

* Sub-Division

* Village Name

* State

* Area Pin Code

* Full Address

- ☒ Own / ☐ Rented (Pl. tick one)

- Meghalaya Power Distribution Corporation

- Eastern Zone * Circle - Ribhoi Circle * Division - Umiam Division

- Umiam Distribution Sub Division

- Umsaw

- Meghalaya * City - Ribhoi (Nongpoh)

793123

Locality

New Connection Details

* Consumer Type: SG / CG / NG (Pl. tick one)

* Urban/Rural Type: Rural / Urban (Pl. tick one)

* Activity

- Domestic Purpose (House)

* Contract Load Unit

- KW / KVA (Pl. tick one) * Contract Load: 2 kw

* Category

- DLT * Product Type: LT / HT (Pl. tick one)

* Scheme

- All Categories excluding industrial / Industrial / Free Scheme /
Saubhagya/ DOUGJY (Pl. tick one)

Other Details

* Meter Number

* Initial KWH-

* Initial KVAH -

* Meter MF

Meter Owned - Utility / Consumer (Pl. tick one)

* Phase

- 1 Phase / 3 Phase (Pl. tick one) * TMC - Yes / No (Pl. tick one)

* Meter Reader

Group No. -

List of Documents to be attach: