

# ROUTINE TEST REPORT

Serial Number: 8817223723

Customer: R.K. TRADING CO.

Customer E.O Number: RKTC/PO/Secure Meters/2023 - 24/011

Customer F.O Date: 27-JUN-2023

Voltage: 240V

Current: 05-30A

Ref. Standard: IS : 13779

Accuracy Class: 1.0

Meter Constant: 6400

1. AC VOLTAGE TEST: PASS
2. TEST OF NO LOAD CONDITION: PASS
3. TEST OF STARTING CURRENT: PASS
4. INSULATION TEST: PASS
5. METER ACCURACY:-

Reference Conditions:  $V_{ref} = 240V/50Hz$   $I_b = 05-30A$   $Amb. Temp = 27 \pm 2^\circ C$

## METER ACCURACY

### % Active Import Errors

| Load % $I_b$ | 0.5 Lag | 0.8 Lead | UPF |
|--------------|---------|----------|-----|
| 600          | 0.3     | 0.0      | 0.0 |
| 100          | 0.1     | 0.0      | 0.0 |
| 10           | 0.1     | 0.0      | 0.0 |
| 5            |         |          | 0.0 |

00001.0

TEST DATE: 22/09/2023

This is computer generated test report no signature required.

  
Meter Tester Gr - I  
MTI Laboratory  
MePDCL, Lumjingsha  
Shillong

  
(Y. Passah)  
Assistant Engineer  
MTI Lab  
MePDCL, Shillong