

Commissioning and Installation Report of New HT-CT Metering Unit at the Premises of M/S MIDAS PAVERS BLOCK, 8TH MILE BARIQUA, RIBHOI DISTRICT

Date of Installation of 11KV CT-PT Unit: 13-11-2024

Date of Installation of Meter: 13-11-2024

DATE OF INSTALLATION OF METER: 20-11-2024																				
Sl. No.	Name of Consumer	Address	Supply Voltage (KV)	CT-PT Specification			CT Ratio Selected	Meter No. & Specification	Meter Ratio	O.M.F	INITIAL READINGS (13.11.2024 @ 16:01 HRS)						S/M Card Details	Seal Number	Remarks	
				Parameter	CT	PT					KWH	KVAH	KW or KVA	R-N (V)	T-N (V)	B-N (V)				
1	M/S MIDAS PAVERS BLOCK	8TH MILE BARIQUA	11	Serial No.	68305			Meter No.: MSS000110 Class: 0.5S, -/5A, Ib=5A, Imax=2xIb 3x415V/√3/110/√3V 16000Pulses/Unit (KWh, KVAh, KVAh) 50Hz Make: HPL Electric & Power Ltd make Type: HST152 Smart Meter Phase Sequence: Forward	30/5A	100	6	0.00	0.00	0.00	62	61	61	Auto) SG Plus, S/M No. 0423 ID 889116099002 4336C5AU M1	CT-PT Secondary JB Sail: 0050493/SC495 UT/TTB/Sum Card 4085310/0.0090500/40 M311 Meter Box 0050493/493	Metering Unit Confirms to Standard Metering Practice and ready for Billing purpose. Overall M.F=6

Note: O.M.F: 6 (KWh, KVAh, KVA)

[Signature]
13/11/2024

Asst. Executive Engineer

Investigation & Enforcement Sub Division

Ribhoi (D) Circle, Meppet, Lumbini