

ROUTINE TEST REPORT

Serial Number: SS17948389

Customer: M/S MAMTA ELECTRICALS

Customer P.O Number: MAMTA/23-24/017

Customer P.O Date: 16-DEC-2024

Voltage: 240V

Current: 05-30A

Ref. Standard: IS : 13779

Accuracy Class: 1.0

Meter Constant: 6400

- 1. AC VOLTAGE TEST: PASS
- 2. TEST OF NO LOAD CONDITION: PASS
- 3. TEST OF STARTING CURRENT: PASS
- 4. INSULATION TEST: PASS
- 5. METER ACCURACY:-

Reference Conditions: Vref = 240V/50Hz Ib = 05-30A Amb. Temp = 27 +/- 2 Deg. C

METER ACCURACY


% Active Import Errors

| Load % Ib | 0.5 Lag | 0.8 Lead | UPF |
|-----------|---------|----------|-----|
| 600       | 0.3     | 0.0      | 0.0 |
| 100       | 0.1     | 0.0      | 0.0 |
| 10        | 0.1     | 0.0      | 0.0 |
| 5         |         |          | 0.0 |

00001.0

TEST DATE: 06/03/2025

This is computer generated test report no signature required

  
 Meter Tester Gr - 1  
 MTI Laboratory  
 MePDCL, Lumjingshal  
 Shillong

  
 Executive Engineer  
 MTI Division  
 MePDCL, Shillong