

SCHNEIDER ELECTRIC INDIA PRIVATE LIMITED

MPS, Gate No.1, Plot No.324-330, KIADB Industrial Area, Hebbal-Hootagalli, Mysuru - 570 018.

TEST CERTIFICATE

ITEM : Single Phase Static Watthour Meter
METER SL NO. : A8258067
RATING : 5-30A, 240V, 50Hz
METER CLASS : 1.0
CONSTANT : 3200 Impulses per kWh
STANDARD : IS 13779

The Meter was tested & has passed following routine tests as per IS: 13779 at reference conditions:

| | TEST | RESULT |
|----|----------------------------|---|
| 01 | No-Load Conditions | Passed |
| 02 | AC Voltage Test | Passed |
| 03 | Insulation Resistance Test | Passed |
| 04 | Starting Test | Passed |
| 05 | Meter Accuracy Test | Passed Meter Accuracy Observed within $\pm 1\%$ |

Initial Reading

00001
0.00

CERTIFIED

Signature:

Date: 27/01/2024

MePDCL
Meter Tester Gr - I
MTI Laboratory
MePDCL, Lumjingshal
Shillong

Executive Engineer
MTI Division
MePDCL, Shillong