

SCHNEIDER ELECTRIC INDIA PRIVATE LIMITED

MPS, Gate No 1, Plot No. 324-130, KIADB Industrial Area, Hebbal-Hootagalli, Mysuru - 570 018.

TEST CERTIFICATE

ITEM : Single Phase Static Watthour Meter
METER SL NO. : A7652146
RATING : 5-30A, 240V, 50Hz
METER CLASS : 1.0
CONSTANT : 3200 Impulses per kWh
STANDARD : IS 13779

The Meter was tested & has passed following routine tests as per IS: 13779 at reference conditions:

	TEST	RESULT
01	No-Load Conditions	Passed
02	AC Voltage Test	Passed
03	Insulation Resistance Test	Passed
04	Starting Test	Passed
05	Meter Accuracy Test	Passed Meter Accuracy Observed within $\pm 1\%$

Initial Reading

000001

CERTIFIED

Signature:

Date: 25/09/2023

Meter Tester Gr - I
MTI Laboratory
MePDCL, Lumjingshal
Shillong

(Y. Passah)
Assistant Engineer
MTI Lab
MePDCL, Shillong.