



SCHNEIDER ELECTRIC INDIA PRIVATE LIMITED

MPS, Gate No 1 Plot No 324 330, KIADB Industrial Area, Hebbal-Hootagali, Mysuru - 570 013

TEST CERTIFICATE

ITEM : Single Phase Static Watthour Meter
METER SI NO. : A9206660
RATING : 5-30A, 240V, 50Hz
METER CLASS : 1.0
CONSTANT : 3200 Impulses per kWh
STANDARD : IS 13779

The Meter was tested & has passed following routine tests as per
IS: 13779 at reference conditions:

	TEST	RESULT
01	No-Load Conditions	Passed
02	AC Voltage Test	Passed
03	Insulation Resistance Test	Passed
04	Starting Test	Passed
05	Meter Accuracy Test	Passed Meter Accuracy Observed within $\pm 1\%$

Initial Reading

00001

CERTIFIED

Signature

Date: 26/08/2024

Meter Tester Gr - I
MTI Laboratory
MePDCL, Lumjingshal
Shillong

Executive Engineer
MTI Division
MePDCL, Shillong