

# SECURE

## ROUTINE TEST REPORT

Serial Number: **SS17288932** Customer: **M/S MAMTA ELECTRICALS**  
Customer P.O Number: **MAMTA/23-24/005**  
Customer P.O Date: **21-SEP-2023**  
Voltage: **240V** Current: **05-30A** Accuracy Class: **1.0**  
Ref. Standard: **IS : 13779**  
Meter Constant: **6400**

1. AC VOLTAGE TEST: **PASS**
2. TEST OF NO LOAD CONDITION: **PASS**
3. TEST OF STARTING CURRENT: **PASS**
4. INSULATION TEST: **PASS**
5. METER ACCURACY:-

Reference Conditions:  $V_{ref} = 240V/50Hz$   $I_b = 05-30A$   $Amb. Temp = 27 +/- 2 Deg. C$

### METER ACCURACY


% Active Import Errors

Load % $I_b$	0.5 Lag	0.8 Lead	UPF
600	0.3	0.0	0.0
100	0.1	0.0	0.0
10	0.1	0.0	0.0
5			0.0

00001.0

TEST DATE: 29/11/2023

This is computer generated test report no signature required

  
Meter Tester Gr - 1  
MTI Laboratory  
MePDCL, Lumjingshai  
Shillong

  
Executive Engineer  
MTI Division  
MeFDCL, Shillong