

2736  
**NEW CONSUMER APPLICATION FORM**

If Consumer Apply for Sub-Meter/ Additional Connection  
 (Please tick on the check box)



**Personal Details**

\* Application No. \_\_\_\_\_  
 \* Consumer Name Kweelly Syti  
Husband's Name Garatis Bamen  
 \* Mobile No. 8882567514 Email \_\_\_\_\_  
 Aadhar / EPIC No. DWN0612903

**Address Details**

\* Accommodation Own / Rented (Pl. tick one)  
 \* Discom Meghalaya Power Distribution Corporation  
 \* Zone Eastern Zone \* Circle Ribhoi Circle \* Division Umiam Division  
 \* Sub-Division Umiam Rural Distribution Sub-Division  
 \* Village Name Umrei Jaian Pedeng  
 \* State Meghalaya \* City Ribhoi (Nongpoh)  
 \* Area Pin Code 793103 Locality Umrei Jaian Pedeng  
 \* Full Address Umrei Jaian Pedeng

**New Connection Details**

\* Consumer Type SG / CG / NG (Pl. tick one) \* Urban/Rural Type Rural / Urban (Pl. tick one)  
 \* Activity House  
 \* Contract Load Unit KW / KVA (Pl. tick one) \* Contract Load 2KW  
 \* Category Domestic \* Product Type LT / HT (Pl. tick one)  
 \* Scheme All Categories excluding industrial / Industrial / Free Scheme / Saubhagya/ DDUGJY (Pl. tick one)

**Other Details**

\* Meter Number \_\_\_\_\_ \* Initial KWH \_\_\_\_\_ \* Initial KVAH \_\_\_\_\_  
 \* Meter MF \_\_\_\_\_ Meter Owned - Utility / Consumer (Pl. tick one)  
 \* Phase 1 Phase / 3 Phase (Pl. tick one) \* TMC - Yes / No (Pl. tick one)  
 Meter Reader \_\_\_\_\_ Group No \_\_\_\_\_

**List of Documents to be attach:**

- \* Test Report
- \* Ownership Proof
- \* Identity Proof
- \* Meter Test Report
- Landlord NOC
- Agreement Fill
- Pollution Control Board
- \_\_\_\_\_ mandatory

*Key Don*  
*for n/a*  
*ASJ*  
 Assistant Executive Engineer  
 Umiam Rural Distribution Sub-Division  
 M.P.D.C. Umiam  
 Date of Connection: \_\_\_\_\_

100KVA Substation

APPLICATION FORM FOR PROVIDING LT SERVICE CONNECTION  
(FOR ALL CATEGORY AND FOR ALL PURPOSE)

To The Area Manager / Asst Executive Engineer  
Service Connection Sub-Division / UR Distribution Sub-Division  
Me/CL Umiam  
(Indicate the local area of the jurisdiction of the Engineer of the licensee)

- Sir,
- I / We hereby request you to supply electricity to the premises located at the address fully described below. I/We are the owner / lawful occupier of the premises.
  - I/We agree to abide by the terms and condition relating to the supply of electricity by Me/CL and to make all payments as may be required and also to pay regularly all the charges as may become due.
  - a) Full name and address of the applicant with contact telephone number. 3882567514

Kwality Spts

- b) Status in relation to the premises:
- Owner
- Occupier

c) Location and address of the premises including Police Station.

Umroi Jaiam Pdemg

- d) Nature of LT Supply:
- |             |                          |                 |                                     |
|-------------|--------------------------|-----------------|-------------------------------------|
| Commercial  | <input type="checkbox"/> | Domestic        | <input checked="" type="checkbox"/> |
| Industrial  | <input type="checkbox"/> | General Purpose | <input type="checkbox"/>            |
| WSLT        | <input type="checkbox"/> | PL              | <input type="checkbox"/>            |
| Agriculture | <input type="checkbox"/> | KJ              | <input type="checkbox"/>            |

2kw Load Sanction from Umroi Jaiam Pdemg 100 KVA S/S

Date 15/4/25  
A  
 Junior Engineer  
 Umiam Rural Distribution Sub-Division  
 Me/POCL, Umiam

K. S. S. S.  
Applicant's Signature

NB: The following documents are to be enclosed:

- 1) Test Report from Licensed contractor.
- 2) Agreement Form duly filled in.
- 3) Proof of ownership (in case the applicant is owner).
- 4) Number of the nearest Electric Pole.
- 5) NOC of the owner of the premises (in case the applicant is occupier).
- 6) Attested copy of permission obtained from Pollution Control Board.
- 7) Building permission from the concerned authority.

Agreement for supply of electricity Low Tension



An agreement made this the \_\_\_ day of \_\_\_ of 20\_\_ between \_\_\_ and his successor and assigns (hereinafter referred to as the consumer) of the one part and the Meghalaya Power Distribution Corporation Limited an electricity distribution licensee under the EA, 2003 and its successors and assigns (hereinafter referred to as the Distribution Utility / MePDCL) of the other part

Note: the term 'consumer' includes an individual person (whether male or female), a body of persons, a company, society, firm, association or organisation.

Whereas, the consumer has applied to the distribution utility for supply of electricity to the premises and the distribution utility has agreed to give the supply under the terms and conditions hereinafter appearing;

Now, therefore, the agreement witness –

- (1) That the supply shall be given to the premises located at Umhai JP with the consumer as owner / occupier of;
- (2) That the supply shall be for the purpose of Domestic  
The load whereof shall not exceed 2000 watts
- (3) That the provisions of the EA 2003 and the regulations, code and orders including tariff orders, as may be made from time to time by the MSERC shall apply and bind the consumers and the distribution utility alike;
- (4) That the consumer shall regularly and timely pay to MePDCL all charges as may be due for the supply of electricity;
- (5) That the agreement shall be a period of two years and may be renewed for a further period;  
Provided that supply shall not be terminated by mere efflux of time if the consumer is willing that the agreement is renewed;
- (6) That the agreement shall be terminated if he consumer on its part desires it so and gives to the MePDCL a prior notice of not less than one month or, on the part of the MePDCL, if the consumer has violated any of the terms and conditions of the agreement.

noted

Provided that on the part of the MePDCL notice shall be given to the consumer stating the reasons for the proposed termination and giving him opportunity to state his case and his statement, if any duly considered before the agreement is terminated and the supply of electricity cut off.

(7) The terms and conditions of this agreement shall be effective from the date of supply of electricity is commenced.

IN WITNESS WHEREOF the parties hereto have set their hands and seals the date, month and year first above written.

*K. S. ...*

Consumer

For and behalf of MePDCL.

Witness:

1. Signature:

Name:

Address:

2. Signature:

Name:

Address:

is to  
K  
C

100kVA Substation

Form 7

Meghalaya Power Distribution Corporation Limited  
Test Report

*[Signature]*

This is to certify that repaired/renewed/additional/new electric installation at the premises of

Full name  
K W E L T Y S Y R T I

(Please leave one block between name & surname)

Address  
U M R O I J A I A W P D E N G

1. The load has been arranged as follows:

Details of load	Wattage of each item	Phase I		Phase II		Phase III		Total wattage of all 3 phases
		No. of points	Total wattage	No. of points	Total wattage	No. of points	Total wattage	
1. Light points								
(i) Fluorescent								
(ii) Incandescent								
(iii) CFL								
(iv) Halogen								
(v) Others / LED	9W	7No	63W					
2. Fan points								
3. Plug points (3-Pin)								
(i) 6 Amps	100W	6Nos	600W					
(ii) 16 Amps	1000W	1No	1000W					
4. Electrical gadgets								
(i) Water Heater (Geyser)								
(ii) Refrigerator								
(iii) AC								
(iv) Others								
5. Welding transformer								
6. Motor								
Total			1663W					
In case of load enhancement existing load (in watts)								
Total load in the premises (in watts)			2KW					

Notes:

- (a) Details of any apparatus (other than the above mentioned) should be given.
- (b) Rating of capacitor used in induction Motor and welding Transformer (Test report of capacitor is to be enclosed)

KVAR

ii. Type of wiring

iii. Voltage and system of supply

iv. Test Result *OK*

Date of testing by licensed contractor

*Callie Coffey*  
*220 V*

1 4 0 4 2 5

	Type of test	Result of test carried out by licensed contractor (in MΩ) / Ω	Result of test carried out by the supplier under relevant Cea regulations, (in MΩ) / Ω
(a)	Insulation resistance between earth and whole system of conductor.	110 MΩ	
(b)	Insulation resistance between all conductors	107 MΩ	
(c)	Earth continuity between earth electrode and earth continuity conductor	3 V	
(d)	Polarity of non-linked SP switches	0 MΩ (PN-220V) EN-0.2V	

v. Full name with signature of licensed contractor (with date)

LIC No.

Mobile No.

*Ms. R. D. Electrical*  
ovt. Electrical Contractor  
LIC No : 381

vi. Full name with signature of supervisor (with date)

LIC No.

Mobile No.

*Mr. R. Dohdong*  
Electrical Supervisor  
Regd No: 459

vii. Full name with signature of wireman (with date)

LIC No.

Mobile No.

*Mr. R. Dohdong*  
Electrical Wireman  
Regd No - 2126

viii. Signature of the authorized official who tested the installation on behalf of supplier (with date)

Mobile No.

ix. Date of connection of supply to the installation



# DORBAR SHNONG UMROI JAI AW PDENG

Raid Mawbuh Myllem Syiemship  
Ri-Bhoi District  
Meghalaya - 793116

Under rule 10(3) of the administration of Myllem Syiemship rules, 2015 of the Khasi Hills Autonomous District (Appointment and Succession of Syiem, Deputy Syiem, Electors and Rangbah Shnong of Myllem Syiemship) Act 2007

Ref No. DSUJP/2023-24

Date: 01-07-2023

## KA DULIR IA SHIM BAD IA AI SIEW KHYNDEW

Nga U/Ka GRATIS RAMUN khun jong U/Ka S. Lalani  
ba shong ba sah ha Mechapad East Jaintia Hill  
Myllem Syiemship nga ai siew noh ha phi U/Ka KWEITY SYPTI  
khun jong U/Ka (L) I. Sutnga ba shong ba sah ha  
Mechapad East Jaintia Hill mynta ka sngi 1<sup>st</sup> July, 2023 ia ka jaka jong nga ka  
ba don ha Umroi Jaiaw Pdeng Shnong, Raid Mawbuh Myllem Syiemship, bad ka ba don hapoti kine ki  
sawdong pud :

Mihngi	:	<u>Takhop ka surak madan jethball - 731b</u>
Sepngi	:	<u>Takhop ka surak pwo - 611b</u>
Shatei	:	<u>Takhop ka surak shnong - 511b</u>
Shathie	:	<u>Takhop ka surak pwo - 171b</u>
Total Area	:	<u>2,978 sqft (As per map of myllem phou phou)</u>

Nga la leh ia kane hapdeng ka jingkoit jingkhiah bad jingtip briew bha, bad da la ka mon  
sngewbha khlem da don mano mano ba pynbor ia nga. Nga ai siew noh ha phi ia katei ka jaka ha ka dor  
Rs 5500000 (Pephew san lakh lakh)  
kumta naduh mynta ka sngi phin dakhoh noh maphi ia kane ka jaka kat kum ki riti dustur jong ka Shnong.  
Lada don mano mano ba uyor kan long halor ka jingkitkhlieh jong U/Ka nongaisiew.

Dated: Umroi Jaiaw Pdeng shnong  
The: 01-07-2023

Cy Bawon  
Nongdie

Sakhi:

[Signature]  
P. N. Nengnong  
Rangbah Shnong  
Umroi Jaiaw  
Pdengshnong

1.

[Signature]  
M. P. P. Lyngdoh  
Secretary  
Dorbar Shnong

[Signature]  
Nongthled

Umroi Jaiaw Pdeng Shnong



UNDAM RURAL DIST  
SUBDIVISION  
1000197935  
2231015

State Bank Of India  
C/O Kvelty Svrti, Umroi JP  
CLT  
15KV/  
767566

Consumer ID  
Mtr Code  
Consumer Name  
Address  
Category  
C Demand Load  
Meter No  
G.M.F.(Cans)

Billing Cycle 17/08/2024  
Prev. Reading Date 14/10/2024  
Curr. Reading Date 58  
No. of Days 223101524A140051  
Bill Number OK(Normal)  
Bill Status 14308.0  
Prev KWH 14325.0  
Current KWH 17.0  
Billed Unit 0  
Recorded MD 0  
Power Factor 0  
Average

Bill Charges

Fixed Charges (Unit, Rate, Amount)  
15.0 KW 140.0 3993.44  
Energy Charges (Unit, Rate, Amount)  
17.0 5.7 113.90  
ED Amount (Unit, Rate, Amount)  
17.0 0.06 1.02  
FPPAS 0.00  
DPC 36.39  
Current Bill Amt 4144.75  
Prev Outstanding 1819.64  
Adjustment 0.00  
Gross Bill Amount 5964.39

Net Bill Amount ₹ 5965.00  
Due Date 28/10/2024  
Last Payment Date 05/08/2024  
Last Payment Amount 74375

14/10/2024 12:50 V3.1

This bill will be construed as final notice under Section 8.2 of  
MSEFC (Electricity Supply Code) Regulations, 2018. Supply  
of electricity shall be disconnected at any date, if dues of  
Electricity bill is not paid within 15 (fifteen) days (in case  
period) after due date of the bill. Thanks for paying. We really  
appreciate it!



For Bill Payments, Please visit [www.meghajerpower.com](http://www.meghajerpower.com) OR  
Download Megha Power App from Google Playstore

N  
\*C  
\*A  
\*C  
\*C  
\*Sc

Serial Number: 8817919080

Customer: M/S MAMTA ELECTRICALS

Customer P.O Number: MAMTA/23-24/017

Customer P.O Date: 16-DEC-2024

Voltage: 240V

Current: 05-30A

Accuracy Class: 1.5

Ref. Standard: IS : 13779

Meter Constant: 6400

1. AC VOLTAGE TEST: PASS
2. TEST OF NO LOAD CONDITION: PASS
3. TEST OF STARTING CURRENT: PASS
4. INSULATION TEST: PASS
5. METER ACCURACY:-

Reference Conditions:  $V_{ref} = 240V/50Hz$   $I_b = 05-30A$  Amb. Temp =  $27 \pm 2$  Deg. C

### METER ACCURACY


#### % Active Import Errors


Load & $I_b$	0.5 lag	0.8 Lead	OFF
600	0.3	0.0	0.0
100	0.1	0.0	0.0
10	0.1	0.0	0.0
5			0.0

00001.0

TEST DATE: 19/02/2025

This is computer generated test report no signature required

  
Meter Tester (Gr - 1)  
MTI Laboratory  
MePDCL, Lumjingshal  
Shillong

  
Executive Engineer  
MTI Division  
MePDCL, Shillong