

NEW CONSUMER APPLICATION RM

☒ If Consumer Apply for Sub Meter/ Additional Connection
(Please tick appropriate box)

Personal Details

*Appl. No. _____
*Consumer Name Baphinda burom Shylla
*Father's Name _____
*Mobile No. 7628853908 Email _____
*Adhaar / EPIC No. 5632 2665 3121

Paste
Photo
Here

Address Details

*Accommodation ☒ Own / ☐ Rented (Pl. tick one)
*District Meghalaya Power Distribution Corporation
*Zone Eastern Zone *Circle Ribhoi Circle *Division Umiam Division
*Sub-Division Umiam Distribution Sub-Division
*Village Name Umkir
*State Meghalaya *City Ribhoi (Nongpoh)
*Area Pin code 793122 Locality _____
*Full Address Umkir

New Connection Details

*Consumer Type SG / CG / NG (Pl. tick one) *Urban/Rural Type Rural / Urban (Pl. tick one)
*Activity _____
*Contract Load (kW / KVA) (Pl. tick one) *Contract Load 1+1+1+1
*Category DLT *Product Type LT / HT (Pl. tick one)
*Scheme All Categories excluding industrial / Industrial / Free Scheme /
Saubhagya / DDUGJY (Pl. tick one)

Other Details

*Meter Number SS17260427 + SS17260428 + SS17260427 + SS17260426 *Initial KWH _____ *Initial KVAH _____
*Meter MF _____ Meter Owned - Utility / Consumer (Pl. tick one)
*Phase 1 Phase / 3 Phase (Pl. tick one) *TMC - Yes / No (Pl. tick one)
Meter Reader _____ Group No. _____

List of Documents to be attach:

- *Test Report
- *Ownership Proof
- *Identity Proof
- *Meter Test Report
- *Landlord NOC
- *Agreement Fill
- *Pollution Control Board

All fields mark with * are mandatory

Date of Connection _____

Additional meter 4

4M-M.D. Nongphlang
X-Mer-200 kVA

APPLICATION FORM FOR PROVIDING LT SERVICE CONNECTION
(FOR ALL CATEGORY AND FOR ALL PURPOSE)

To

The Area Manager / Asst Executive Engineer
Service Connection Sub-Division/ Distribution Sub-Division
MeECL

(Indicate the local area of the jurisdiction of the Engineer of the licensee)

Sir,

1. I / We hereby request you to supply electricity to the premises located at the address fully described below. I/We are the owner / lawful occupier of the premises.
2. I/We agree to abide by the terms and condition relating to the supply of electricity by MeECL and to make all payments as may be required and also to pay regularly all the charges as may become due.
3. a) Full name and address of the applicant with contact telephone number.

Baphindaburam Skylla

b) Status in relation to the premises. Owner ☒

umbir Occupier ☐

c) Location and address of the premises including Police Station.

d) Nature of LT Supply: Commercial ☐

Domestic ☒

Industrial ☐

General Purpose ☐

WSLT ☐

PL ☐

Agriculture ☐

KI ☐

1+1+1+1 lead sanctioned for
Addl/mtr from 200 kVA Umbir & Co

Junior Engineer
Umlam Distribution Sub Division-I
Date: 11/4/15
Me. P.D.C.L. Umlam

Applicant's Signature

NB : The following documents are to be enclosed:

- 1) Test Report from Licensed contractor.
- 2) Agreement Form duly filled in.
- 3) Proof of ownership (in case the applicant is owner)
- 4) Number of the nearest Electric Pole.
- 5) NOC of the owner of the premises (in case the applicant is occupier).
- 6) Attested copy of permission obtained from Pollution Control Board.
- 7) Building permission from the concerned authority.

Smt E Susangi please do
take necessary actions
11/4/15
Junior Engineer
Umlam Distribution Sub Division-I
Me. P.D.C.L. Umlam

ROUTINE TEST REPORT

Meter Number: RH17260427
 Customer P.O. Number: RKTC/PO/Secure Meters/2023 - 24/011
 Customer P.O. Date: 27-JUN-2023
 Voltage: 240V
 Current: 05-30A
 Ref. Standard: IS : 13779
 Accuracy Class: 1.0
 Meter Constant: 6400

1. AC VOLTAGE TEST: PASS
2. TEST OF NO LOAD CONDITION: PASS
3. TEST OF STARTING CURRENT: PASS
4. INSULATION TEST: PASS
5. METER ACCURACY:-

Reference Conditions: $V_{ref} = 240V/50Hz$ $I_b = 05-30A$ Amb. Temp = 27 ± 2 Deg. C

METER ACCURACY

% Active Import Errors

Load % I_b	0.5 Lag	0.8 Lead	UPF
600	-0.2	0.0	0.0
100	0.0	0.0	0.0
10	0.0	0.0	0.0
5			0.0

000010

TEST DATE: 31/10/2023

This is computer generated test report no signature required

MTI Laboratory
 MePDCL, Lumjingshai
 Shillong

Executive Engineer
 MTI Division
 MePDCL, Shillong