

SECURE

ROUTINE TEST REPORT

Serial Number: **SS17289585**

Customer: **M/S MAMTA ELECTRICALS**

Customer P.O Number: **MAMTA/23-24/005**

Customer P.O Date: **21-SEP-2023**

Voltage: **240V**

Current: **05-30A**

Accuracy Class: **1.0**

Ref. Standard: **IS : 13779**

Meter Constant: **6400**

1. AC VOLTAGE TEST: **PASS**
2. TEST OF NO LOAD CONDITION: **PASS**
3. TEST OF STARTING CURRENT: **PASS**
4. INSULATION TEST: **PASS**
5. METER ACCURACY:-

Reference Conditions: $V_{ref} = 240V/50Hz$ $I_b = 05-30A$ Amb. Temp = 27 ± 2 Deg. C

METER ACCURACY

% Active Import Errors

| Load % I_b | 0.5 Lag | 0.8 Lead | UPF |
|--------------|---------|----------|------|
| 600 | 0.2 | -0.1 | -0.1 |
| 100 | 0.0 | 0.0 | 0.0 |
| 10 | 0.0 | 0.0 | 0.0 |
| 5 | | | 0.0 |

00001.0

TEST DATE: 30/11/2023

This is computer generated test report no signature required

M. K. S.
Meter Tester Gr - I
MTI Laboratory
MePDCL, Lumjingshai
Shillong

[Signature]
Executive Engineer
MTI Division
MePDCL, Shillong