

SECURE

No-2

ROUTINE TEST REPORT

Serial Number: SS17270492

Customer: M/S MAMTA ELECTRICALS

Customer P.O Number: MAMTA/23-24/005

Customer P.O Date: 21-SEP-2023

Voltage: 240V

Current: 05-30A

Accuracy Class: 1.0

Ref. Standard: IS : 13779

Meter Constant: 6400

1. AC VOLTAGE TEST: PASS
2. TEST OF NO LOAD CONDITION: PASS
3. TEST OF STARTING CURRENT: PASS
4. INSULATION TEST: PASS
5. METER ACCURACY:-

Reference Conditions: Vref = 240V/50Hz Ib = 05-30A Amb. Temp = 27 +/- 2 Deg. C

METER ACCURACY


% Active Import Errors

Load % Ib	0.5 Lag	0.8 Lead	UPF
600	0.4	0.0	0.0
100	0.2	0.0	0.0
10	0.2	0.0	0.0
5			0.0

00001.0

TEST DATE: 11/11/2023

This is computer generated test report no signature required


Meter Tester Gr - 1
MTI Laboratory
MePDCL, Lumjingshai
Shillong


(Y. Passah)
Assistant Engineer
MTI Lab
MePDCL Shillong