



ISO: 9001: 2015. & ISO 14001: 2015.

HPL Electric & Power Ltd.

TEST CERTIFICATE

ITEM : Single Phase Static Watthour Meter

METER SL. NO. : 965094

RATING : 5-30A 240V, 50Hz

CLASS
METER : 1.0

CONSTANT : 6400 Impulses per kWh

STANDARD : IS 13779 :1999

The Meter was tested & has passed following routine tests as per
IS: 13779 at reference conditions:

	TEST	RESULT
01	No-Load Conditions	Passed
02	AC Voltage Test	Passed
03	Insulation Resistance Test	Passed
04	Starting Test	Passed
05	Meter Accuracy Test	Passed Meter Accuracy Observed within $\pm 1\%$

Initial Reading


000001

CERTIFIED

Signature: 

Date: 19/11/2022


Meter Tester Gr - I
MTI Laboratory
MePDCL, Lumjingshal
Shillong


(Y. Passah)
Assistant Engineer
MTI Lab
MePDCL, Shillong.