

SS22110007

Customer: M/S MAMTA ELECTRICALS

Number: Mamta /SML/25-26/02

Date: 12-MAY-2025

V: 240V

Current: 10-100A

Accuracy Class: 1.0

Standard: IS : 13779

Turn Constant: 1600

AC VOLTAGE TEST: PASS

TEST OF NO LOAD CONDITION: PASS

TEST OF STARTING CURRENT: PASS

INSULATION TEST: PASS

METER ACCURACY:-

Reference Conditions: Vref = 240V/50Hz Ib = 10-100A Amb. Temp = 27 +/- 2 Deg. C

METER ACCURACY

Active Errors [Import]


% Reactive Errors [Import]

Load % Ib	0.5 Lag	0.8 Lead	UPF
1000	0.0	0.0	0.0
100	0.0	0.1	0.1
10	0.1	0.0	0.0
5			0.0

Load % Ib	0.5 Lag	0.8 Lead
1000	0.0	0.0
100	0.1	0.1
10	0.0	0.0

0.00004.0


Meter Tester Gr - I
MTI Laboratory
MPPDCL, Lumjingshai
Chitwan


Executive Engineer
MTI Division
MPPDCL, Shilong