

even to the consumer state
to state his case and
supply of electricity

Schedule 1 Form No. 7.

MEGHALAYA ENERGY CORPORATION LTD

TEST REPORT.

This is to certify that repaired/renewed/additional/new electric installation at the premises of

S D O (P H E) E L E C T R I C A N S u b : D i v i s i o n

(Please leave one block between name & surname)

(Full name)

U N I T # 1 L U M K H Y R I E M W S S

(Address)

is duly completed, tested and is ready for your Engineer to test and connect on your main line.

1. The load has been arranged as follows :-

Details of Load	Wattage of each item	Phasi - 1		Phasi - 2		Phasi - 3		Total Watt of all 3 phases
1. Light Points (i) Fluorescent (ii) Incandescent (iii) CFL (iv) Halogen (v) Others LED	50	50x2 =	100					
2. Fan Points	20	20x6 =	120					
3. Plug Points (3-pin) (i) 6Amps (ii) 16Amps	60	60x4 =	240					
4. Electrical gadgets (i) Water Heater (geyser) (ii) Refrigerator (iii) Air Conditioner (iv) Other	1000	1000x1 =	1000	1000x1 =	1000	1000x1 =	1000	240 3000
5. Welding Transformer								
6. Motor 3 φ Pump 7.5 HP	5600							5600
Total								8,840
In case of load enhancement Existing load (in watts)								
Total load in the premises (in watts)								8,840

Notes :-

- Details of any apparatus (other than the above mentioned) should be given.
- Rating of capacitor used in Induction Motor and Welding Transformer (Test report of capacitor is to be enclosed)

503 : 9000

KVAR