

MEGHALAYA POWER DISTRIBUTION CORPORATION LIMITED
OFFICE OF THE ASSISTANT EXECUTIVE ENGINEER
NEW SHILLONG DISTRIBUTION SUB DIVISION

No.MePDCL/NSDSD/T- 04/2024-25/

Dated ____ September, 2024 .

To.

The Executive Engineer,
Shillong East Distribution Division
MePDCL,Shillong..

Sub:- **Completion report on charging of 11KV Lines and 11/0.4KV, 63 KVA S/S of Pump House (DTW-XI-XII) , Wahkhap New Shillong.**

Sir,

With reference to the above, I am to inform you that the 11 KV Lines and 11/0.4Kv 63KVA, S/S of Pump House (DTW-XI-XII) at Wahkhap New Shillong was charged on the 14th August, 2024.The details of Consumer are as under:-

Name	: Pump House (DTW-XI-XII)
	Wahkap Mawpat
Date of Charging	: 14 th August 2024
Transformer capacity:	63 KVA
Transformer Maintenance:	
Connected Load	: 34KW
Category	: WSLT
Metering	: Meter No.MEB 99432
Rating	: 3x 240V (415V) 50Hz, 40 Amp Max 200 Amp
Type	: Thread Through
Make	: Secure
Meter Property	: MePDCL
Initial Reading	
	Kwh: 0000

This is for favour of your information.

Yours faithfully

Assistant Executive Engineer
New Shillong Distribution Sub-Division,
MePDCL,New , Shillong.

Memo No.MePDCL/NSDSD/T-04/2024-25/ 307@.


Dated 30th September 2024.

Copy to
1. AEE, RSD-II,MePDCL ,Shillong with a request to commence at the earliest for information and necessary action

2. The JE, (Revenue), NSDSD, MePDCL,Shillong.

3. The Executive Engineer Electrical Division PHE Shillong. For information

4.R/F


Assistant Executive Engineer
New Shillong Distribution Sub-Division,
MePDCL,New , Shillong.