

MEGHALAYA POWER DISTRIBUTION CORPORATION LIMITED
OFFICE OF THE ASSISTANT EXECUTIVE ENGINEER
NEW SHILLONG DISTRIBUTION SUB DIVISION

No MePDCL/NSDSD/T- 04/2024-25/

Dated _____ September, 2024

To

The Executive Engineer,
Shillong East Distribution Division
MePDCL, Shillong.

Sub

Completion report on charging of 11KV Lines and 11/0.4KV, 25 KVA S/S of Pump House, (DTW-XV) Wahkhap-1, Mawpat New Shillong.

Sir,

With reference to the above, I am to inform you that the 11 KV Lines and 11/0.4Kv 25KVA, S/S of Pump House at (DTW-XV) Wahkap-1, Mawpat New Shillong. Was charged on the 14th August, 2024. The details of Consumer are as under:-

Name	: PumpHouse(DTW-XV)Wahkhap-1 Mawpat
Date of Charging	: 14 th August 2024
Transformer capacity	: 25 KVA
Transformer Maintenance	:
Connected Load	: 22 KW
Category	: WSLT
Metering	: Meter No.MEB99438
Rating	: 3x 240V (415V) 50Hz, 40 Amp Max 200 Amp
Type	: Thread Through
Make	: Secure
Meter Property	: MePDCL
Initial Reading	:
Kwh	: 0000

This is for favour of your information.

Yours faithfully

Assistant Executive Engineer
New Shillong Distribution Sub-Division,
MePDCL, New , Shillong.

Memo No.MePDCL/NSDSD/T-04/2024-25/309 @.

Dated 30th September 2024.

Copy to

1. AEE, RSD-II, MePDCL, Shillong with a request to commence at the earliest for information and necessary action

2. The JE, (Revenue), NSDSD, MePDCL, Shillong.

3. The Executive Engineer Electrical Division PHE Shillong. For information

4. R/F

Assistant Executive Engineer
New Shillong Distribution Sub-Division,
MePDCL, New , Shillong.