

POWER DISTRIBUTION CORPORATION LIMITED
OFFICE OF THE ASSISTANT EXECUTIVE ENGINEER
NEW SHILLONG DISTRIBUTION SUB DIVISION

No.MePDCL/NSDSD/T- 04/2023-24/

Dated_____ Dec, 2024.

To.

The Executive Engineer,
Shillong East Distribution Division
MePDCL,Shillong..

Sub:- **Report on Charging of 11KV lines and 11/0.4 KV,25KVA S/S of Pump House, Mawpdang (DTW-IV)sohlaper, New Shillong**

Sir,

With reference to the above, I am to inform you that the 11 KV Lines and 11/0.415KV, 25KVA S/S of Pump House, Mawpdang (DTW-IV)sohlaper, New Shillong is charged on the 14th August 2024. The details are as under.

Name	: Pump House, Mawpdang (DTW-IV), New Shillong
Address	: Mawpdang, Sohlaper New Shillong.
Date of Charging	: 14 th August, 2024
Transformer capacity	: 25 KVA
Connected Load	: 9 KW
Category	: WSLT
Metering	: Meter No.MEB 99549
Rating	: 3x 240V(415V)
Type	: Thread Through
Make	: Secure
Meter Property	: MePDCL
	Initial Reading
	Kwh : 0000.0
	Kvah : 0000.0
	KVA : 0
	OMF: 1

This is for favour of your information and necessary action.

Yours faithfully

Assistant Executive Engineer
New Shillong Distribution Sub-Division,
MePDCL, , Shillong.

Memo No.MePDCL/NSDSD/T-04/2024-25/1184@.

Dated 11th December, 2024

Copy to

1. The AEE RSD-II ,MePDCL,Shillong with a request to commence at the earliest for information and necessary action.
2. The JE (Revenue) ,NSDSD ,Shillong
3. The Executive Engineer Electrical Division PHE Shillong for linformation
4. R/F

Assistant Executive Engineer
NSDSD