

**POWER DISTRIBUTION CORPORATION LIMITED**  
**OFFICE OF THE ASSISTANT EXECUTIVE ENGINEER**  
**NEW SHILLONG DISTRIBUTION SUB DIVISION**

No.MePDCL/NSDSD/T- 04/2024-25/

Dated\_\_\_\_ Dec, 2024.

To.

The Executive Engineer,  
Shillong East Distribution Division  
MePDCL, Shillong..

Sub:-

**Report on Charging of 11KV lines and 11/0.4 KV, 25KVA S/S of Pump House, Mawpdang (DTW-II), Nongmulieh New Shillong**

Sir,

With reference to the above, I am to inform you that the 11 KV Lines and 11/0.415KV, 25KVA S/S of Pump House, Mawpdang (DTW-II) Nongmulieh, New Shillong is charged on the 14<sup>th</sup> August 2024. The details are as under.

Name	: Pump House, Mawpdang (DTW-II), New Shillong
Address	: Mawpdang, Nongmulieh New Shillong.
Date of Charging	: 14 <sup>th</sup> August, 2024
Transformer capacity	: 25 KVA
Connected Load	: 9 KW
Category	: WSLT
Metering	: Meter No.MEB 99576
Rating	: 3x 240V(415V)
Type	: Thread Through
Make	: Secure
Meter Property	: MePDCL
	Initial Reading
	Kwh : 0000.0
	Kvah : 0000.0
	KVA : 0
	OMF: 1

This is for favour of your information and necessary action.

Yours faithfully

Assistant Executive Engineer  
New Shillong Distribution Sub-Division,  
MePDCL, , Shillong.

Memo No.MePDCL/NSDSD/T-04/2024-25/488 @.

Dated 11<sup>th</sup> December, 2024

Copy to

1. The AEE RSD-II ,MePDCL,Shillong with a request to commence at the earliest for information and necessary action.
2. The JE (Revenue) ,NSDSD ,Shillong
3. The Executive Engineer Electrical Division PHE Shillong for linformation
4. R/F

Assistant Executive Engineer  
NSDSD