

POWER DISTRIBUTION CORPORATION LIMITED
OFFICE OF THE ASSISTANT EXECUTIVE ENGINEER
NEW SHILLONG DISTRIBUTION SUB DIVISION

No.MePDCL/NSDSD/T- 04/2025-26/

Dated _____ May, 2025.

To,

The Executive Engineer,
Shillong East Distribution Division
MePDCL,Shillong..

Sub:-

Report on Charging of 11KV lines and 11/0.4 KV,100KVA S/S of Smti,ShimtilinKharkrang at Mawdiangdiang , New Shillong

Sir,

With reference to the above, I am to inform you that the 11 KV Lines and 11/0.415KV, 100KVA S/S of Smti, Shimtilin Kharkrang at Mawdiangdiang New Shillong is charged on the 06th May 2025. The details are as under.

Name	: Smti,Shimtilin Kharkrang
Address	: Mawdiangdiang New Shillong.
Date of Charging	: 06 th May, 2025
Transformer capacity	: 100KVA
Connected Load	: 78 KVA
Category	: CHT
Metering	: Meter No.MEB 99515
Rating	: 3x 240V (415V)
Type	: Thread Through
Make	: Secure
Meter Property	: MePDCL
	Initial Reading
	Kwh : 0000.0
	Kvah : 0000.0
	KVA : 0
	OMF: 1

This is for favour of your information and necessary action.

Yours faithfully

Assistant Executive Engineer
New Shillong Distribution Sub-Division,
MePDCL, Shillong.

Dated 15th May, 2025

Memo No.MePDCL/NSDSD/T-04/2025-26/ 86 @

Copy to

1. AEE, RSD-II, MePDCL ,Shillong with a request to commence at the earliest for information and necessary action

2. The JE, (Revenue), NSDSD, MePDCL,Shillong.

3. The Smti, Shimtilin Kharkrang. For information

4. R/F

Assistant Executive Engineer
New Shillong Distribution Sub-Division,
MePDCL, Shillong.