

POWER DISTRIBUTION CORPORATION LIMITED
OFFICE OF THE ASSISTANT EXECUTIVE ENGINEER
NEW SHILLONG DISTRIBUTION SUB DIVISION

MePDCL/NSDSD/T- 04/2025-26/

Dated _____ July, 2025.

The Executive Engineer,
Shillong East Distribution Division
MePDCL, B.C. House Shillong..

Sub:-

Completion report on Charging of 11KV lines and 11/0.415 KV, 63KVA S/S of Shri, Cheboy Talang at Wahkhap (Mawdiangdiang), New Shillong.

Sir,

With reference to the above, I am to inform you that the 11 KV Lines and 11/0.415KV, 63KVA S/S of Shri, Cheboy Talang at Wahkhap (Mawdiangdiang), New Shillong.. New Shillong is charged on the 30th June, 2025. The details are as under.

Name	: Shri, Cheboy Talang
Address	: Wahkhap (Mawdiangdiang), New Shillong.
Date of Commissioning	: 30 th /06/2025
Transformer capacity	: 63 KVA
Connected Load	: 35Kw
Category	: CLT
Transformer Maintenance:	
Type	: Trivector Smart Meter
Metering	: Meter No. MS5004415
Rating	: 3x240v, 50Hz
Make	: HPL Electric & Power Ltd
Meter Property	: MePDCL
CT Ring	: 100/5A
OMF	: 20
Initial Reading	
KWh	: 1.55
KVAh	: 1.97
KVA	: 0.00

This is for favour of your information and necessary action.

Yours faithfully

Assistant Executive Engineer
New Shillong Distribution Sub-Division,
MePDCL, Shillong.

Dated 8th July, 2025.

Memo No. MePDCL/NSDSD/T-04/2025-26/ 166 @

Copy to

1. AEE, RSD-II MePDCL, Shillong with a request to commence billing at the earliest
2. The JE, (Revenue), NSDSD, MePDCL, Shillong for information and necessary action
3. Shri, Cheboy Talang
4. R/F

Assistant Executive Engineer
New Shillong Distribution Sub-Division,
MePDCL, New , Shillong.