

MEGHALAYA POWER DISTRIBUTION CORPORATION LIMITED
OFFICE OF THE ASSISTANT EXECUTIVE ENGINEER
NEW SHILLONG DISTRIBUTION SUB DIVISION

No.MePDCL/NSDSD/T- 04/2025-26/
To.

Dated ____ July, 2025.

The Executive Engineer,
Shillong East Distribution Division
MePDCL,B.C. House Shillong.,

Sub:- **Completion report on Charging of 11KV lines and 11/0.415 KV,25KVA S/S of
M/S BAC INFRATECH Ltd at Mawpdang ,Mawkhonu, Ummir), New Shillong.**
Sir,

With reference to the above, I am to inform you that the 11 KV Lines and
11/0.415KV, 25KVA S/S of M/S BAC INFRATECH Ltd at Mawpdang,Mawkhonu Ummir New
Shillong, was charged on the 27th June, 2025. The details are as under.

Name	: M/S BAC INFRATECH Ltd
Address	: Mawpdang Mawkhonu Ummir, New Shillong.
Date of Commissioning	: 27 th /06/2025
Transformer capacity	: 25 KVA
Connected Load	: 19Kw
Category	: CLT
Transformer Maintenance:	
Type	: Trivector Smart Meter
Metering	: Meter No.MS5004418
Rating	: 3x240v, 50Hz
Make	: HPL Electric & Power Ltd
Meter Property	: MePDCL
CT Ring	: 50/5A
OMF	: 10
Initial Reading	
KWh	: 1.20
KVAh	: 1.50
KVA	: 0.00

This is for favour of your information and necessary action.

Yours faithfully

Assistant Executive Engineer
New Shillong Distribution Sub-Division,
MePDCL, Shillong.

Memo No.MePDCL/NSDSD/T-04/2025-26/172@

Dated 10th July, 2025.


Copy to

1. AEE, RSD-II MePDCL, Shillong with a request to commence billing at the earliest

2. The JE, (Revenue), NSDSD, MePDCL, Shillong for information and necessary action

3. M/S BAC INFRATECH Ltd

4. R/F


Assistant Executive Engineer
New Shillong Distribution Sub-Division,
MePDCL, New , Shillong.