

MEGHALAYA POWER DISTRIBUTION CORPORATION LIMITED
OFFICE OF THE ASSISTANT EXECUTIVE ENGINEER
NEW SHILLONG DISTRIBUTION SUB DIVISION

No. MePDCL/NSDSD/T- 04/2024-25/

Dated _____ December, 2024 .

To,

The Executive Engineer,
Shillong East Distribution Division
MePDCL, Shillong..

Sub

Completion report on charging of 11KV Lines and 11/0.4KV, 25 KVA S/S of
Shri, Iohbor Syiemlieh at Wahkhap Mawdiangdiang New Shillong.

Sir

With reference to the above, I am to inform you that the 11 KV Lines and 11/0.4Kv
25KVA, S/S of, **Shri, Iohbor Syiemlieh at Wahkhap Mawdiangdiang New Shillong** was
charged on the 07th December, 2024. The details of Consumer are as under:-

Name	: Shri, Iohbor Syiemlieh Wahkhap Mawdiangdiang New Shillong,
Date of Charging	: 07 th December 2024
Transformer capacity	: 25KVA
Transformer Maintenance:	
Connected Load	: 18Kw
Category	: CLT
Metering	: Meter No. MS5003618
Rating	: 3x 240V 50Hz,
CT Ring	: 50/5
Type	: Trivector Smart Meter
Make	: HPL Electric & Power Ltd
Meter Property	: MePDCL
	Initial Reading
	Kwh: 0000
	M.F: 10

This is for favour of your information.

Yours faithfully

Assistant Executive Engineer
New Shillong Distribution Sub-Division,
MePDCL, New, Shillong.

Dated 19th December 2024.

Ph. No.

Memo No. MePDCL/NSDSD/T-04/2024-25/500@

Copy to

1. AEE, RSD-II, MePDCL, Shillong with a request to commence at the earliest for information and
necessary action

✓ To JE, (Revenue), NSDSD, MePDCL, Shillong.

1. Shri, Iohbor Syiemlieh New Shillong. For information

4 H/P

for 11KV Mawdiangdiang

BT - Drangiang

Assistant Executive Engineer
NSDSD