

Meghalaya State Electricity Board

TEST REPORT

This is to certify that repaired/renewed/additional new electric installation at the premises of

WALLAMBOK LANGSTIEH

(Full Name)

(Please leave one loop between name & surname)

COUNTRYSIDE VIEW MAWDIANGDIANG, SHILONG

(Address)

is duly completed tested and is ready for your Engineer to test and connect on your main line.

1. The load has been arranged as follows :

Details of Load	Wattage of each item	Phase - 1		Phase - 2		Phase - 3		Total watt of all 3 phases
		No. of points	Total watt	No. of points	Total watt	No. of points	Total points	
1. Light points								
(i) Fluorescent	40W	12	480	12	480	12	480	1440
(ii) Incandescent								
(iii) CFL								
(iv) Halogen								
(v) Others Bulb	100W	2	200	2	200	2	200	600
2. Fan points								
3. Plug points (3-pin)								
(i) 6 Amps	100W	3	300	3	300	3	300	900
(ii) 16 Amps	1000W	1	1000	1	1000	1	1000	3000
4. Electrical gadgets								
(i) Water Heater (Geyser)								
(ii) Refrigerator								
(iii) Air Conditioner								
(iv) Others								
5. Welding Transformer								
6. Motor								
Total	6/kw		1980		1980		1980	5940
In case of load enhancement Existing load (in watts)								
Total load in the premises (in watts)								

Notes :-

(a) Details of any apparatus (other than the above mentioned should be given.

(b) Rating of capacitor used in Inductor Motor

and Welding Transformer (Test report of capacitor)

is to be enclosed)



KVAR