

Schedule I Form 7

# Meghalaya Energy Corporation Limited

## TEST REPORT

This is to certify that repaired/renewed/additional/new electric installation at the premises of

ELGIVA KHARBUDON

(Please leave one block between name &amp; surname)

(Full Name)

MAWKASIANG MAWDIANGDIANG SHILLONG

(Address)

is duly completed, tested and is ready for your Engineer to test and connect on your main line.

1. The load has been arranged as follows :-

Details of Load	Wattage of each item	Phase - 1		Phase - 2		Phase - 3		Total watt of all 3 phases
		No. of points	Total watt	No. of points	Total watt	No. of points	Total watt	
1. Light points								
(i) Fluorescent led	20w	40	800w					
(ii) Incandescent								
(iii) CFL								
(iv) Halogen								
(v) Others led	9w	50	450w					
2. Fan points	70w	10	700w					
3. Plug points (3-pin)								
(i) 6 Amps	100w	10	1000w					
(ii) 16 Amps	1000w	2	2000w					
4. Electrical gadgets								
(i) Water Heater (Geyser)								
(ii) Refrigerator								
(iii) Air Conditioner								
(iv) Others								
5. Welding Transformer								
6. Motor								
Total			4950w					4950w
In case of load enhancement								
Existing load (in watts)								
Total load in the premises (in watts)								

Say 5k.w.

Notes :-

(a) Details of any apparatus (other than the above mentioned) should be given.

(b) Rating of capacitor used in Induction Motor and Welding Transformer (Test report of capacitor is to be enclosed).

KVAR