

Meghalaya Energy Corporation Limited

TEST REPORT

This is to certify that repaired/renewed/additional/new electric installation at the premises of

S H R I R U M A K J O M O H

(Please leave one block between name & surname)

(Full Name)

U M S A W L I O P P N I F T

(Address)

is duly completed, tested and is ready for your Engineer to test and connect on your main line.

1. The load has been arranged as follows :-

Details of Load	Wattage of each item	Phase - 1		Phase - 2		Phase - 3		Total watt of all 3 phases
		No. of points	Total watt	No. of points	Total watt	No. of points	Total watt	
1. Light points (i) Fluorescent (ii) Incandescent (iii) CFL (iv) Halogen (v) Others	15w	40	600	40	600	40	600	1800
2. Fan points								
3. Plug points (3-pin) (i) 6 Amps (ii) 16 Amps	1500w	15	1500	0	0	0	0	1500
4. Electrical gadgets (i) Water Heater (Geyser) (ii) Refrigerator (iii) Air Conditioner (iv) Others	10000w	0	0	10	10000	0	0	10000
	2000w	0	0	0	0	2	2500	4000
5. Welding Transformer								
6. Motor								
Total								17300
In case of load enhancement Existing load (in watts)								
Total load in the premises (in watts)								18Kw

Notes :-

- (a) Details of any apparatus (other than the above mentioned) should be given.
- (b) Rating of capacitor used in Induction Motor