

MEGHALAYA POWER DISTRIBUTION CORPORATION LIMITED
OFFICE OF THE ASSISTANT EXECUTIVE ENGINEER
NEW SHILLONG DISTRIBUTION SUB DIVISION

No.MePDCL/NSDSD/T- 04/2024-25/

Dated ____ September, 2024 .

To.

The Executive Engineer,
Shillong East Distribution Division
MePDCL,Shillong..

Sub: - **Completion report on charging of 11KV Lines and 11/0.4KV, 25 KVA S/S of Pump House, (DTW-XXI) Lumkhyriem , New Shillong.**

Sir,

With reference to the above, I am to inform you that the 11 KV Lines and 11/0.4Kv 25KVA, S/S of Pump House at (DTW-XXI) Lumkhyriem,Mawpat New Shillong. was charged on the 14th August, 2024.The details of Consumer are as under:-

Name : PumpHouse(DTW-XXI)Lumkhyriem
Date of Charging : 14th August 2024
Transformer capacity : 25 KVA
Transformer Maintenance:
Connected Load : 23 KW
Category : WSLT
Metering : Meter No.MEB99395
Rating : 3x 240V (415V) 50Hz, 40 Amp Max 200 Amp
Type : Thread Through
Make : Secure
Meter Property : MePDCL
Initial Reading

Kwh : 0000

This is for favour of your information.

Yours faithfully

Assistant Executive Engineer
New Shillong Distribution Sub-Division,
MePDCL,New , Shillong.

Memo No.MePDCL/NSDSD/T-04/2024-25/302 @.

Dated 30th September 2024.

Copy to

1. AEE, RSD-II,MePDCL ,Shillong with a request to commence at the earliest for information and necessary action

✓ 2. The JE, (Revenue), NSDSD, MePDCL,Shillong.

3. The Executive Engineer, Electrical Division, ^{PHE} Shillong. For information

4. R/F

Assistant Executive Engineer
New Shillong Distribution Sub-Division,
MePDCL,New , Shillong.