

MEGHALAYA POWER DISTRIBUTION CORPORATION LIMITED
OFFICE OF THE ASSISTANT EXECUTIVE ENGINEER
NEW SHILLONG DISTRIBUTION SUB DIVISION

No. MePDCL/NSDSD/T- 04/2024-25/

Dated _____ September, 2024

To

The Executive Engineer,
Shillong East Distribution Division
MePDCL, Shillong..

Sub:

Completion report on charging of 11KV Lines and 11/0.4KV, 63 KVA S/S of Pump House (DTW-VI), Khlaw Mawpat New Shillong.

Sir,

With reference to the above, I am to inform you that the 11 KV Lines and 11/0.4Kv 63KVA. S/S of Pump House (DTW-VI) at Khlaw Mawpat New Shillong was charged on the 14th August, 2024. The details of Consumer are as under:-

Name	: Pump House (DTW-VI)
	Khlaw Mawpat
Date of Charging	: 14 th August 2024
Transformer capacity	: 63 KVA
Transformer Maintenance:	
Connected Load	: 30KW
Category	: WSLT
Metering	: Meter No. MEB 99498
Rating	: 3x 240V (415V) 50Hz, 40 Amp Max 200 Amp
Type	: Thread Through
Make	: Secure
Meter Property	: MePDCL
Initial Reading	
Kwh	: 0000

This is for favour of your information.

Yours faithfully

Assistant Executive Engineer
New Shillong Distribution Sub-Division,
MePDCL, New, Shillong.

Memo No. MePDCL/NSDSD/T-04/2024-25/ 303@.

Dated 30th September 2024.

Copy to

1. AEE, RSD-II, MePDCL, Shillong with a request to commence at the earliest for information and necessary action

✓ 2. The JE, (Revenue), NSDSD, MePDCL, Shillong.

3. The Executive Engineer, Electrical Division ^{PHE} Shillong. For information

4. R/F

Assistant Executive Engineer
New Shillong Distribution Sub-Division,
MePDCL, New, Shillong.