

**MEGHALAYA POWER DISTRIBUTION CORPORATION LIMITED**  
**OFFICE OF THE ASSISTANT EXECUTIVE ENGINEER**  
**NEW SHILLONG DISTRIBUTION SUB DIVISION**

No.MePDCL/NSDSD/T- 04/2024-25/

Dated \_\_\_\_\_September, 2024 .

To.

The Executive Engineer,  
Shillong East Distribution Division  
MePDCL,Shillong..

Sub: **Completion report on charging of 11KV Lines and 11/0.4KV, 25 KVA S/S of Pump House, (DTW-X) Wahnuid,Mawpat New Shillong.**

Sir,

With reference to the above, I am to inform you that the 11 KV Lines and 11/0.4Kv 25KVA, S/S of Pump House at (DTW-X) Wahnuid,Mawpat New Shillong. was charged on the 14<sup>th</sup> August, 2024.The details of Consumer are as under:-

Name : PumpHouse(DTW-X)Wahnuid Mawpat  
Date of Charging : 14<sup>th</sup> August 2024  
Transformer capacity : 25 KVA  
Transformer Maintenance:  
Connected Load : 18 KW  
Category : WSLT  
Metering : Meter No.MEB99344  
Rating : 3x 240V (415V) 50Hz, 40 Amp Max 200 Amp  
Type : Thread Through  
Make : Secure  
Meter Property : MePDCL  
Initial Reading  
Kwh : 0000

This is for favour of your information.

Yours faithfully

Assistant Executive Engineer  
New Shillong Distribution Sub-Division,  
MePDCL,New , Shillong.

Memo No.MePDCL/NSDSD/T-04/2024-25/ 304 @

Dated 30<sup>th</sup> September 2024.

Copy to

1. AEE, RSD-II,MePDCL ,Shillong with a request to commence at the earliest for information and necessary action

2. The JE, (Revenue), NSDSD, MePDCL,Shillong.

3. The Executive Engineer, Electrical Division, <sup>PHE</sup> Shillong. For information

4. R/F

Assistant Executive Engineer  
New Shillong Distribution Sub-Division,  
MePDCL,New , Shillong.