

**MEGHALAYA POWER DISTRIBUTION CORPORATION LIMITED**  
**OFFICE OF THE ASSISTANT EXECUTIVE ENGINEER**  
**NEW SHILLONG DISTRIBUTION SUB DIVISION**

No.MePDCL/NSDSD/T- 04/2024-25/

Dated \_\_\_\_\_ September, 2024 .

To.

The Executive Engineer,  
Shillong East Distribution Division  
MePDCL,Shillong..

Sub:

**Completion report on charging of 11KV Lines and 11/0.4KV, 63 KVA S/S of Pump House (DTW-XV) , Umsarang New Shillong.**

Sir,

With reference to the above, I am to inform you that the 11 KV Lines and 11/0.4Kv 63KVA, S/S of Pump House (DTW-XV) at Umsarang New Shillong was charged on the 14<sup>th</sup> August, 2024.The details of Consumer are as under:-

Name	: Pump House (DTW-XV)
	Umsarang Mawpat
Date of Charging	: 14 <sup>th</sup> August 2024
Transformer capacity:	63 KVA
Transformer Maintenance:	
Connected Load	: 44KW
Category	: WSLT
Metering	: Meter No.MEB 99548
Rating	: 3x 240V (415V) 50Hz, 40 Amp Max 200 Amp
Type	: Thread Through
Make	: Secure
Meter Property	: MePDCL
Initial Reading	
Kwh:	0000

This is for favour of your information.

Yours faithfully

Assistant Executive Engineer  
New Shillong Distribution Sub-Division,  
MePDCL,New , Shillong.

✓  
Memo No.MePDCL/NSDSD/T-04/2024-25/305@


Dated 30<sup>th</sup> September 2024.

Copy to

1. AEE, RSD-II, MePDCL ,Shillong with a request to commence at the earliest for information and necessary action

✓ The JE, (Revenue), NSDSD, MePDCL,Shillong.

3. The Executive Engineer, Electrical Division <sup>PAE</sup> Shillong. For information

  
Assistant Executive Engineer  
New Shillong Distribution Sub-Division,  
MePDCL,New , Shillong.