

CONSUMER DETAILS

Application no. 03032026

Name	ATC Telecom Infra Pvt Ltd
Address	Lumsohpetbneng
Contact No.	8787493382
Category	CLT
Load	22
Meter No.	22002135
Meter Brand	JPM
SIM Type	JIO
SIM No.	89918650406001803484
OMF	1
TMC	No
Date of Connection	13-Jan-26
Load Security	106920
Service Connection / HT Metering	35978.12

DT Details

DT Capacity	63 KVA
Serial Number	
Manufacture Date	
Brand	



Me PDCL

MEGHALAYA POWER DISTRIBUTION CORPORATION LIMITED
OFFICE OF THE ASSISTANT EXECUTIVE ENGINEER
INVESTIGATION & ENFORCEMENT SUB-DIVISION, RIBHOI (D) CIRCLE
MePDCL, UMIAM

No. MePDCL /I&E/RBDC/T-07/2025-26/724

Dated Umiam the 26th February, 2026

To,

The Assistant Executive Engineer,
Umiam Distribution Sub-Division.
MePDCL, Umiam.

Sub: Inspection Report of New LT-CT Metering Unit of new consumer viz., Telecom Infrastructure PVT. Ltd, Lumsohpetbneng.

Sir,

With reference to the subject cited above, this is to inform you that the office of the undersigned has on the 25-02-2026 inspected the new **LT-CT Metering Unit of Telecom Infrastructure PVT. Ltd, Lumsohpetbneng.** and the detailed Inspection Report is enclosed herewith for your kind perusal.

It is to be noted that the installed Meter No. **SS22171303** found at site is Whole Current Secure Make Meter (Non-Smart) and has therefore been replaced with JPM Make Whole Current Smart Meter No. **22002135** and the already consumed units of 11975.00 kWh is to be recovered later as Additional Units. The entire metering unit is as per standard metering practice with **Multiplication Factor (O.M.F for billing) of 1.**

This is for your kind information and necessary action.

Encl.: Inspection Report.

Yours faithfully,

(Fullmoon L. Kynshi)
Assistant Executive Engineer
I & E Sub-Division, Ribhoi (D) Circle
MePDCL, Umiam

No. MePDCL /I&E/RBDC/T-07/2025-26/724(a)

Dated Umiam the 26th February, 2026

Copy to:-

1. The Superintending Engineer, Ribhoi (D) Circle, MePDCL, Umiam for kind information.
2. The Superintending Engineer (I & E), EZ, MePDCL, Shillong for kind information.
3. The Executive Engineer, Umiam Distribution Division for kind information.
4. The Executive Engineer, MTI Division, MePDCL, Shillong for kind information.
5. The Executive Engineer (HVC), O/o CE (Commercial) for kind information with a request to integrate this meter with HES/MDM.
6. The Junior Engineer (Central Billing Section), Umiam Distribution Division for kind information and necessary action.
7. R/F.


ASSISTANT EXECUTIVE ENGINEER

**INSPECTION REPORT OF NEW METERING UNIT OF ATC
Telecom Infrastructure PVT. Ltd, Lumsohpetbneng CONDUCTED ON THE 25.02.2026.**

SL NO	Consumer No	SUPPLY VOLTAGE (KV)	NAME OF CONSUMER	ADDRESS	CT Ratio	O.M.F	METER NO.	CATEGORY	CONTRACT DEMAND (KW)	READINGS					Remark	
										KWH	KVAH	KW	R-N (V)	Y-N (V)		B-N (V)
1	New (Yet to be allotted)	11	ATC Telecom Infrastructure PVT. Ltd	Lumsohpetbneng	1	1	22002135 3Ph Whole Current 10(60)A, 3x240V/415V, 50Hz (kWh, kVAh, kVarh) 1000Imp/kWh, Type: DTZ1513 JPM Industries Ltd Make Smart Meter	CLT	22	0.00	0	0	240	240	238	Old Meter No. 5522171303 (kWh as on 25-02-2025). Additional Units being non-smart was replaced with Whole Current Smart Meter Number with SIM CARD (JIO No.). 8991 8650 4060 0180 3484

Note: O.M.F: 1 (kWh, kVAh, kVA)
DTC: 63KVA
Contract Demand Applied: 22KVA

F. L. Kynshi
26/02/2026

F. L. Kynshi
Asstt Executive Engineer
Investigation & Enforcement Sub Division
MePDCL, Umiam.