

MEGHALAYA POWER DISTRIBUTION CORPORATION LIMITED
OFFICE OF THE ASSISTANT EXECUTIVE ENGINEER
NEW SHILLONG DISTRIBUTION SUB DIVISION

No.MePDCL/NSDSD/T- 04/2025-26/

Dated ___ February, 2026.

To.

The Executive Engineer,
Shillong East Distribution Division
MePDCL,B.C. House Shillong..

Sub:-

Completion report on Charging of 11KV lines and 11/0.415 KV,200KVA S/S for providing power supply to the Premises of Smti,Susan S.H.D.Sohliya at Pynthorbah Suri Umlulong , Mawpdang New Shillong.

Sir,

With reference to the above, I am to inform you that the 11 KV Lines and 11/0.415KV, 200KVA S/S of for providing power supply to the premises of Smti Susan S.H.D. Sohliya at Pynthorbah Suri Umlulong , New Shillong is charged on the 22nd January, 2026.

The details are as under.

Name	: Smti,Susan S.H.D.Sohliya
Address	: Pynthorbah Suri Umlulong ,Mawpadang New Shillong.
Date of Commissioning	: 22 nd /01/2026.
Transformer capacity	: 200 KVA
Connected Load	: 167KVA
Category	: CHT
Transformer Maintenance:	MePDCL
Type	: CTSMN5
Metering	: Meter No.MS5003891
Rating	: 3x240v, 50Hz
Make	: HPL Electric &Power Ltd
Meter Property	: MePDCL
CT Ring	: 300/5A
OMF	: 60
Initial Reading	
KWh	:0000
KVAh	:0000
KVA	:000

This is for favour of your information and necessary action.

Yours faithfully

Assistant Executive Engineer
New Shillong Distribution Sub-Division,
MePDCL, Shillong.

Memo No.MePDCL/NSDSD/T-04/2025-26/560 @.

Dated 17th Feb, 2026.

Copy to

1. AEE, RSD-II MePDCL, Shillong with a request to commence billing at the earliest

2. The JE, (Revenue), NSDSD,MePDCL,Shillong for information and necessary action

3. Smti,Susan S.H.D.Sohliya

4. R/F

Assistant Executive Engineer
New Shillong Distribution Sub-Division,
MePDCL,New , Shillong