

MEGHALAYA POWER DISTRIBUTION CORPORATION LIMITED
OFFICE OF THE ASSISTANT EXECUTIVE ENGINEER
NEW SHILLONG DISTRIBUTION SUB DIVISION

No.MePDCL/NSDSD/T- 04/2025-26/

Dated _____ February, 2026 .

To.
The Executive Engineer,
Shillong East Distribution Division
MePDCL,Shillong..

Sub:- **Completion report on charging of 11KV Lines and 11/0.4KV, ,200KVA S/S of Smt,Emmon Tlang at Dongmylliem ,Tynring, New Shillong.**

Sir,
With reference to the above, I am to inform you that the 11 KV Lines and 11/0.4Kv 200KVA, S/S of Smt, Emmon Tlang at Dongmylliem ,Tynring New Shillong was charged on the 22th January, 2026.The details of Consumer are as under:-

Name :Emmon Tlang,
Address : Dongmylliem, Tynring
Date of Charging : 22th January, 2026
Transformer capacity : 200 KVA
Transformer Maintenance:
Connected Load : 184 KVA
Category : CHT
Metering : Meter No.MS5003892
CT Ring : 300/5A
Rating : 3x 240V , 50Hz, kwh kvah kvarh
Type : CTSMN5
Make : HPL Electric & Power Ltd
Meter Property : MePDCL
OMF : 60
Initial Reading

Kwh: 0000
KVA :0000
KVAH:0000

This is for favour of your information.

Yours faithfully

Assistant Executive Engineer
New Shillong Distribution Sub-Division,
MePDCL,New , Shillong.

Memo No.MePDCL/NSDSD/T-04/2025-26/554@.
Copy to:-

Dated 6th February 2026.

1. AEE, RSD-II,MePDCL ,Shillong with a request to commence at the earliest for information and necessary action

2. The JE, (Revenue), NSDSD, MePDCL,Shillong. for information and necessary action

3. Smt,Emmon Tlang

4. R/F

Assistant Executive Engineer
New Shillong Distribution Sub-Division,
MePDCL,New , Shillong.