

MEGHALAYA POWER DISTRIBUTION CORPORATION LIMITED
OFFICE OF THE ASSISTANT EXECUTIVE ENGINEER
NEW SHILLONG DISTRIBUTION SUB DIVISION

No.MePDCL/NSDSD/T- 04/2024-25/

To.

Dated ____ January, 2025 .

The Executive Engineer,
Shillong East Distribution Division
MePDCL, Shillong..

Sub:-

Completion report on charging of 11KV Lines and 11/0.4KV, 25 KVA S/S of Pump House (DTW-I), at Mawdiangdiang New Shillong.

Sir,

With reference to the above, I am to inform you that the 11 KV Lines and 11/0.4Kv 25KVA, S/S of Pump House (DTW-I), at Mawdiangdiang New Shillong was charged on the 08th December, 2024. The details of Consumer are as under:-

Name	: Pump House (DTW-I),
Address	: Mawdiangdiang
Date of Charging	: 08 th December 2024
Transformer capacity:	25 KVA
Transformer Maintenance:	
Connected Load	: 10KW
Category	: WSLT
Metering	: Meter No.MEB 99550
Rating	: 3x 240V (415V) 50Hz, 40 Amp Max 200 Amp
Type	: Thread Through
Make	: Secure
Meter Property	: MePDCL
Initial Reading	
Kwh:	0000

This is for favour of your information.

Yours faithfully

/

Assistant Executive Engineer
New Shillong Distribution Sub-Division,
MePDCL, New , Shillong.

Memo No.MePDCL/NSDSD/T-04/2024-25/523@.

Dated 15th January 2025.


Copy to

1. AEE, RSD-II, MePDCL , Shillong with a request to commence at the earliest for information and necessary action

✓ 2. The JE, (Revenue), NSDSD, MePDCL, Shillong.

3. The Executive Engineer Electrical Division PHE Shillong. For information

4. R/F


Assistant Executive Engineer
New Shillong Distribution Sub-Division,
MePDCL, New , Shillong.