

MEGHALAYA POWER DISTRIBUTION CORPORATION LIMITED
OFFICE OF THE ASSISTANT EXECUTIVE ENGINEER
NEW SHILLONG DISTRIBUTION SUB DIVISION

No.MePDCL/NSDSD/T- 04/2025-26/

Dated _____ August, 2025.

To.

The Executive Engineer,
Shillong East Distribution Division
MePDCL,B.C. House Shillong..

Sub:-

Completion report on Charging of 11KV lines and 11/0.415 KV,100KVA S/S for providing power supply to the Premises of Shri, Barnabas Nongbah at Ummir , New Shillong ., New Shillong.

Sir,

With reference to the above, I am to inform you that the 11 KV Lines and 11/0.415KV, 100KVA S/S of for providing power supply to the premises of Shri, Barnabas at Ummir, New Shillong is charged on the 20th August, 2025.

The details are as under.

Name	: Shri,Barnabas Nongbah
Address	: Ummir New Shillong.
Date of Commissioning	: 20 th /08/2025
Transformer capacity	: 100 KVA
Connected Load	: 20Kw
Category	: CLT
Transformer Maintenance:	
Type	: Trivector Smart Meter
Metering	: Meter No.MS5004282
Rating	: 3x240v, 50Hz
Make	: EASTERN TRAFO PRIVATE LIMITED
Meter Property	: MePDCL
CT Ring	: 150/5A
OMF	: 30
Initial Reading	
KWh	: 0.6206
KVAh	: 1.7974
KVA	: 0.00

This is for favour of your information and necessary action.

Yours faithfully

Assistant Executive Engineer
New Shillong Distribution Sub-Division,
MePDCL, Shillong.

Dated 25th August, 2025.

Memo No.MePDCL/NSDSD/T-04/2025-26/272@.

Copy to

1. AEE, RSD-II MePDCL, Shillong with a request to commence billing at the earliest

2. The JE, (Revenue), NSDSD,MePDCL,Shillong for information and necessary action

3. Shri,Barnabas Nongbah

4. R/F

Assistant Executive Engineer
New Shillong Distribution Sub-Division,
MePDCL,New , Shillong