



MePDCL

MEGHALAYA POWER DISTRIBUTION CORPORATION LIMITED
OFFICE OF THE ASSISTANT EXECUTIVE ENGINEER
UMIAM RURAL DISTRIBUTION SUB-DIVISION, UMIAM

No. MePDCL/AEE/URDSD/T-14/2025-26/

Dated: September 2025

To,
The Executive Engineer,
Umiam Distribution Division,
MePDCL, Umiam.

Sub: Completion Report

Sir,

With reference to the above, I have the honour to inform you that the works for construction of 11KV line = 0.1KM and 500KVA Sub-Station under Deposit works for providing power supply to Eastern Ri-Bhoi Organic Farmer Producer Company at Umsli Bhoiymbong village, Ri-Bhoi District was completed in all respect and Charge on 27 August 2025. The details are as follow

- 1, Name of Consumer: Eastern Ri-Bhoi Organic Farmer Producer Company
- 2, Address: Umsli Bhoiymbong village, Ri-Bhoi District
- 3, Category: 480KVA (Four Hundred and Eighty KVA) IHT *1st yr 50KVA*
- 4, Meter No: 70690
- 5, Total Estimated Cost: Rs 4535306.00
- 6, Receipt/ Acknowledge No: ACB/1774/Pt-III/2025/146 DATED: 19-05-2025
- 7, Date of completion: 03 May 2024
- 8, Date of Charging: 27 August 2025
- 9, Maintenance and replacement of Transformer in case of failure will be the responsibility by the Department as per Agreement signed with the Consumer.

This is for favour of your information and necessary approval.

Enclosed: As stated.

Yours faithfully,

Assistant Executive Engineer
Umiam Rural Distribution Sub-Division
MePDCL, Umiam

No. MePDCL/AEE/URDSD/T-14/2025-26/305(a)

Dated: 22nd September 2025

Copy to:

- 1) Shri Revistar Kharumnuid, CEO Cum Managing Director, Umsli Bhoiymbong village, Ri-Bhoi District for information and necessary action regarding signing agreement and billing.
- 2 The Assistant Executive Engineer, Umiam Distribution Sub-Division, MePDCL, Umiam for favour of Information and necessary action. Internal wiring Test Report and Meter Test Certificate are also enclosed.
- 3 ✓ The Junior Engineer, CBS, Umiam for information and to start billing with immediate effect.

Assistant Executive Engineer

to 31/10/2025

C

**EASTERN RI BHOI ORGANIC
FARMER PRODUCER COMPANY LIMITED**



AT YARD, NEAR KURKALANG STADIUM
GE LUMDAITKHLA,

BHOIRYMBONG, RI BHOI, MEGHALAYA-793116, INDIA.

Email : easternribhoiorganicfpc@gmail.com & rkharumnuid08@gmail.com

Contact details: 08414926216:

Regn. No: CIN: U01100ML2017PTC013648 (Registered under Companies Act, 2013).

Date: 04/12/2024

ofpc/12/2019-20/247

The Assistant Executive Engineer
Umiam Rural Distribution Sub-Division
MePDCL, Umiam

Subject: Application for installation of 500KV New Transformer in the Organic Spice Industrial Unit at Umsli, Bhoirymbong

In light of the above mentioned subject, I hereby apply for installation of 500KV New Transformer in the Organic Spice Industrial Unit at Umsli, Bhoirymbong of Eastern Ri-Bhoi Organic Farmer Producer company Limited Bhoirymbong and kindly provide us the estimate on the above mentioned work to the office of the undersigned. The company is in need of such connection for running and setting up of the large Scale Organic Spice Industrial Unit and the office of administration simultaneously. The connection needed is of 3 (three) phase line of 500 KVA. Your kind consideration and cooperation on this matter is highly appreciated.

This is for your kind information and necessary action.

For EASTERN RI BHOI ORGANIC FARMER PRODUCER COMPANY LIMITED

Yours' Faithfully,

MR. REVISTAR KHARUMNUID
CEO Cum Managing Director
DIN 07968750

APPLICATION FORM FOR PROVIDING LT. SERVICE CONNECTION (FOR ALL CATEGORY AND FOR ALL PURPOSE)

To,

The Area Manager/ Asstt. Executive Engineer
Service Connection Sub-Division/Distribution Sub-Division
MeECL _____
(Indicate the local area of the jurisdiction of the Engineer of the licensee)

Sir,

- 1 I/We hereby request you to supply electricity to the premises located at the address more fully described below. I/We are the owner/lawful occupier of the premises.
- 2 I/We agree to abide by the terms and condition relating to the supply of electricity by MeECL and to make all payments as may be required and also to pay regularly all charges as may become due.
- 3 a) Full name and address of the applicant with contact telephone number
EASTERN RI-BHOI ORGANIC FARMER PRODUCER COMPANY LIMITED
UMSLE
8414926216

b) Status in relation to the premises

Owner

☒

Occupier

☒

c) Location and address of the premises including Police Station.

d) Nature of LT. supply :

Comercial

☐

Domestic

☐

Industrial

☒

General Purpose

☐

WSLT

☐

PL

☐


Agriculture

☐

KJ

☐

Date :


Eastern Ri-Bhoi Organic
Farmer Producer Company Limited
Applicant's Signature
CIN: 061150 0004781 C013648
PAN: H0AAEECE8438M
Regd Office Napmara, Lumdaitkhla
RI-Bhoi Meghalaya, India 793116

NB : The following documents are to be enclosed :

- 1) Test Report from Licensed contractor.
- 2) Agreement Form duly filled in.
- 3) Proof of ownership (in case applicant is owner)
- 4) Number of nearest Electric Pole.
- 5) NOC of the owner of the premises (in case the application is an occupier).
- 6) Attested copy of permission obtained from Pollution Control Board.
- 7) Building permission from the concerned authority.



Annexure-3

Agreement for Supply of Electricity low tension

An Agreement made this the _____ day of _____ of 20 _____ between _____ and his successor and assigns (hereinafter referred to as the consumer) of the one part and the Meghalaya Power Distribution Corporation Limited an electricity distribution licensee under the EA, 2003 and its successors and assigns (hereinafter referred to as the Distribution / Utility / MePDCL) of the other part.

Note - the term 'consumer' includes an individual person (Whether male or female), a body of persons, a company, society, firm, association or organization.

Whereas, the consumer has applied to the distribution utility for supply of electricity to the premises and the distribution utility has agreed to give the supply under the terms and conditions hereafter appearing;

Now, therefore, the agreement witness -

(1). That the supply shall be given to the premises located at UMSLI with the Consumer as owner/occupier of;

(2). That the supply shall be for the purpose of Industrial
The load whereof shall not exceed 408 kVA or 480 kVA watts.

(3). That the provision of the EA, 2003 and the regulations, code and orders including tariff orders, as may be made from time to time by the MSERC shall apply and bind the consumers and the distribution utility alike;

(4). That the consumer shall regularly and timely pay to MePDCL all charges may be due for the supply of electricity;

(4-a). That the consumer shall pay the Transformer Maintenance Charge as stipulated by the license and thereby maintenance and replacement of the transformer on account of failure shall be the responsibility of the licensee.


(5). That the agreement shall be a period of two years and may be renewed for a further period; Provided that supply shall not be terminated by mere efflux of time if the consumer is willing that the agreement is renewed;

(6). That the agreement shall be terminated if the consumer on its part desires it so and gives to the MePDCL a prior notice of not less than one month or on the part of the MePDCL, if the consumer has violated any of the terms and conditions of the agreement

Provided that on the part of the MePDCL notice shall be given to the consumer starting the reasons for the proposed termination and giving him opportunity to state his case and his statement, if any, duly considered before the agreement is terminated and the supply of Electricity cut off:

(7) The terms and conditions of this agreement shall be effective from the date of supply of electricity is commenced.

IN WITNESS WHEREOF the parties hereto have set their hands and seals the date, month, and year first above written.


Eastern RI-Bhoi Organic
Farmer Producer Company Limited
(For and on behalf of and by)
PAN No: AEEC1001M2017P1C013648
Authorisation of the consumer
Res. Khannara, Lumdaitkhia
RI-Bhoi Meghalaya, India. 793116

For and on behalf of MePDCL

Witness :-

1. Signature : _____

Name : _____

Address : _____

2. Signature : _____

Name : _____

Address : _____

Meghalaya Energy Corporation Limited

TEST REPORT

This is to certify that repaired/renewed/additional/new electric installation at the premises of

E A S T E R N R I B H O I O R G A N I C F A R M E R P R O D U C E R
(Please leave one block between name & surname) COMPANY LIMITED

(Full Name)

U M S L I

(Address)

is duly completed, tested and is ready for your Engineer to test and connect on your main line.

1. The load has been arranged as follows :-

Details of Load	Wattage of each item	Phase - 1		Phase - 2		Phase - 3		Total watt of all 3 phases
		No. of points	Total watt	No. of points	Total watt	No. of points	Total watt	
1. Light points								
(i) Fluorescent	100	5	500	5	500	5	500	1500
(ii) Incandescent								
(iii) CFL	20	5	100	5	100	5	100	300
(iv) Halogen								
(v) Others								
2. Fan points	100	2	200	2	200	2	200	600
3. Plug points (3-pin)								
(i) 6 Amps	100	3	300	3	300	3	300	900
(ii) 16 Amps	1000	2	2000	2	2000	2	2000	6000
4. Electrical gadgets								
(i) Water Heater (Geyser)								
(ii) Refrigerator	3000	4	12000	4	12000	4	12000	36000
(iii) Air Conditioner								
(iv) Others	3000	3	9000	3	9000	3	9000	27000
5. Welding Transformer								
6. Motor 7.5HP	55950	2	111900	2	111900	2	111900	335700
Total			136000		136000		136000	408000
In case of load enhancement			-		-		-	-
Existing load (in watts)								
Total load in the premises (in watts)			136.00		136.00		136.00	408.00

Notes :-

Sag = 408kw or 480kVA

(a) Details of any apparatus (other than the above mentioned) should be given.

(b) Rating of capacitor used in Induction Motor and Welding Transformer (Test report of capacitor is to be enclosed).

KVAR

Meghalaya Energy Corporation Limited

TEST REPORT

This is to certify that repaired/renewed/additional/new electric installation at the premises of

E A S T E R N R I B H O I O R G A N I C F A R M E R PRODUCER
(Please leave one block between name & surname) COMPANY LIMITED

(Full Name)

U M S L I

(Address)

is duly completed, tested and is ready for your Engineer to test and connect on your main line.

1. The load has been arranged as follows :-

Details of Load	Wattage of each item	Phase - 1		Phase - 2		Phase - 3		Total watt of all 3 phases
		No. of points	Total watt	No. of points	Total watt	No. of points	Total watt	
1. Light points								
(i) Fluorescent	100	5	500	5	500	5	500	1500
(ii) Incandescent								
(iii) CFL	20	5	100	5	100	5	100	300
(iv) Halogen								
(v) Others								
2. Fan points	100	2	200	2	200	2	200	600
3. Plug points (3-pin)								
(i) 6 Amps	100	3	300	3	300	3	300	900
(ii) 16 Amps	1000	2	2000	2	2000	2	2000	6000
4. Electrical gadgets								
(i) Water Heater (Geyser)								
(ii) Refrigerator	3000	4	12000	4	12000	4	12000	36000
(iii) Air Conditioner								
(iv) Others	3000	3	9000	3	9000	3	9000	27000
5. Welding Transformer								
6. Motor 75HP	55950	2	111900	2	111900	2	111900	335700
Total			136000		136000		136000	408000
In case of load enhancement Existing load (in watts)			-		-		-	-
Total load in the premises (in watts)			13600		13600		13600	40800

Notes :-

- (a) Details of any apparatus (other than the above mentioned) should be given.
- (b) Rating of capacitor used in Induction Motor and Welding Transformer (Test report of capacitor is to be enclosed).

Sag = 408kva or 480kVA

VAR

II. Type of wiring *casing and capping wiring*

III. Voltage and system of supply *440V*

IV. Test Result : *Ok*

Date of Testing by Licensed Contractor :

1	9	1	2	2	4
---	---	---	---	---	---

Type of Test	Result of test carried out by licensed contractor (in $M\Omega$) / Ω	Result of test carried out by the supplier under relevant IE Rules, in ($M\Omega$) / Ω
a. Insulation resistance between earth and whole system of conductor	<i>200MΩ 200MΩ 200MΩ</i>	
b. Insulation resistance between all conductors.	<i>200MΩ 200MΩ 200MΩ</i>	
c. Earth continuity between earth electrode and earth continuity conductor.	<i>3Ω 3Ω 3Ω</i>	
d. Polarity of non-linked SP switches.		

V. Full Name with signature of Licensed contractor :

LIC No.

S. Wahlang
S. Wahlang

Electrical Contractor

Regd. No 383

VI. Full Name with signature of supervisor
(with date)

LIC No.

K. Nophsiey
K. Nophsiey

Electrical Supervisor

Regd. No 1028

VII. Full Name with signature of wireman
(with date)

PERMIT No.

S. Wahlang
S. Wahlang

Electrical Wireman

Regd. No 2468

VIII. Signature of the authorised official who tested
The installation of behalf of supplier.

IX. Date of connection of supply to the installation

Me PDCL

MEGHALAYA POWER DISTRIBUTION CORPORATION LIMITED
OFFICE OF THE ASSISTANT EXECUTIVE ENGINEER
INVESTIGATION & ENFORCEMENT SUB-DIVISION, RIBHOI (D) CIRCLE
MePDCL, UMIAM

No. MePDCL /I&E/RBDC/T-07/2025-26/651

Dated Umiām the 29th August, 2025

To,

✓ The Assistant Executive Engineer,
Umiām Rural Distribution Sub-Division
MePDCL, Umiām.

Sub: Commissioning and Installation Report of New HT-CT Metering Unit of Eastern Ribhoi Organic Farmer Processing Company Ltd, Bhoirymbong

Sir,


With reference to the subject cited above, this is to inform you that the office of the undersigned has on the 20-08-2025 assisted your office in commissioning and installation of new HT-CT Metering Unit of Eastern Ribhoi Organic Farmer Processing Company Ltd, Bhoirymbong and the Commissioning & Installation Report is enclosed herewith for further necessary action from your end.

It is to be noted that the installed Meter No. **MS5005687** is an HT-CT HPL LTD Make Smart Meter with internal CT Ratio=1 & PT Ratio=100 and the entire metering unit is *as per standard metering practice* with an Overall Multiplication Factor (O.M.F) of 4.

This is for your kind information and necessary action.

Encl.: Commissioning and Installation Report.

Yours faithfully,



(Fullmoon L. Kynshi)
Assistant Executive Engineer
I & E Sub-Division, Ribhoi (D) Circle
MePDCL, Umiām

No. MePDCL /I&E/RBDC/T-07/2025-26/651(a)

Dated Umiām the 29th August, 2025

Copy to:-

1. The Superintending Engineer, Ribhoi (D) Circle, MePDCL, Umiām for kind information.
2. The Superintending Engineer (I & E), Eastern Zone, MePDCL, Shillong for kind information.
3. The Executive Engineer, Umiām Distribution Division for kind information.
4. The Assistant Executive Engineer, MTI Sub-Division, MePDCL, Shillong for kind information.
5. The Executive Engineer (HVC), O/o CE (Commercial) for kind information with a request to integrate this consumer with HES/MDM.
6. R/F.

ASSISTANT EXECUTIVE ENGINEER

Commissioning and Installation Report of New HT-CT Metering of Eastern Ribhoi Organic Farmer Processing Company Ltd, Bhoiymbong.

Date of Installation of 11KV CT-PT Unit:										20-08-2025						Location	Latitudes	Longitudes	
Date of Installation of Meter:										20-08-2025							25°42'23.97"N	92°1'23.65"E	
Sl. No.	Name of Consumer	Address	Supply Voltage (KV)	CT-PT Specification			CT Ratio Selected	Meter No. & Specification	Meter Ratio	O.M.F	INITIAL READINGS (20-08-2025 @14:00 HRS)						SIM Card Details (Service, SIM No.)	Seal Number	Remarks
				Parameter	CT	PT					KWH	KVAH	KVA	R-N (V)	Y-N (V)	B-N (V)			
1	Eastern Ribhoi Organic Farmer Processing Company Ltd	Bhoiymbong	11	Serial No.	70690		20/5A	Meter No.: MS5005687	100	4	0.00	0.00	0.00	62	62	62	Airtel, 0524ID 899116099002 6412414U H1	TTB-9228705 Box-9228789	Metering Unit Confirms to Standard Metering Practice and ready for Billing purpose with an Overall M.Fed.
				Ratio:	10-20/5	11KV/110V		Class: 0.5S, -/5A, Ib=5A, Imax=2xIb											
				Burden:	15VA	50VA		3x(11kV/V3/110/V3V)											
				Class	0.5S	0.5		16000Pules/Unit (kWh, kVAh, kVArh)											
				Freq.	50HZ			50Hz											
				Make:	Macroplast Pvt Ltd			Make: HPL Electric & Power Ltd make											
				Type: 3P 4W				Type: HST52 Smart Meter Phase Sequence: Forward											

MEGHALAYA ENERGY CORPORATION LIMITED

(Government of Meghalaya Enterprise)
'Accounts Department'
Corporate Identification No. U40101ML2009SGC008374
"Lum Jingshai", Shillong

Phone No.0364 - 2592155 & Fax No.0364 - 2591344

Date: 19-05-2025

No. ACB/1774/Pt-III/2025/146

The Executive Engineer,
Umiam Distribution Division,
MePDCL, Umiam.

Executive Engineer
Umiam Distribution Division
MEPDCL, Umiam

Dairy No 380 Dt 22/5/25


Acknowledgement receipt.

Your letter No. MePDCL/EE/UDD/MC-02/2025-26/197

dated. 14-05-2024.

With reference to the above, I am to acknowledge the following being amount deposited in our MeECL Deposit Work Account No. 10196051058.

Sl	Particulars	Amount (Rs.)	Date of credit
1.	Payment for construction of 11 KV line, 11/0.4 KV 500 KVA including Civil Works for construction of Sub-station fencing and rainshed for DT metering, HT metering and Load Security and application fee providing power supply to Eastern Ri-Bhoi Organic Farmer Producer Company (ERBOFPC) Ltd at Umsli, Ri-Bhoi District.	45,35,306.00	08-05-2025


(S Bareh)

Senior Accounts Officer,
(Cash & Bank Section).

Phone : 033 2573-3574
Email : easterntrfr1989@gmail.com



Narayanpur, R-Gopalpur
Kolkata - 700 136

EASTERN TRANSFORMER & EQUIPMENT PRIVATE LIMITED
(ISO 9001 - 2015 COMPANY)

TRANSFORMER TEST CERTIFICATE

Rating	500 kVA	Service	Outdoor	Phase	3	Cycles	50
BIS EE L1 A4							
Volts	11000/433	Amps	26.24/666.67	Vector Group	Dyn11	Taps	$\pm 2\frac{1}{2}\%$, $\pm 5\%$
Wound	DW(CU)	Cooling	ONAN	Temp. Rise	40/45°C	W/O No.	2940/S2282
Customer	M/s. Meghalaya Power Distribution Corporation Limited					SPEC.	IS 1180 (L1A4)
P.O. No. & Date	ACE(MM)/DW-13/2023-24/17 dated 26.03.2024					Date	23.12.2024

TRANSFORMER SERIAL NO.		<u>S2282-2</u>	
No Load Loss	Watts	585	HV Resistance at 26°C
Magnetising Current	%	0.30	AB 1.334 Ohm
Load Loss	Watts	3673	BC 1.367 Ohm
Total Loss at 100% load	Watts	4258	CA 1.378 Ohm
Total Loss at 50% load	Watts	1503	
EFFICIENCY at U.P.F. & Full Load	%	99.21	LV Resistance at 26°C
¾ Load	%	99.32	ab 1.620 Milliohm
½ Load	%	99.27	bc 1.698 Milliohm
IMPEDANCE	%	4.58	ca 1.669 Milliohm
REGULATION AT U.P.F.	%	0.91	
AT 0.8 P.F.	%	3.25	
N.B.: The above data apply at 75°C and Normal Tap		TRANSFORMER OIL BREAK DOWN VALUE	
INSULATION RESISTANCE AT 26°C		Average break down value (BDV) of oil at the time of test = 64kV	
(Meggar 2500 V)	HV/E	M/Ohms	4900
(Meggar 500 V)	LV/E	M/Ohms	2700
(Meggar 2500 V)	HV/LV	M/Ohms	5700

VOLTAGE RATIO, POLARITY, PRESSURE TEST, OIL LEAKAGE TEST & VECTOR GROUP CHECKED

HIGH VOLTAGE TESTS

H.V. to L.V. and Earth	28000	Volts applied for	60	Seconds at	50	Cycles
L.V. to Earth	3000	Volts applied for	60	Seconds at	50	Cycles
Overvoltage test of twice normal at	100	Cycles for	60	Seconds		

TAPS & CONNECTIONS : See connection diagram

Date of Test : 17.12.2024

N.B. : Tests performed in accordance with IS 1180

Certified

Engineer



[Handwritten signature]
7/10/24

INSPECTORATE OF ELECTRICITY:: SHILLONG

No.IEL.III/61/2024/444

Dated Shillong, the 07th August, 2025.

APPROVAL FOR CHARGING

To,

The Assistant Executive Engineer,
Umiam Rural Distribution Sub-Division,
MePDCL, Umiam.

Ref: No.MePDCL/UDSD/T-04/2025-26/166 Dated Umiam, the 16th July, 2025..

1. Whereas, the 11 KV line drawn to M/s Eastern, Organic Farmer Producer Company Ltd at Umsli, Ri-Bhoi District, Meghalaya was inspected on 06th August, 2025 is found to be in order and conform to the Regulations of the Central Electricity Authority (Measures relating to Safety and Electric Supply) Regulations, 2023.
2. Whereas, the 11/0.43KV, 500 KVA Substation installed provide power supply to M/s Eastern, Organic Farmer Producer Company Ltd at Umsli, Ri-Bhoi District, Meghalaya was inspected on 06th August, 2025 is found to be in order and conform to the Regulations of the Central Electricity Authority (Measures relating to Safety and Electric Supply) Regulations, 2023.

Therefore, in exercised of the powers conferred by sub-section (1) of the Section 162 of the Electricity Act, 2003 (36 of 2003), approval for charging of the above Lines and Substation of 11/0.43KV, 500 KVA Substation installed provide power supply to M/s Eastern, Organic Farmer Producer Company Ltd at Umsli, Ri-Bhoi District, Meghalaya is hereby accorded under the Regulation 45 of the Central Electricity Authority (Measures relating to Safety and Electric Supply) Regulations 2023, subject to the conditions that all precautionary measures as laid down under the Electricity Act 2003, Indian Electricity Rules and Regulations is strictly followed to ensure safety.

This approval is valid for a period of 5 years w.e.f 07th August, 2025 upto 06th August, 2030 as under sub-Regulation (1) of Regulation 32 of the Central Electricity Authority (Measure relating to Safety and Electric Safety) Regulations 2023. The same should be renewal within the above date under the said Regulation for further necessary action from this end.

(I/c) Senior Electrical Inspector,
Meghalaya, Shillong

Dated Shillong, the 07th August, 2025.

Memo. No.IEL.III/61/2024/444(a)

Copy to:-

- The Executive Engineer, Umiam Distribution Division, MePDCL, Umiam for information.

(I/c) Senior Electrical Inspector.

FOR BRIGHTER TOMORROW SAVE POWER TODAY

AGREEMENT FOR SUPPLY OF ELECTRICITY (HIGH TENSION/EXTRA HIGH TENSION)



An Agreement made this the 27 day of August, 2025 between _____ name/description of the company/body/association receiving electricity _____ (hereinafter referred to as the 'the consumer' and which term shall include its successors and assigns) of the one part and the Meghalaya Power Distribution Utility Limited an electricity distribution licensee under the EA, 2003 (hereinafter referred to as the 'MePDCL' and which term shall include its successors and assigns) of the other part.

Whereas, the consumer is Eastern Ri-Bhoi Organic Farmer Producer Company here briefly mentioned the nature of business/work/activity of IHT and requires electricity of quantum 500 KVA at 11/0.4 voltage level for the purpose of _____

And, whereas, the consumer has applied to the MePDCL for supply of electricity required and the MePDCL has agreed to supply it.

Now, therefore, the parties hereto mutually agree as follows:

- (1) That the connected load shall be 480 KVA as declared in the Annexure appended hereto.
- (2) That the contracted load shall be 50 KVA for the 1st year, 480 KVA for the 2nd year, 480 KVA for the 3rd year, 480 KVA for the 4th year, 480 KVA for the 5th year.
- (3) That the consumer shall draw power of not less than 75% and not more than 100% of the contracted load.
- (4) That the consumer shall not sell the electricity supplied except utilizing it for the purpose herein before stipulated and shall not charge tariff other than those approved by the Commission from time to time.
- (5) That the provision of the EA, 2003 and the Regulations, Code and orders including tariff order, as may be made from time to time by the Meghalaya State Electricity Regulatory Commission shall apply in matters, including disputes, if any, relating to supply of electricity under this agreement.

That the consumer shall regularly and timely pay to the utility all charges as may be due for the supply of electricity.


That maintenance and replacement of the Transformer on account of failure shall be the



- (7) That the agreement shall be for a period of 5 (five) years from the date of its execution subject to renewal on terms as may be mutually agreed upon the terms and conditions thereof shall specifically be effective from the date of supply of the electricity is commenced.
- (8) That the agreement shall be terminated if the consumer on its part desires it so and gives to the MePDCL a prior notice of not less than one month or, on the part of MePDCL, if the consumer has violated any of the terms and conditions of the agreement.

Provided that on the part of the MePDCL notice shall be given to the consumer stating the reasons for the proposed termination and giving him opportunity to state his case and his statement, if any, duly considered before the agreement is terminated and the supply of electricity cut off.

IN WITNESS WHEREOF the parties hereto have set their hands and seals the date, month and year first above written.



()

For and on behalf of and by
Chief Executive Officer
Eastern Pibhoi Organic
Farmer Producer Company Limited

()

For and on behalf of and by
authorization of Meghalaya Power
Distribution Corporation Limited

Witness:

Name	Designation/Occupation	Signature
Shri W.C Khongmuid	AEE URDSD	
Shri L Laloo	Business man	
Shri C Rymbai	General Manager (ERBO)	